



Colorado Department
of Public Health
and Environment

WATER QUALITY INFORMATION BULLETIN

Highlights For November 2011

- **Agenda: Rulemaking Hearing, Rulemaking Deliberations, Administrative Action Hearing and Business Meeting, November 14, 2011**
<http://www.cdphe.state.co.us/op/wqcc/Meetings/Agenda/Agenda1111.pdf>
- **Notice of Public Rulemaking Hearing**
 - Water Quality Improvement Fund, Regulation #55 (5 CCR 1002-55)
<http://www.cdphe.state.co.us/op/wqcc/Hearings/Rulemaking/55/55.html>
- **Notice of Triennial Review Informational Hearing**
 - Colorado River Salinity Standards, Regulation #39 (5 CCR 1002-39)
<http://www.cdphe.state.co.us/op/wqcc/Hearings/IH/39trih2011.pdf>
- **Summary of Proceedings/Motions (DRAFT)**
Water Quality Control Commission Regular Meeting, October 11, 2011
<http://www.cdphe.state.co.us/op/wqcc/Meetings/MeetingSummaries/1110SUM.pdf>
- **Water Quality Control Commission Long-Range Schedule**
<http://www.cdphe.state.co.us/op/wqcc/Meetings/LRSandNotes/wqlongrange.html>
- **Explanatory Notes regarding Water Quality Commission Long-Range Schedule**
<http://www.cdphe.state.co.us/op/wqcc/Meetings/LRSandNotes/wqlongrange.html>

PUBLICATION DATE: November 3, 2011

A. PERMIT ACTIONS

1. PERMITS SENT TO PUBLIC NOTICE ON OCTOBER 21, 2011 – COMMENTS DUE BY NOVEMBER 21, 2011

The website to view public notices and drafts:

<http://www.cdphe.state.co.us/wg/PermitsUnit/PUBLICNOTICEpage.html>

2. DISCHARGE PERMITS ISSUED – SEPTEMBER 2011

<u>PERMITTEE</u>	<u>PERMIT NO.</u>	<u>COUNTY</u>	<u>DATE ISSUED</u>
Riverglen Homeowners Assoc	CO-029742	Larimer	09/15/2011
City of Victor	CO-024201	Teller	09/21/2011
Roxborough Water & Sanitation Dist	CO-041645	Douglas	09/21/2011
Colorado Retail Venutures Services, LLC	CO-048847	Mesa	09/21/2011
Upper Thompson Sanitation Dist	CO-031844	Larimer	09/26/2011
Stonegate Village Metro Dist	CO-040291	Douglas	09/26/2011
Pinery Water & Wastewater Dist	CO-041092	Douglas	09/26/2011
Leprino Foods Co Greeley Facility	CO-048860	Weld	09/26/2011
Town of Manassa	CO-042935	Conejos	09/27/2011

3. GENERAL PERMIT CERTIFICATIONS – SEPTEMBER 2011

<u>PERMITTEE</u>	<u>PERMIT NO.</u>	<u>COUNTY</u>	<u>DATE ISSUED</u>
Hydro Construction Co Inc	COG-073837	Jefferson	09/09/2011
Tezak Heavy Equipment Co Inc	COG-073838	Mineral	09/09/2011
Concrete Express Inc	COG-073839	Jefferson	09/09/2011
Hydro Construction Co Inc	COG-073841	Pitkin	09/09/2011
Brannan Construction	COG-073842	Jefferson	09/09/2011
Triad Western Constructors Inc	COG-073843	Montezuma	09/09/2011
Hamon Contractors Inc	COG-073848	El Paso	09/09/2011
Garney Construction	COG-073844	Jefferson	09/12/2011
Garney Construction	COG-073845	Park	09/12/2011
Haselden Construction. LLC	COG-073846	Arapahoe	09/12/2011
SEMA Construction Inc	COG-073847	Gunnison	09/12/2011
City of Westminster	COG-315025	Jefferson	09/15/2011
Earth Environmental Services Inc	COG-315144	Jackson	09/15/2011
Regional Transportation Dist	COG-315157	Denver	09/15/2011
Varra Co Inc	COG-500346	Weld	09/19/2011
ACA Moltz/JV	COG-073849	Eagle	09/21/2011
GLH Construction Inc	COG-073851	Weld	09/21/2011
GLH Construction Inc	COG-073852	Weld	09/21/2011
Tezak Heavy Equipment Co Inc	COG-073856	El Paso	09/21/2011
Gould Construction	COG-073853	Garfield	09/26/2011
Jefferson County – Road & bridge Div	COG-073857	Jefferson	09/26/2011
Icon Inc	COG-073858	Eagle	09/26/2011
Peabody Sage Creek Mining, LLC	COG-603191	Routt	09/26/2011
Climax Molybdenum Co Climax Mine	COG-603192	Summit	09/26/2011
Native Excavating Inc	COG-073862	Routt	09/26/2011
Red Mountain Resources, LLC	COG-601033	Logan	09/27/2011
ARCADIS U.S., Inc	COG-315146	Adams	09/28/2011
Eagle Environmental Consulting, Inc	COG-315147	Jefferson	09/28/2011
ConocoPhillips Co	COG-315165	Jefferson	09/28/2011
Terracon Consultants Inc	COG-315179	Larimer	09/28/2011
K&G Petroleum, LLC	COG-315182	Denver	09/28/2011
Sema Construction Inc	COG-315210	Adams	09/28/2011

A. PERMIT ACTIONS (cont.)

3. GENERAL PERMIT CERTIFICATIONS – SEPTEMBER 2011

<u>PERMITTEE</u>	<u>PERMIT NO.</u>	<u>COUNTY</u>	<u>DATE ISSUED</u>
Dover Industries Inc	COG-315161	Boulder	09/29/2011
ConocoPhillips Co	COG-315197	Adams	09/29/2011
ConocoPhillips Co	COG-315198	Jefferson	09/29/2011
Lawrence Construction	COG-315226	Denver	09/29/2011
Colorado Dept of Transportation	COG-315227	Denver	09/29/2011
Brown Group Retail Inc	COG-315230	Denver	09/29/2011
Kiewit Western Co	COG-315240	Denver	09/29/2011
Raytheon Co	COG-315176	Boulder	09/30/2011
Broderick Investment Co	COG-315180	Adams	09/30/2011
Jalisco International Inc	COG-315224	Denver	09/30/2011
Public Service Co of Colorado	COG-315233	Adams	09/30/2011
Public Service Co of Colorado	COG-315234	Adams	09/30/2011
Forum Real Estate	COG-315236	Boulder	09/30/2011
Hamon Contractors Inc	COG-315239	Denver	09/30/2011
Public Service Co of Colorado	COG-315241	Boulder	09/30/2011
GH Phipps Construction Co	COG-215242	Boulder	09/30/2011

(A) Denotes Amendment

B. STORMWATER DISCHARGE GENERAL PERMIT CERTIFICATIONS – AUGUST 2011

COR-010000	Light Industrial Activities	1
COR-020000	Heavy Industrial Activities	0
COR-030000	Construction Activities	108
COR-040000	Metal Mining	2
COR-060000	Recycling	0
COR-070000	Non-Standard MS4	0
COR-080000	Cherry Creek MS4	0
COR-090000	Statewide MS4	0
COR-340000	Sand and Gravel Mining	1
	No Exposure Certifications	11

Stormwater permit applications, guidance documents, general permits, etc, are available at:
<http://www.cdphe.state.co.us/wq/PermitsUnit>

C. ENFORCEMENT/CIVIL PENALTIES/CONSENT OF SETTLEMENT AGREEMENTS

Documents related to the below enforcement actions are available for public inspection at the Division. Copies of the below actions are available upon written request to the Division or, in most instances, may be obtained from the Divisions' Enforcement Action website: <http://www.cdphe.state.co.us/wq/enforcement/index.html>



Regular enforcement updates are also available on Twitter (http://twitter.com/WQCD_Enforce)

1. ENFORCEMENT – NEW ACTION

<u>RESPONSIBLE PARTY</u>	<u>ACTION</u>	<u>COUNTY</u>	<u>DATE</u>
Cotter Corp	Industrial – Notice of Violation/ Cease and Desist Order Amendment #3	Jefferson	09/27/2011
Seaboard Foods LLC	HCSFO – Order for Civil Penalty	Yuma	09/28/2011
Sunset Lake Summer Home Improvement Assoc	Drinking Water – Enforcement Order	Mesa	09/28/2011
R&M Vista Ridge, Inc	Stormwater – Notice of Violation/ Order for Civil Penalty	Boulder	09/29/2011
S&A Holdings, LLC (d/b/a Mesa Lakes Resort)	Domestic – Notice of Violation/ Cease and Desist Order Extension #3	Mesa	10/21/2011
SEMA Construction, Inc	Stormwater – Order for Civil Penalty	Clear Creek	10/21/2011
Mountain Air Ranch, Inc	Drinking Water – Enforcement Order Amendment #2	Jefferson	10/24/2011
Aspen Center for Environmental Studies (d/b/a Rock Bottom Ranch)	Drinking Water – Enforcement Order	Eagle	10/24/2011

2. CONSENT OR SETTLEMENT AGREEMENTS TO PUBLIC NOTICE

<u>RESPONSIBLE PARTY</u>	<u>ACTION</u>	<u>COUNTY</u>	<u>DATE</u>
Heyl Construction, Inc (f/k/a Heyl, LLC)	Stormwater – Compliance Order on Consent	Garfield	09/27/2011

3. FINAL AGENCY ACTIONS

NONE SINCE LAST PUBLICATION

4. NOTICE OF ENFORCEMENT HEARINGS

NONE SINCE LAST PUBLICATION

D. CONSTRUCTION ACTIONS

1. Site Applications Reviews

<u>APPLICANT</u>	<u>TYPE</u>	<u>FACILITY DESCRIPTION</u>	<u>COUNTY</u>	<u>ACTION</u>
Town of Morrison	Site Application #3732 (ES.10.42130)	Increase hydraulic and organic capacities from 0.2 MGD and 420 lbs. BOD ₅ /day to 0.35 MGD and 876 lbs. BOD ₅ /day respectively. To include: influent flow monitoring, grinder, fine screening, grit removal, SBR process including anoxic, aerobic, and settling stages, chemical feeds for phosphorus removal and alkalinity adjustment, effluent flow equalization, UV disinfection, effluent flow monitoring, discharge through existing outfall, and aerated solids storage	Jefferson	Approved 09/30/2011
City of Fort Collins – Drake Water Reclamation Facility North Process Trains Improvements	Site Application #4020 (ES.11.43331) Amendment	Convert each of the dedicated intermediate clarifiers for the two NPTs into an anaerobic basin (with two floating mixers per basin) followed by an anoxic basin within the existing clarifier volume; convert an existing influent structure to an influent mixing box that will allow the NPT influent wastewater to be mixed with RAS prior to splitting the wastewater flow to the two NPTs; install new mixed liquor internal return pumping system to return aeration basin effluent to the front of the new anoxic basins at each NPT; replace the existing centrifugal WAS pumps and VFDs with new rotary lobe pumps and VFDs of similar size and capacity; replace the existing underdrain system vertical turbine pumps; add automated flow control valves, flow meters, and a master control panel to the aeration system; add new foam/scum removal gates and boxes; add pumps and flow meters to the centrate return system	Larimer	Approved 09/24/2011
Park County School District RE-2 – Lake George Elementary School Capacity Rerating	Site Application #4279 (ES.10.41854) Amendment	Decrease the hydraulic capacities from 2,870 gpd maximum month average and 4,305 gpd peak daily flow to 1,995 gpd and 2,992 gpd	Park	Approved 09/30/2011

D. CONSTRUCTION ACTIONS (cont.)

1. Site Applications Reviews

<u>APPLICANT</u>	<u>TYPE</u>	<u>FACILITY DESCRIPTION</u>	<u>COUNTY</u>	<u>ACTION</u>
Pueblo West Metro Dist	Site Application #4388 (ES.11.43266) Amendment	Addition of grit classification and dewatering at the headworks; upgrades to the vacuum truck receiving station; and upgrading the solids handling and treatment process including removing one of the existing stabilization ponds from service, converting the other existing stabilization pond into emergency storage, and the addition of three aerobic digester cells, associated equipment including aeration grid systems, blowers, decanters, and pumps	Pueblo	Approved 10/03/2011
Pagosa Springs Sanitation Dist	Site Application #4991 (ES.11.43254) Extension	Extended the site application approval until 06/16/2012	Archuleta	Approved 09/30/2011
Town of Campo	Site Application #ES.11.43090	The current hydraulic and organic capacity ratings for the facility changed from 0.036 MGD and 42 lbs. BOD ₅ /day to 0.058 MGD and 40.5 lbs. BOD ₅ /day. Synthetic liner in Cells No. 1 and 2; yard piping influent and effluent flow metering equipment; construction of two lined parallel surface flow wetland cells; hypochlorite disinfection system, 12-inch diameter chlorine contact piping; and surface water discharge	Baca	Approved 09/21/2011
U. S. Department of the Army – Fort Carson Special Forces Complex Lift Station	Site Application #ES.11.43214	Lift Station and Force Main. Design capacities 0.037 MGD Average Capacity, 104 GPM Peak Capacity	El Paso	Approved 09/21/2011
Metro Wastewater Reclamation Dist – Northern Treatment Plant	Site Application #ES.11.43053 Correction	CORRECTION: Approval to include the following condition – Depending on the outcome of the current water rights negotiations, MWRD may not need to construct the proposed Effluent Pump Back System effluent forcemain. If it is not required, elimination of the effluent pump back station and forcemain from the project scope will not require an amendment of site approval. If it is required, MWRD must submit documentation demonstrating the full legal control of the effluent forcemain alignment for each construction phase individually prior to construction	Weld	Approved 10/10/2011

D. CONSTRUCTION ACTIONS (cont.)

1. Site Applications Reviews

<u>APPLICANT</u>	<u>TYPE</u>	<u>FACILITY DESCRIPTION</u>	<u>COUNTY</u>	<u>ACTION</u>
City and County of Broomfield	Site Application #ES.11.43335	Lift Station and Force Main. Design capacities 0.095 MGD Average Capacity, 332 GPM Peak Capacity. The two lift station sewage pumps are each sized for the 5-year peak hour flow of 332 gpm	Broomfield	Approved 10/16/2011
U. S. Department of the Army – Pueblo Chemical Agent Destruction Pilot Plant	Site Application #ES.10.41831	CORRECTION: 0.023 MGD Average Daily Flow Capacity and 37.9 lbs. BOD ₅ /day Organic Loading Capacity. Three lift stations pumping to a 64,365 gallon above-ground steel storage tank with aeration and mixing equipment	Pueblo	Approved 10/16/2011
U. S. Department of the Interior, National Park Service – Florissant Fossil Beds National Monument ISDS	Site Application #ES.11.43165	Septic tank, lift station and force main to pump effluent to the absorption field which has gravelless chambers	Teller	Approved 10/20/2011

2. Plans and Specifications Reviews

<u>APPLICANT</u>	<u>SITE APPLICATION</u>	<u>FACILITY DESCRIPTION</u>	<u>COUNTY</u>	<u>ACTION</u>
Woodmen Hills Metro Dist	Site Application #4406 (ES.10.42056) Amendment	Increase the flow capacity of the lift station back-up wet well and pump station from 0.150 MGD to 0.288 MGD, and change the receiving entity from the existing McLaughlin Lift Station back-up wet well and pumps from Cherokee Metropolitan District's old WWTF to its new Water Reclamation Facility. Replace lift station on the current site with proposed set of pumps to convey wastewater to the Paintbrush Hills WWTF	El Paso	Approved 08/05/2011
Town of Nederland	Site Application #4972 (ES.11.43241)	Elimination of a previously approved, but not constructed, treatment process train. Revised treatment which includes: influent and effluent flow metering, mechanical screening, two-train (SBR) treatment system, alkalinity addition, tertiary filtration with chemical addition, UV disinfection, and emergency sludge storage	Boulder	Approved 10/04/2011

D. CONSTRUCTION ACTIONS (cont.)

2. Plans and Specifications Reviews

<u>APPLICANT</u>	<u>SITE APPLICATION</u>	<u>FACILITY DESCRIPTION</u>	<u>COUNTY</u>	<u>ACTION</u>
Boy Scouts of America, Longs Peak Council, Inc – Ben Delatour Boy Scout Ranch	Site Application #ES.10.41833	<u>Streamlined Design Approval</u> - Packaged extended aeration treatment plant and separate, aerated septage-receiving tank with associated lift station	Larimer	Approved 03/15/2011
Taylor River Canyon, LLC	Site Application #ES.10.41842	Septic tanks, Advantex recirculating fabric filter with surface discharge	Gunnison	Approved 09/29/2011
U. S. Department of the Army – Pueblo Chemical Agent Destruction Pilot Plant	Site Application #ES.10.41831	0.023 MGD Average Daily Flow Capacity and 37.9 lbs. BOD ₅ /day Organic Loading Capacity. Three lift stations pumping to a 64,365 gallon above-ground steel storage tank with aeration and mixing equipment	Pueblo	Approved 10/17/2011

E. WATER QUALITY CERTIFICATIONS (Section 401)

Water Quality Certifications, under Section 401 of the Clean Water Act, provide for Division determinations that federally issued permits and licenses will comply with the Basic Standards and Methodologies for Surface Water, the Basic Standards for Ground Water, surface and ground water classifications and water quality standards, and all other applicable water quality requirements for the affected waters.

1. For the purposes of the antidegradation requirements found in Section 31.8 of the Basic Standards and Methodologies, the following projects have been reviewed to make a preliminary determination of the significance of such projects and a draft certification determination. Public comment on these preliminary determinations will be received for thirty days following the date of publication of this newsletter. More information on the specific projects can be obtained from John Hranac (john.hranac@state.co.us), (303) 692-3586 or Christy Pickens (christy.pickens@state.co.us), (303) 692-3584. The U.S. Army Corp of Engineers (COE) may also review these projects, under Section 404 of the Clean Water Act, and a list of their current public notice can be found on their web site.

<u>APPLICANT</u>	<u>PERMIT #</u>	<u>ACTIVITY</u>	<u>COUNTY</u>	<u>WATERBODY</u>	<u>DETERMINATION</u>
#4296 Grand Valley Irrigation Co / 185kW Dividers Guenther	FERC	Development of a low head power production site on the Grand Valley Irrigation Canal system utilizing the drop to the Lower Mainline Canal	Mesa	Colorado River, Colorado River Basin, Seg. COLCLC02b of Lower Colorado River Sub-basin	No new or increased impacts to water quality. Draft Regular Certification
#4297 Grand Valley Irrigation Co / 450kW Street Drop Guenther	FERC	Development of a power production site on the Grand Valley Irrigation Canal system utilizing the drop chute on the mainline of the canal	Mesa	Colorado River, Colorado River Basin, Seg. COLCLC02b of Lower Colorado River Sub-basin	No new or increased impacts to water quality. Draft Regular Certification

E. WATER QUALITY CERTIFICATIONS (Section 401) (cont.)

1. Preliminary Determination

APPLICANT	PERMIT #	ACTIVITY	COUNTY	WATERBODY	DETERMINATION
#4298 Telluride Energy / 11kW Silverton Johnson	FERC	Develop power from excess flow and pressure from an existing pipeline down Arrastra Gulch across the Animas River to the Mayflower Mill water treatment plant	San Juan	Animas River, San Juan River and Dolores River Basins, Seg. COSJAF03a of Animas River Sub-basin	No new or increased impacts to water quality. Draft Regular Certification
#4299 Rio Grande Canal Water Users Assoc / 140kW Del Norte Yeager	FERC	Development of a power production site at the Rio Grande Canal diversion dam on the Rio Grande. A turbine would be installed at the existing sand gate structure to utilize the head created by the dam and Rio Grande	Rio Grande	Rio Grande, Rio Grande River Basin, Seg. CORGRG04 of Rio Grande River Sub-basin	No new or increased impacts to water quality. Draft Regular Certification
#4300 Town of Pagosa Springs/San Juan River Improvements	SPK-2005-75106-DC	Construction of numerous in-stream structures for both the angler and whitewater enthusiasts within the town	Archuleta	San Juan, San Juan River Basin, Seg. COSJSJ06a of San Juan River Sub-basin	Temporary impacts to water quality only. Draft Conditional Certification
#4301 Urban Drainage & Flood Control Dist/City of Thornton	NWO-2009-1605-DEN	To prevent the 100-yr flood event from overtopping street by constructing a sloping grouted-boulder drop structure upstream and constructing a new culvert. This project will also stabilize the degrading channel	Adams	Brantner Gulch, South Platte River Basin, Seg. COSPMS03a of Middle South Platte River Sub-basin	Potential long-term water quality impacts. Draft Regular Certification

2. The following projects have received a final certification determination from the Division. For further information regarding these projects, please call the Division at (303) 692-3500.

<u>APPLICANT</u>	<u>PERMIT #</u>	<u>ACTIVITY</u>	<u>COUNTY</u>	<u>WATERBODY</u>	<u>CERTIFICATION</u>
#4287 Regional Transportation District (RTD) / Englewood Station Parking Lot	NWO-2010-2722-DEN	The overall project is to add 281 additional parking spaces to the Park-n-Ride area	Arapahoe	Little Dry Creek, South Platte River Basin, Seg. COSPUS14 of Upper South Platte River Sub-basin	Withdrawn per J. Hranac 10/28/2011

E. WATER QUALITY CERTIFICATIONS (Section 401) (cont.)

3. The following NPDES permit has been reviewed to make a proposed determination for certification in accordance with section 401 of the Federal Clean Water act. Public comment on this proposed determination will be received for thirty (30) days following the date of publication of this newsletter. More information can be obtained from Nathan Moore (Nathan.moore@state.co.us, (303) 692-3555.

NONE SINCE LAST PUBLICATION

F. FINANCIAL SOLUTIONS UNIT

1. LOAN APPLICATIONS RECEIVED

<u>ENTITY</u>	<u>AMOUNT</u>	<u>PROJECT DESCRIPTION</u>	<u>COUNTY</u>	<u>DATE</u>
Town of Crested Butte	\$972,500	The proposed project is to construct a new 600,000 gallon water storage tank at the existing Water Treatment Plant	Gunnison	10/14/2011

2. LOANS APPROVED BY CWRPDA

NONE SINCE LAST PUBLICATION

3. LOANS EXECUTED

<u>ENTITY</u>	<u>AMOUNT</u>	<u>PROJECT DESCRIPTION</u>	<u>COUNTY</u>	<u>DATE</u>
City of Monte Vista	\$400,000	The project consists of distribution system improvements which will allow for adequate chlorine residual contact time	Rio Grande	10/12/2011
Town of Blanca	\$488,050	The project consists of constructing a new storage tank adjacent to the existing tank; refit the existing water supply well; and install additional piping for improved transmission system operation	Costilla	10/14/2011

4. STATE GRANT CONTRACTS EXECUTED

NONE SINCE LAST PUBLICATION

5. \$10,000 PLANNING AND/OR DESIGN GRANTS

NONE SINCE LAST PUBLICATION

6. WATER QUALITY IMPROVEMENT FUND

NONE SINCE LAST PUBLICATION

7. DRINKING WATER ELIGIBILITY ASSESSMENT

<u>LOANEE</u>	<u>PROJECT DESCRIPTION</u>	<u>COUNTY</u>	<u>DATE</u>
Town of Crested Butte	The proposed project is to construct a new 600,000 gallon water storage tank at the existing Water Treatment Plant	Gunnison	10/06/2011

F. FINANCIAL SOLUTIONS UNIT (cont.)

8. PUBLIC HEARING/PUBLIC MEETING

NONE SINCE LAST PUBLICATION

9. FINDING OF NO SIGNIFICANT IMPACT AND CATEGORICAL EXCLUSION DETERMINATIONS

<u>LOANEE</u>	<u>PROJECT DESCRIPTION</u>	<u>COUNTY</u>	<u>DATE</u>
Allenspark Water & San Dist	The proposed project is the construction of a new Sequence Batch Reactor Wastewater Treatment Plant	Boulder	09/27/2011
Elbert Water & San Dist	The proposed project is the construction of a new water storage tank, replace deteriorating distribution line, and install new piping to loop the system	Elbert	09/26/2011
Town of Vona	The proposed project is to construct a new water storage tank, re-equip two wells, and replace the existing water meters	Kit Carson	09/26/2011
Palmer Lake San Dist	The proposed project is to extend the existing sanitary sewer system to eliminate On-site Wastewater Systems	El Paso	09/27/2011
Town of Nunn	The proposed project is the construction of a new water storage tank, a new water main from the new storage tank to the NWCWD master meter, and the replacement of water lines throughout the system	Weld	10/25/2011

10. CONSTRUCTION LOAN COMPLETIONS

<u>LOANEE</u>	<u>AMOUNT</u>	<u>PROJECT DESCRIPTION</u>	<u>COUNTY</u>	<u>DATE</u>
Town of Kremmling	\$2,000,000	Replace approximately 10,300 feet of leaking water distribution lines	Grand	10/13/2011
Town of Paonia	\$734,080	The project replaced the existing 0.81 mgd filter bag water treatment system with a new 0.81 microfiltration water treatment system; other various system improvements were included	Delta	09/22/2011
Town of Sawpit	\$100,000	The project consists of replacing approximately 2,000 ft of existing water distribution pipelines with new 1-inch, 2-inch, 3-inch & 6-inch HDPE water distribution pipelines and appurtenances; replacement of approx. 370 ft of existing water distribution pipelines using directional drilling methods; constructing a new 4,000 gallon below ground storage tank	San Miguel	09/26/2011
Rocky Ford	\$945,337.00	The project consists of installing a transmission line to the Hancock Water Company System to provide water to blend	Otero	10/06/2011

G. TOTAL MAXIMUM DAILY LOADS SENT TO PUBLIC NOTICE

NONE SINCE LAST PUBLICATION

SPECIAL NOTES

The WQCD has prepared for public review a draft of "GUIDANCE FOR DISCHARGES FROM FIRE SAFETY MAINTENANCE ACTIVITIES". The Division will be accepting comments on the draft guidance until November 28, 2011.

Comments and questions should be directed to Michelle DeLaria at the address listed below or at michelle.delaria@state.co.us. The document is available electronically on the WQCD website at: <http://www.cdphe.state.co.us/wq/PermitsUnit/PUBLICNOTICEpage.html>

WQCD-WQP-B2
4300 Cherry Creek Drive South
Denver, Colorado 80246-1530