



COLORADO
Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

COLORADO SAFE DRINKING WATER PROGRAM CALENDAR YEAR 2014 ANNUAL COMPLIANCE REPORT



Table of Contents

Introduction	3
Definitions	4
National Primary Drinking Water Regulations	5
Violations During the Calendar Year 2014.....	6
Variances and Exemptions.....	15
Report Availability and Contact Information	15

Tables

Table 1. Number of PWSs by System Type and Population	6
Table 2. Summary by Rule and Violation Type	7
Table 3. Summary of Inorganic Chemicals	8
Table 4. Summary of Nitrogen Compounds	8
Table 5. Summary of Radionuclides.....	9
Table 6. Summary of Volatile Organic Chemicals	9
Table 7. Summary of Synthetic Organic Chemicals	10
Table 8. Summary of the Consumer Confidence Report Rule	11
Table 9. Summary of Disinfectants and Disinfection Byproducts	11
Table 10. Summary of the Groundwater Rule	12
Table 11. Summary of Lead and Copper.....	12
Table 12. Summary of Microorganisms	13
Table 13. Summary of the Public Notice Rule	13
Table 14. Summary of the Surface Water Treatment Rule	14

Appendix

Appendix A: PWSs with Health-Based Violations	16
---	----

Introduction

The United States Environmental Protection Agency (EPA) established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 Amendments, EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs). For some regulations EPA establishes treatment techniques (TTs) in lieu of MCLs. Standards were also set on how often public water systems (PWSs) monitor their water for contaminants and report the sample results. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M&R) requirements. In addition, EPA requires select PWSs to monitor for unregulated contaminants to provide data for future regulatory development. The 1996 Amendments to the SDWA require public notification to include a clear and understandable explanation of the nature of each violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation, and the possibility of alternative water supplies during the violation. The Colorado Department of Public Health and Environment's (CDPHE) Safe Drinking Water Program (SDWP) implements the SDWA, with amendments, pursuant to the Colorado Primary Drinking Water Regulations, Regulation 11 (CPDWR) for the State of Colorado.

The Annual Compliance Report (ACR) is intended to provide a total annual representation of the numbers of violations. Violations fall into 1 of 4 categories:

- Health-Based
 1. Maximum Contaminant Level (MCL)
 2. Treatment Technique (TT)
- Non-Health-Based
 3. Monitoring and/or Reporting (M&R)
 4. Public Notice (PN)

This report was prepared to meet the EPA's reporting requirements and is updated on a yearly basis. This report is available at <https://www.colorado.gov/cdphe/drinking-water-consumer-information>.

Definitions

- **Public Water System (PWS):** Provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are 3 types of PWSs:
 - Community (e.g. cities, or towns)
 - Non-Transient, Non-Community (e.g. schools, or factories)
 - Transient, Non-Community systems (e.g. restaurants, rest stops, or parks)
- **Health-Based:** Potential short-term or long-term health risks.
 - **Maximum Contaminant Level (MCL):** The highest level of a contaminant allowed in drinking water. Note: Under the Lead and Copper Rule, MCLs were not established. For this rule, “action levels” rather than MCLs define the levels at which a public water system must take action to reduce the concentration of lead and/or copper.
 - **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant (added for the treatment of water) allowed in drinking water. MRDLs are enforceable in the same manner as MCLs.
 - **Treatment Techniques (TT):** Unacceptable levels, in lieu of a MCL, for selected water characteristics or a failure to correct an identified issue. Turbidity, for example, which measures the cloudiness of water.
- **Non-Health-Based:** No health risks or health risks are unknown.
 - **Monitoring and Reporting (M&R):** To monitor, test, and report for water characteristics (e.g. contaminants) present in drinking water. All minor and major violations are included.
 - **Public Notice (PN):** A requirement for the PWS to notify their customers of any and all violations. PN requirements take into account the seriousness of the violation (or situation) and any potential adverse health effects that may be involved.
- **Variance:** A departure from a primary drinking water regulation if the characteristics of the raw water sources available to the PWS do not allow the system to meet the MCL.
- **Exemption:** Temporarily relieves a PWS of its obligation to comply with an MCL, TT, or both, due to compelling factors (which may include economic factors).

National Primary Drinking Water Regulations

The Safe Drinking Water Act (SDWA) is the federal law that regulates the quality of drinking water. The SDWA sets standards for drinking water quality and stipulates the monitoring requirements for PWSs. The following regulations have been promulgated under the SDWA:

- Chemical Phase Rule: Provide public health protection through the reduction of chronic risk (e.g. cancer, organ damage, etc.) from the exposure of:
 - Inorganic Chemicals (IOCs)
 - Nitrate and Nitrite (NOX)
 - Synthetic Organic Chemicals (SOCs)
 - Volatile Organic Chemicals (VOCs)
 - Radionuclides (RADs)
- Consumer Confidence Report (CCR): An annual drinking water quality report distributed by PWSs to their customers by July 1st. The report contains information regarding sources used (i.e. rivers, lakes, reservoirs, etc.), detected contaminants, violations, and educational information.
- Microbial, Disinfectants, and Disinfection Byproducts (MICRO, DIS, and DBPs): In general, drinking water must be disinfected to inactivate microbial pathogens (e.g. *E. coli*, salmonella, etc.). To protect against potential microbial contamination, PWSs add disinfectants such as chlorine. However, disinfectants can react with naturally occurring material in the source water and form byproducts, which may pose adverse health risks. PWSs must carefully maintain a balance between addressing potential microbial contamination and byproduct formation. The following rules address this issue:
 - Groundwater Rule (GWR): The purpose of the GWR is to provide increased protection against microbial pathogens in PWSs that utilize groundwater sources.
 - Stage 2 Disinfectant and Disinfection Byproduct Rules (DBPs): The purpose of these rules is to reduce exposure to disinfection byproducts for customers of PWSs that add a disinfectant to the drinking water during any part of the treatment process.
 - Surface Water Treatment Rules (SWTRs): The purpose of the SWTRs is to prevent waterborne diseases caused by viruses, *Giardia*, and *Cryptosporidium*. The rules require surface water systems to filter and disinfect their water to reduce the occurrence of microbial contamination.
 - Total Coliform Rule (TCR): Provide public health protection by maintaining the integrity of the distribution system and requiring public water systems to monitor for the presence of microbial contamination.
- Lead and Copper Rule (LCR): Protect public health by minimizing the public's exposure to lead and copper.
- Public Notice Rule (PN): Require PWSs to notify their customers of any drinking water violations or situations that may pose an adverse health risk.

Violations During the Calendar Year 2014

Calendar Year 2014 Overview

The number of PWSs in the state changes on a day by day basis. This is due to seasonal operations, new PWSs opening, existing PWSs closing, and changes to the population being served. Table 1 displays a typical number of systems, on any one day, by population and system type.

Table 1. Number of PWSs by System Type and Population

Population	Water System Type			
	Community	Non-Transient, Non-Community	Transient, Non-Community	Total
25-500	505	134	883	1522
501-3,300	207	24	75	306
3,301-10,000	79	6	8	93
10,001-100,000	73	0	0	73
>100,000	9	0	0	9
Total	873	164	966	2003

Violations are based on data compiled in June, 2015 from Colorado’s production SDWIS/State database. If a violation: (1) was unresolved as of January 1, 2014, or (2) occurred in calendar year 2014 it was included. M&R violations for PWSs that sample less frequently than annually will be reported in the third, sixth, or ninth year of a compliance cycle. Calendar year 2014 was the first year in a compliance cycle. Table 2 summarizes the number of violations and the number of systems by each drinking water rule and violation type and tables 3 - 14 provide further details for each of the drinking water rules.

Appendix A identifies the public water systems that were in violation of maximum contaminant levels and/or treatment technique requirements in calendar year 2014. The final column indicates if the violation was resolved.

Summary of All Violations

- 89 systems in violation of at least one of the MCLs.
- 46 systems in violation of at least one of the TTs.
- 387 systems failed to monitor/report for at least one of the rules.
- 12 systems failed to notify their customers.

Table 2. Summary by Rule and Violation Type

Group	Maximum Contaminant Level Violations		Monitoring & Reporting Violations		Public/State Notification Violations		Treatment Technique Violations	
	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
Consumer Confidence (CCR) Totals:	-	-	34	34	-	-	-	-
Disinfectants (DIS) & Disinfection Byproducts (DBPs) Totals:	51	17	203	114	-	-	4	3
Ground Water (GW) Totals:	-	-	10	9	-	-	5	5
Inorganics (IOCs) Totals:	25	4	86	9	-	-	-	-
Lead and Copper (LCR) Totals:	-	-	74	65	-	-	-	-
Microorganisms (MICRO) Totals:	28	23	220	158	-	-	-	-
Nitrogen (NITs) Totals:	65	17	126	112	-	-	-	-
Public Notice (PN) Totals:	-	-	-	-	13	12	-	-
Radionuclides (RADs) Totals:	359	32	17	8	-	-	-	-
Surface Water (SW) Totals:	-	-	99	39	-	-	74	38
Synthetic Organics (SOCs) Totals:	-	-	160	10	-	-	-	-
Volatile Organics (VOCs) Totals:	-	-	358	16	-	-	-	-
Total:	528	89	1387	387	13	12	83	46

Inorganic Chemical Violations (not including Nitrogen Compounds and Radionuclides)

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 4 systems in violation of at least one of the MCLs.
- 9 systems failed to monitor/report for at least one of the contaminants.

Table 3. Summary of Inorganic Chemicals

Inorganics (IOCs)				
Contaminant	Maximum Contaminant Level Violations		Monitoring & Reporting Violations	
Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
ANTIMONY, TOTAL	-	-	7	6
ARSENIC	8	2	7	6
BARIUM	-	-	7	6
BERYLLIUM, TOTAL	-	-	7	6
CADMIUM	-	-	7	6
CHROMIUM	-	-	7	6
FLUORIDE	12	1	9	8
MERCURY	-	-	7	6
NICKEL	-	-	7	6
SELENIUM	5	1	7	6
SODIUM	-	-	7	6
THALLIUM, TOTAL	-	-	7	6
Inorganics (IOCs) Totals:	25	4	86	9

Nitrogen Compound Violations

- All PWSs are required to comply.
- 0 systems in violation for Nitrite.
- 17 systems in violation of the Nitrate MCL.
- 112 systems failed to monitor/report for Nitrate.

Table 4. Summary of Nitrogen Compounds

Nitrogen (NITs)				
Contaminant	Maximum Contaminant Level Violations		Monitoring & Reporting Violations	
Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
NITRATE	65	17	126	112
Nitrogen (NITs) Totals:	65	17	126	112

Radionuclide Violations

- Community PWSs are required to comply.
- 32 systems in violation of at least one of the MCLs.
- 8 systems failed to monitor/report for at least one of the contaminants.

Table 5. Summary of Radionuclides

Radionuclides (RADs)				
Contaminant	Maximum Contaminant Level Violations		Monitoring & Reporting Violations	
Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
COMBINED RADIUM (-226 & -228)	211	23	7	6
COMBINED URANIUM	79	10	6	4
GROSS ALPHA, EXCL. RADON & U	69	12	4	3
Radionuclides (RADs) Totals:	359	32	17	8

Volatile Organic Chemical Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 0 systems in violation of at least one of the MCLs.
- 16 systems failed to monitor/report for at least one of the contaminants.

Table 6. Summary of Volatile Organic Chemicals

Volatile Organics (VOCs)				
Contaminant	Maximum Contaminant Level Violations		Monitoring & Reporting Violations	
Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
1,1,1-TRICHLOROETHANE	-	-	17	15
1,1,2-TRICHLOROETHANE	-	-	17	15
1,1-DICHLOROETHYLENE	-	-	17	15
1,2,4-TRICHLOROBENZENE	-	-	17	15
1,2-DICHLOROETHANE	-	-	17	15
1,2-DICHLOROPROPANE	-	-	17	15
BENZENE	-	-	17	15
CARBON TETRACHLORIDE	-	-	17	15
CHLOROETHYLENE	-	-	17	15
CIS-1,2-DICHLOROETHYLENE	-	-	17	15
DICHLOROMETHANE	-	-	17	15
ETHYLBENZENE	-	-	17	15
O-DICHLOROETHYLENE	-	-	17	15
P-DICHLOROETHYLENE	-	-	17	15
STYRENE	-	-	17	15
TETRACHLOROETHYLENE	-	-	17	15
TOLUENE	-	-	17	15
TRANS-1,2-DICHLOROETHYLENE	-	-	17	15
TRICHLOROETHYLENE	-	-	17	15
VINYL CHLORIDE	-	-	17	15
XYLENES, TOTAL	-	-	18	16
Volatile Organics (VOCs) Totals:	-	-	358	16

Synthetic Organic Chemical Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 0 systems in violation of at least one of the MCLs.
- 10 systems failed to monitor/report for at least one of the contaminants.

Table 7. Summary of Synthetic Organic Chemicals

Synthetic Organics (SOCs)				
Contaminant Name	Maximum Contaminant Level Violations		Monitoring & Reporting Violations	
	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
1,2-DIBROMO-3-CHLOROPROPANE	-	-	5	5
2,4,5-TP	-	-	5	5
2,4-D	-	-	5	5
ALDCARB	-	-	5	5
ALDCARB SULFONE	-	-	5	5
ALDCARB SULFOXIDE	-	-	5	5
ATRAZINE	-	-	5	5
BENZO(A)PYRENE	-	-	5	5
BHC-GAMMA	-	-	5	5
CARBOFURAN	-	-	5	5
CHLORDANE	-	-	5	5
DALAPON	-	-	5	5
DI(2-ETHYLHEXYL)ADIPATE	-	-	5	5
DI(2-ETHYLHEXYL)PHTHALATE	-	-	9	9
DNOSEB	-	-	5	5
DQUAT	-	-	6	6
ENDOTHALL	-	-	5	5
ENDRN	-	-	5	5
ETHYLENE DIBROMIDE	-	-	5	5
HEPTACHLOR	-	-	5	5
HEPTACHLOR EPOXIDE	-	-	5	5
HEXACHLOROBENZENE	-	-	5	5
HEXACHLOROCYCLOPENTADIENE	-	-	5	5
LASSO	-	-	5	5
METHOXYCHLOR	-	-	5	5
OXAMYL	-	-	5	5
PENTACHLOROPHENOL	-	-	5	5
PICLORAM	-	-	5	5
SIMAZINE	-	-	5	5
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	-	-	5	5
TOXAPHENE	-	-	5	5
Synthetic Organics (SOCs) Totals:	-	-	160	10

Consumer Confidence Report (CCR) Rule Violations

- Community PWSs are required to comply.
- 34 PWSs in violation for failing to report to their customers.

Table 8. Summary of the Consumer Confidence Report Rule

Consumer Confidence (CCR)									
Violation		Maximum Contaminant Level Violations		Monitoring & Reporting Violations		Public/State Notification Violations		Treatment Technique Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
71 - CCR REPORT	CONSUMER CONFIDENCE RULE	-	-	34	34	-	-	-	-
Consumer Confidence (CCR) Totals:		-	-	34	34	-	-	-	-

Disinfectants & Disinfection Byproducts Rule Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 17 systems in violation of at least one of the MCLs.
- 114 systems failed to monitor/report for at least one of the contaminants.

Table 9. Summary of Disinfectants and Disinfection Byproducts

Disinfectants (DIS) & Disinfection Byproducts (DBPs)									
Violation		Maximum Contaminant Level Violations		Monitoring & Reporting Violations		Public/State Notification Violations		Treatment Technique Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
02 - MCL, AVERAGE	BROMATE	2	2	-	-	-	-	-	-
	TOTAL HALOACETIC ACIDS (HAA5)	14	5	-	-	-	-	-	-
	TTHM	35	11	-	-	-	-	-	-
12 - QUALIFIED OPERATOR FAILURE	DBP STAGE 1	-	-	-	-	-	-	1	1
46 - INADEQUATE DBP PRECURSOR REMOVAL	CARBON, TOTAL	-	-	-	-	-	-	3	2
27 - MONITORING, ROUTINE (DBP), MAJOR	BROMATE	-	-	1	1	-	-	-	-
	CHLORINE	-	-	83	65	-	-	-	-
	CHLORITE	-	-	2	1	-	-	-	-
	TOTAL HALOACETIC ACIDS (HAA5)	-	-	54	49	-	-	-	-
	TTHM	-	-	56	51	-	-	-	-
27 - MONITORING, ROUTINE (DBP), MINOR	TOTAL HALOACETIC ACIDS (HAA5)	-	-	4	4	-	-	-	-
	TTHM	-	-	3	3	-	-	-	-
Disinfectants (DIS) & Disinfection Byproducts (DBPs) Totals:		51	17	203	114	-	-	4	3

Groundwater Rule Violations

- PWSs with a groundwater source not treated to surface water standards are required to comply.
- 5 systems in violation for failing to address one or more field discovered significant deficiency.
- 9 systems failed to monitor/report their source water for *E. coli*.

Table 10. Summary of the Groundwater Rule

Ground Water (GW)									
Violation		Maximum Contaminant Level Violations		Monitoring & Reporting Violations		Public/State Notification Violations		Treatment Technique Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
45 - FAILURE ADDRESS DEFICIENCY (GWR)	GROUNDWATER RULE	-	-	-	-	-	-	5	5
34 - MONITORING, SOURCE (GWR), MAJOR	E. COLI	-	-	10	9	-	-	-	-
Ground Water (GW) Totals:		-	-	10	9	-	-	5	5

Lead and Copper Rule Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 65 systems failed to monitor/report.

Table 11. Summary of Lead and Copper

Lead and Copper (LCR)									
Violation		Maximum Contaminant Level Violations		Monitoring & Reporting Violations		Public/State Notification Violations		Treatment Technique Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
51 - INITIAL TAP SAMPLING (LCR)	LEAD & COPPER RULE	-	-	1	1	-	-	-	-
52 - FOLLOW-UP OR ROUTINE TAP M/R (LCR)	LEAD & COPPER RULE	-	-	58	58	-	-	-	-
53 - WATER QUALITY PARAMETER M/R (LCR)	LEAD & COPPER RULE	-	-	2	1	-	-	-	-
56 - INITIAL/FOLLOW-UP/ROUTINE SOWT M/R (LCR)	LEAD & COPPER RULE	-	-	4	4	-	-	-	-
57 - OCCT/SOWT RECOMMENDATION/STUDY (LCR)	LEAD & COPPER RULE	-	-	6	6	-	-	-	-
65 - PUBLIC EDUCATION (LCR)	LEAD & COPPER RULE	-	-	3	3	-	-	-	-
Lead and Copper (LCR) Totals:		-	-	74	65	-	-	-	-

Microorganisms (Total Coliform & *E. coli*) Violations

- All PWSs are required to comply.
- 23 systems in violation with at least one of the MCLs. 1 system was a potential immediate health risks and public notification was required within 24 hours of the problem being identified. This may have included a boil or bottled water order with increased monitoring.
- 158 systems failed to monitor/report for total coliform.

Table 12. Summary of Microorganisms

Microorganisms (MICRO)									
Violation		Maximum Contaminant Level Violations		Monitoring & Reporting Violations		Public/State Notification Violations		Treatment Technique Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
21 - MCL (TCR), ACUTE	COLIFORM (TCR)	1	1	-	-	-	-	-	-
22 - MCL (TCR), MONTHLY	COLIFORM (TCR)	27	22	-	-	-	-	-	-
03 - MONITORING, ROUTINE MAJOR	E. COLI	-	-	1	1	-	-	-	-
23 - MONITORING (TCR), ROUTINE MAJOR	COLIFORM (TCR)	-	-	181	135	-	-	-	-
24 - MONITORING (TCR), ROUTINE MINOR	COLIFORM (TCR)	-	-	25	20	-	-	-	-
25 - MONITORING (TCR), REPEAT MAJOR	COLIFORM (TCR)	-	-	11	10	-	-	-	-
26 - MONITORING (TCR), REPEAT MINOR	COLIFORM (TCR)	-	-	2	2	-	-	-	-
Microorganisms (MICRO) Totals:		28	23	220	158	-	-	-	-

Public Notice Rule Violations

- All PWSs that incurred a violation or posed an adverse health risk are required to comply.
- 12 systems failed to provide public notice to their customers.

Table 13. Summary of the Public Notice Rule

Public Notice (PN)									
Violation		Maximum Contaminant Level Violations		Monitoring & Reporting Violations		Public/State Notification Violations		Treatment Technique Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
05 - NOTIFICATION, STATE	NITRATE	-	-	-	-	1	1	-	-
75 - PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	-	-	-	-	8	7	-	-
76 - PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	-	-	-	-	4	4	-	-
Public Notice (PN) Totals:		-	-	-	-	13	12	-	-

Surface Water Treatment Rule Violations

- Surface Water and Groundwater-Under-the-Direct-Influence-of-Surface-Water PWSs are required to comply.
- 38 systems in violation for either inadequate filtration resulting in high turbidity (cloudiness) of the water, inadequate disinfection, or failure to filter.
- 39 systems failed to monitor/report for either turbidity or chlorine disinfectant residual.

Table 14. Summary of the Surface Water Treatment Rule

Surface Water (SW)									
Violation		Maximum Contaminant Level Violations		Monitoring & Reporting Violations		Public/State Notification Violations		Treatment Technique Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
41 - RES DISINFECT CONCENTRATION (SWTR)	CHLORINE	-	-	-	-	-	-	20	11
42 - FAILURE TO FILTER (SWTR)	SWTR	-	-	-	-	-	-	16	15
43 - SINGLE COMB FLTR EFFLUENT (ESWTR/LTI)	TURBIDITY	-	-	-	-	-	-	10	7
44 - MONTHLY COMB FLTR EFFLUENT (ESWTR/LTI)	TURBIDITY	-	-	-	-	-	-	28	12
36 - MONITORING, RTN/RPT MAJOR (SWTR - FILTER)	CHLORINE	-	-	67	34	-	-	-	-
36 - MONITORING, RTN/RPT MINOR (SWTR - FILTER)	CHLORINE	-	-	12	7	-	-	-	-
38 - MONITORING, ROUTINE (ESWTR/LTI), MAJOR	TURBIDITY	-	-	16	8	-	-	-	-
38 - MONITORING, ROUTINE (ESWTR/LTI), MINOR	TURBIDITY	-	-	4	3	-	-	-	-
Surface Water (SW) Totals:		-	-	99	39	-	-	74	38

Variations and Exemptions

For the calendar year 2014, Colorado's Safe Drinking Water Program did not issue any variations or exemptions to any public water system.

Report Availability and Contact Information

The 2014 summary report is available at <https://www.colorado.gov/cdphe/drinking-water-consumer-information>.

For further information concerning this report, or with specific violations associated with public water systems, you may contact Phillip Stanwood with the Safe Drinking Water Compliance Assurance Section at (303) 692-3502 or by email at Phillip.Stanwood@state.co.us.

Appendix A: PWSs with Health-Based Violations

PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2014?
CO0150100	A And B Wa Inc	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0160050	Alpine Village Llc	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	No
CO0126117	Antelope Hills Assoc	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	Yes
CO0261118	Anton Supers	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0111100	Antonito Town Of	Treatment Technique	CHLORINE	No
CO0261002	Arickaree School	Maximum Contaminant Level	NITRATE	Yes
CO0123123	Asgard Subdivision Wa	Maximum Contaminant Level	NITRATE	No
			SELENIUM	No
CO0214142	Bear Creek Loa	Treatment Technique	TURBIDITY	No
CO0135138	Berthoud Town Of	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0151100	Beulah Water Works District	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0115152	Bone Mesa Domestic Wd	Treatment Technique	SWTR	No
CO0151150	Boone Town Of	Treatment Technique	CHLORINE	No
		Maximum Contaminant Level	NITRATE	No
CO0262152	Borderline Cantina	Maximum Contaminant Level	NITRATE	No
CO0215202	Bowie Mine No2	Maximum Contaminant Level	TOTAL HALOACETIC ACIDS (HAA5)	Yes
CO0136300	Branson Town Of	Treatment Technique	SWTR	No
CO0101030	Brighton Mhp	Maximum Contaminant Level	NITRATE	No
CO0132005	Burlington City Of	Maximum Contaminant Level	NITRATE	No
CO0238002	Caliche School	Maximum Contaminant Level	TTHM	Yes
CO0121080	Camelot Property Owners Assoc	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	No
CO0235172	Camp Timberline	Treatment Technique	TURBIDITY	No
CO0123167	Carbondale Town Of	Treatment Technique	CHLORINE	No
CO0262171	Ceesi	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0145090	Cheraw Town Of	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	No
CO0233300	Climax Climax Mine	Treatment Technique	TURBIDITY	No
CO0151200	Colorado City Md	Maximum Contaminant Level	TTHM	No
CO0234240	Colvig Silver Camps	Treatment Technique	SWTR	No

PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2014?
CO0111300	Conejos Ws	Treatment Technique	GROUNDWATER RULE	Yes
CO0235185	Covenant Heights Conference Center	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED URANIUM	No
			COMBINED RADIUM (-226 & -228)	No
CO0230052	Crossroads Restaurant	Maximum Contaminant Level	NITRATE	No
CO0260040	Crystola Bar And Grill	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0333150	Dexter Point Cg	Maximum Contaminant Level	NITRATE	No
CO0160275	Divide South	Treatment Technique	CHLORINE	No
CO0235221	Dripping Springs Bed And Breakfast Inn	Treatment Technique	TURBIDITY	Yes
CO0145120	East End Wa	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	No
CO0242150	Echo Basin Ranch	Treatment Technique	SWTR	Yes
CO0107246	Eldorado Artesian Spring Inc	Treatment Technique	GROUNDWATER RULE	No
CO0247017	Eleven Mile Ranch Hoa	Maximum Contaminant Level	NITRATE	Yes
CO0145150	Eureka Wc	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED RADIUM (-226 & -228)	No
CO0254138	Euzoa Bible Church	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0145180	Fayette Wc	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED RADIUM (-226 & -228)	No
CO0160175	Florissant Wsd	Treatment Technique	SWTR	No
		Maximum Contaminant Level	TTHM	No
CO0153285	Foothills Ws	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0235346	Fort Collins Koa Lakeside Cg	Treatment Technique	CHLORINE	No
CO0145210	Fowler Town Of	Maximum Contaminant Level	TTHM	No
CO0159055	Frisco Town Of	Maximum Contaminant Level	COLIFORM (TCR)	Yes
CO0130035	Genesee Wsd	Treatment Technique	CHLORINE	No
CO0330325	Goose Creek Cg	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0119321	Green Acres Mhp	Treatment Technique	TURBIDITY	No
CO0130045	Hidden Valley Mutual Wc	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	Yes
			COMBINED URANIUM	Yes
			COMBINED RADIUM (-226 & -228)	No
CO0223343	Hideout Cabins And Cg	Maximum Contaminant Level	COLIFORM (TCR)	No

PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2014?
CO0102300	High Valley Mhp	Maximum Contaminant Level	ARSENIC	Yes
CO0160200	Highland Lakes Wd	Maximum Contaminant Level	NITRATE	No
CO0235345	Hill Top General Store	Treatment Technique	SWTR	No
			CHLORINE	No
		Maximum Contaminant Level	COLIFORM (TCR)	No
CO0145300	Hilltop Wc	Maximum Contaminant Level	BROMATE	No
CO0145330	Holbrook Center Soft Wa	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	No
CO0128400	Huajatolla Valley Estates Inc	Treatment Technique	SWTR	Yes
CO0162359	Hudson Town Of	Maximum Contaminant Level	TTHM	No
CO0325165	Idlewild Cg	Treatment Technique	GROUNDWATER RULE	No
CO0109011	Kit Carson Town Of	Maximum Contaminant Level	COMBINED URANIUM	No
CO0208440	Koa Buena Vista	Maximum Contaminant Level	NITRATE	No
CO0238006	Kuskies Cafe	Treatment Technique	GROUNDWATER RULE	No
CO0203724	Lds Strasburg	Maximum Contaminant Level	COLIFORM (TCR)	Yes
CO0134570	Lightner Creek Mhp	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0235283	Livermore Ws	Treatment Technique	TURBIDITY	No
CO0145450	Manzanola Town Of	Maximum Contaminant Level	COMBINED URANIUM	No
CO0107502	Maple Grove Wd	Maximum Contaminant Level	COLIFORM (TCR)	Yes
CO0150800	May Valley Wa	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED RADIUM (-226 & -228)	No
CO0207504	Meadow Mtn Water Supply	Treatment Technique	TURBIDITY	Yes
CO0138025	Merino Town Of	Maximum Contaminant Level	COMBINED URANIUM	No
CO0123510	Mitchell Cooper Ditch Pipeline	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0108420	Monarch Mountain Lodge	Treatment Technique	SWTR	No
			CHLORINE	No
CO0206524	Mountain Prairie Llc	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0151350	Mountain Shadows Mobile Estates	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	No
CO0130100	Mountain Wsd	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
CO0130090	Mt Vernon Country Club	Treatment Technique	CHLORINE	No
CO0145630	North Holbrook Wc	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	No
CO0157500	Norwood Water Commission	Maximum Contaminant	TTHM	No

PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2014?
		Level		
CO0154566	Oak Creek Town Of	Maximum Contaminant Level	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0144025	Pagels Tp	Maximum Contaminant Level	COMBINED URANIUM	No
CO0115601	Paonia Town Of	Treatment Technique	SWTR	No
CO0225733	Parshall Inn The	Maximum Contaminant Level	NITRATE	No
CO0145540	Patterson Valley Wc	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED RADIUM (-226 & -228)	No
CO0238605	Peetz Table Wind Energy Farm	Maximum Contaminant Level	ARSENIC	Yes
CO0138030	Peetz Town Of	Treatment Technique	GROUNDWATER RULE	No
CO0122700	Penrose Wd	Maximum Contaminant Level	TTHM	No
CO0154609	Phippsburg Town Of	Treatment Technique	TURBIDITY	No
CO0151450	Pine Drive Wd	Maximum Contaminant Level	COLIFORM (TCR)	Yes
CO0118050	Ponderosa Retreat And Conference Ctr	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED RADIUM (-226 & -228)	No
CO0101125	Prairie View Poa	Maximum Contaminant Level	TOTAL HALOACETIC ACIDS (HAA5)	No
			TTHM	No
CO0260600	Quaker Ridge Camp	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0239666	Rainbow Rv And Trailer Park	Treatment Technique	SWTR	No
CO0211700	Rainbow Trout Ranch	Treatment Technique	SWTR	Yes
CO0219666	Rancho Del Rio	Treatment Technique	SWTR	No
CO0145570	Riverside Wc	Maximum Contaminant Level	COLIFORM (TCR)	No
			COMBINED RADIUM (-226 & -228)	No
CO0262724	Roggen Central Food And Gas	Maximum Contaminant Level	NITRATE	No
CO0151700	Rye Town Of	Treatment Technique	TURBIDITY	No
		Maximum Contaminant Level	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0155800	Saguache Town Of	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0107702	San Souci Mhp	Treatment Technique	SWTR	Yes
CO0260700	Sanborn Western Camps	Maximum Contaminant Level	NITRATE	No
CO0131800	Sheridan Lake Wc	Maximum Contaminant Level	COMBINED URANIUM	No
CO0251743	Signal Mountain Ranch Property Owners Wc	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED RADIUM (-226 & -228)	No

PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2014?
CO0156600	Silverton Town Of	Treatment Technique	DBP STAGE 1	Yes
CO0153718	South Fork Heights Apartments	Treatment Technique	CHLORINE	Yes
CO0145690	South Swink Wc	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED RADIUM (-226 & -228)	No
CO0138045	Sterling City Of	Maximum Contaminant Level	TTHM	Yes
			COMBINED URANIUM	Yes
CO0115726	Stucker Mesa Domestic Wc	Treatment Technique	SWTR	No
CO0123500	Sun Meadow Estates	Maximum Contaminant Level	TTHM	No
			COMBINED URANIUM	No
CO0135725	Sunrise Ranch	Treatment Technique	CARBON, TOTAL	No
CO0145720	Swink Town Of	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	Yes
CO0247041	Tarryall River Ranch	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0157900	Telluride Pines Hoa	Treatment Technique	TURBIDITY	Yes
CO0263321	The Grainery	Maximum Contaminant Level	NITRATE	No
CO0154743	Timbers Wsd	Maximum Contaminant Level	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0101157	Todd Creek Village Md	Treatment Technique	TURBIDITY	No
CO0154755	Tree Haus Md	Treatment Technique	TURBIDITY	No
CO0210014	Tributary	Treatment Technique	TURBIDITY	No
CO0121841	Turkey Canon Ranch Wd	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED URANIUM	No
CO0230063	Twins Inn Inc	Maximum Contaminant Level	COLIFORM (TCR)	No
CO0105700	Two Buttes Town Of	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	Yes
CO0121845	Us Air Force Academy	Maximum Contaminant Level	TTHM	Yes
CO0108925	Ute Heights Community Ws	Maximum Contaminant Level	FLUORIDE	No
CO0134790	Ute Pass Wa Inc	Treatment Technique	CARBON, TOTAL	No
CO0145750	Valley Wc	Maximum Contaminant Level	GROSS ALPHA, EXCL. RADON & U	No
			COMBINED RADIUM (-226 & -228)	No
CO0105800	Vilas Town Of	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	No
CO0145780	Vroman Wc	Maximum Contaminant Level	COMBINED RADIUM (-226 & -228)	No
CO0162833	Wattenburg Improvement Assoc	Maximum Contaminant Level	NITRATE	Yes
CO0145810	West Grand Valley Wa	Maximum Contaminant Level	BROMATE	No
CO0144035	Wiggins Town Of	Maximum Contaminant	NITRATE	Yes

PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2014?
		Level		
CO0251700	Xcel Energy Comanche Plant	Treatment Technique	TURBIDITY	No
CO0254185	Xcel Energy Hayden Station	Treatment Technique	CHLORINE	No
CO0154900	Yampa Town Of	Treatment Technique	SWTR	No