



**COLORADO**  
Department of Public  
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

# COLORADO SAFE DRINKING WATER PROGRAM CALENDAR YEAR 2017 ANNUAL COMPLIANCE REPORT

This report is available at [colorado.gov/cdphe/drinking-water-consumer-information](http://colorado.gov/cdphe/drinking-water-consumer-information)



# Table of Contents

<b>Introduction</b>	<b>4</b>
<b>Definitions</b>	<b>4</b>
<b>National Primary Drinking Water Regulations</b>	<b>6</b>
<b>Violations</b>	<b>7</b>
Overview	8
Summary of All Violations	8
Inorganic Chemical Violations (not including Nitrogen Compounds and Radionuclides)	10
Nitrogen Compound Violations	10
Radionuclide Violations	11
Volatile Organic Chemical Violations	11
Synthetic Organic Chemical Violations	12
Consumer Confidence Report (CCR) Rule Violations	13
Cross Connection Control and Backflow Prevention Rule Violations	13
Disinfection Violations	14
Disinfection Byproducts Rule Violations	15
Chlorite and Bromate Rule Violations	15
Total Trihalomethanes and Haloacetic Acids Rule Violations	15
Groundwater Rule Violations	15
Lead and Copper Rule Violations	16
Notification, Record Keeping, and Monitoring Plan Violations	16
Operator Certification Rule Violations	17
Plans and Specification Violations	17
Public Notice Rule Violations	17
Revised Total Coliform Rule (Microbial) Violations	18
Sanitary Survey Rule Violations	18
Storage Tank Rule Violations	19
Surface Water Treatment Rule Violations	20
Water Hauler Rule Violations	21
<b>Variances and Exemptions</b>	<b>22</b>
<b>Report Availability and Contact Information</b>	<b>22</b>





## Tables

Table 1. Number of PWSs by System Type and Population	8
Table 2. Summary by Rule and Violation Type	9
Table 3. Summary of Inorganic Chemicals	10
Table 4. Summary of Nitrogen Compounds	10
Table 5. Summary of Radionuclides	11
Table 6. Summary of Volatile Organic Chemicals	11
Table 7. Summary of Synthetic Organic Chemicals	12
Table 8. Summary of the Consumer Confidence Report	13
Table 9. Summary of Cross Connection Control and Backflow Prevention	13
Table 10. Summary of Disinfection	14
Table 11. Summary of the Chlorite and Bromate	15
Table 12. Summary of Total Trihalomethanes and Haloacetic Acids	15
Table 13. Summary of the Groundwater	15
Table 14. Summary of Lead and Copper	16
Table 15. Summary of Notification, Record Keeping, and Monitoring Plan	16
Table 16. Summary of Operator Certification	17
Table 17. Summary of Plans and Specifications	17
Table 18. Summary of the Public Notice	17
Table 19. Summary of the Revised Total Coliform	18
Table 20. Summary of the Sanitary Survey	18
Table 21. Summary of the Storage Tank	19
Table 22. Summary of the Surface Water Treatment	20
Table 23. Summary of the Surface Water Precursors	20
Table 24. Summary of the Total Coliform	21
Table 25. Summary of the Water Hauler	21

## Appendix

Appendix A: PWSs with Health-Based Violations	23
---	----



# Introduction

---

The United States Environmental Protection Agency (EPA) established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 Amendments, EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs). For some regulations, EPA establishes treatment techniques (TTs) in lieu of MCLs. Standards were also set on how often public water systems (PWSs) monitor their water for contaminants and report the sample results. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M&R) requirements. In addition, EPA requires select PWSs to monitor for unregulated contaminants to provide data for future regulatory development. The 1996 Amendments to the SDWA require public notification to include a clear and understandable explanation of the nature of each violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation, and the possibility of alternative water supplies during the violation. The Colorado Department of Public Health and Environment's (CDPHE) Safe Drinking Water Program (SDWP) implements the SDWA, with amendments, pursuant to Regulation 11 (Colorado Primary Drinking Water Regulations) for the State of Colorado.

The Annual Compliance Report (ACR) is intended to provide a total annual representation of the numbers of violations. Violations fall into one of two categories:

1. Health-Based
2. Non-Health-Based

This report was prepared to meet the EPA's reporting requirements and is updated on a yearly basis.



# Definitions

---

- **Public Water System (PWS)**: Provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs:
  - Community (e.g. cities, or towns)
  - Non-Transient, Non-Community (e.g. schools, or factories)
  - Transient, Non-Community systems (e.g. restaurants, rest stops, or parks)
- **Health-Based**: Potential short-term or long-term health risks.
  - **Maximum Contaminant Level (MCL)**: The highest level of a contaminant allowed in drinking water. Note: Under the Lead and Copper Rule, MCLs were not established. For this rule, “action levels” rather than MCLs define the levels at which a public water system must take action to reduce the concentration of lead and/or copper.
  - **Maximum Residual Disinfectant Level (MRDL)**: The highest level of a disinfectant (added for the treatment of water) allowed in drinking water. MRDLs are enforceable in the same manner as MCLs.
  - **Treatment Techniques (TT)**: Unacceptable levels, in lieu of a MCL, for selected water characteristics or a failure to correct an identified issue. Turbidity, for example, which measures the cloudiness of water.
- **Non-Health-Based**: No health risks or health risks are unknown.
  - **Monitoring and Reporting (M&R)**: To monitor, test, and report for water characteristics (e.g. contaminants) present in drinking water. All minor and major violations are included.
  - **Public Notice (PN)**: A requirement for the PWS to notify their customers of any and all violations. PN requirements take into account the seriousness of the violation (or situation) and any potential adverse health effects that may be involved.
- **Variance**: A departure from a primary drinking water regulation if the characteristics of the raw water sources available to the PWS do not allow the system to meet the MCL.
- **Exemption**: Temporarily relieves a PWS of its obligation to comply with an MCL, TT, or both, due to compelling factors (which may include economic factors).



# National Primary Drinking Water Regulations

---

The Safe Drinking Water Act (SDWA) is the federal law that regulates the quality of drinking water. The SDWA sets standards for drinking water quality and stipulates the monitoring requirements for PWSs. The following regulations have been promulgated under the CPDWR:

- **Chemical Phase Rule**: Provide public health protection through the reduction of chronic risk (e.g. cancer, organ damage, etc.) from the exposure of:
  - Inorganic Chemicals (IOCs)
  - Nitrate and Nitrite (NOX)
  - Synthetic Organic Chemicals (SOCs)
  - Volatile Organic Chemicals (VOCs)
  - Radionuclides (RADs)
- **Consumer Confidence Rule (CCR)**: An annual drinking water quality report distributed by PWSs to their customers by July 1<sup>st</sup>. The report contains information regarding sources used (i.e. rivers, lakes, reservoirs, etc.), detected contaminants, violations, and educational information.
- **Cross-Connection Control Rule (CCX)**: Require PWSs to inspect system for cross-connections and backflow prevention devices.
- **Microbial, Disinfection, and Disinfection Byproducts (MICRO, DIS, and DBPs)**: In general, drinking water must be disinfected to inactivate microbial pathogens (e.g. *E. coli*, salmonella, etc.). To protect against potential microbial contamination, PWSs add disinfectants such as chlorine. However, disinfectants can react with naturally occurring material in the source water and form byproducts, which may pose adverse health risks. PWSs must carefully maintain a balance between addressing potential microbial contamination and byproduct formation. The following rules address this issue:
  - **Groundwater Rule (GWR)**: The purpose of the GWR is to provide increased protection against microbial pathogens in PWSs that utilize groundwater sources.
  - **Disinfection (DIS)**: The purpose of these rules is to provide protection against microbial contamination.
  - **Disinfection Byproduct Rules (DBPs)**: The purpose of these rules is to reduce exposure to disinfection byproducts for customers of PWSs that add a disinfectant to the drinking water during any part of the treatment process.
  - **Surface Water Treatment Rules (SWTRs)**: The purpose of the SWTRs is to prevent waterborne diseases caused by viruses, *Giardia*, and *Cryptosporidium*. The rules require surface water systems to filter and disinfect their water to reduce the occurrence of microbial contamination.
  - **Revised Total Coliform Rule (RTCR)**: The purpose of this rule is to increase public health protection through the reduction of contamination in the drinking water distribution system.
  - **Total Coliform Rule (TCR)**: Provide public health protection by maintaining the integrity of the distribution system and requiring public water systems to



monitor for the presence of microbial contamination. This rule was replaced by the Revised Total Coliform Rule on April 1, 2017.

- Lead and Copper Rule (LCR): Protect public health by minimizing the public's exposure to lead and copper.
- Notification, Record Keeping, and Monitoring Plan (Notification): Require PWSs to notify the state of any drinking water violations or situations that may pose an adverse health risk, retain records, and have a monitoring plan.
- Operator Certification Rule (Op Cert): Require PWSs to have a certified operator.
- Plans and Specifications (P&S): Require PWSs to get approval from the state before making physical modifications to the water system.
- Public Notice Rule (PN): Require PWSs to notify their customers of any drinking water violations or situations that may pose an adverse health risk.
- Sanitary Survey (SS): Require PWSs to correct deficiencies found during an inspection.
- Storage Tanks (Tanks): Require PWSs to perform inspections on finished water storage tanks and fix any issues identified.
- Water Hauler Rule (Hauler): Require PWSs that haul water to meet special requirements.





# Violations

## Overview

The number of PWSs in the state changes on a day by day basis. This is due to seasonal operations, new PWSs opening, existing PWSs closing, and changes to the population being served. Table 1 displays a typical number of systems, on any one day, by population and system type.

*Table 1. Number of PWSs by System Type and Population*

Population	Water System Type			Total
	Community	Transient, Non-Community	Non-Transient, Non-Community	
25-500	519	870	135	1524
501-3,300	204	72	28	304
3,301-10,000	83	5	5	93
10,001-100,000	73	0	0	73
>100,000	10	0	0	10
<b>Total</b>	<b>889</b>	<b>947</b>	<b>168</b>	<b>2004</b>

Violations are based on data compiled in June, 2018 from Colorado's production SDWIS/State database. If a violation: (1) was unresolved as of January 1, 2017, or (2) occurred in calendar year 2017, it was included. M&R violations for PWSs sampling less frequently than annually will be reported in the third, sixth, or ninth year of a compliance cycle. Calendar year 2017 was the third year in a compliance cycle. Table 2 summarizes the number of violations and the number of systems by each drinking water rule and violation type. The subsequent sections provide further details for each of the drinking water rules.

Appendix A identifies the public water systems that were in violation of maximum contaminant levels and/or treatment technique requirements. The final column indicates if the violation was resolved.

## Summary of All Violations

- 350 systems in violation of at least one of the health-based standards.
- 702 systems in violation of at least one of the non-health-based standards.

Table 2. Summary by Rule and Violation Type

Group	Non-Health-Based Violations		Health-Based Violations	
	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
Chlorite and Bromate (DBP - Other) Totals:	4	2	-	-
Consumer Confidence (CCR) Totals:	48	45	-	-
Cross Connection Control (CCX) Totals:	192	150	22	19
Disinfection (DIS) Totals:	483	269	173	74
Ground Water (GW) Totals:	30	25	-	-
Inorganics (IOCs) Totals:	294	15	25	4
Lead and Copper (LCR) Totals:	123	107	14	13
Nitrogen (NOX) Totals:	86	58	127	19
Notification, Record Keeping, and Monitoring Plan (Notification) Totals:	148	136	-	-
Operator Certification (Op Cert) Totals:	-	-	96	93
Plans and Specifications (P&S) Totals:	57	57	-	-
Precursors (Precursors) Totals:	25	4	1	1
Public Notice (PN) Totals:	239	151	-	-
Radionuclides (RADs) Totals:	60	9	444	26
Revised Total Coliform (RTCR) Totals:	206	171	63	62
Sanitary Survey (SS) Totals:	-	-	59	29
Storage Tanks (Tanks) Totals:	35	35	32	30
Surface Water (SW) Totals:	250	113	76	37
Synthetic Organics (SOCs) Totals:	603	11	-	-
Total Coliform (TCR) Totals:	-	-	6	5
TTHM and HAA5 (DBP - TTHM and HAA5) Totals:	100	46	97	22
Volatile Organics (VOCs) Totals:	609	13	-	-
Water Hauler (Hauler) Totals:	3	3	2	2
<b>Total:</b>	<b>3595</b>	<b>702</b>	<b>1237</b>	<b>350</b>

## Inorganic Chemical Violations (not including Nitrogen Compounds and Radionuclides)

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 4 systems in violation of at least one of the MCLs.
- 15 systems failed to monitor/report for at least one of the contaminants.

Table 3. Summary of Inorganic Chemicals

Inorganics (IOCs)				
Contaminant	Health-Based Violations		Non-Health-Based Violations	
	Name	# of Violations	# of Water Systems with Violations	# of Violations
ANTIMONY, TOTAL	-	-	24	10
ARSENIC	11	2	30	12
BARIUM	-	-	24	10
BERYLLIUM, TOTAL	-	-	24	10
CADMIUM	-	-	24	10
CHROMIUM	-	-	24	10
FLUORIDE	9	1	24	11
MERCURY	-	-	24	10
NIKEL	-	-	24	10
SELENIUM	5	1	24	10
SODIUM	-	-	24	10
THALLIUM, TOTAL	-	-	24	10
<b>Inorganics (IOCs) Totals:</b>	<b>25</b>	<b>4</b>	<b>294</b>	<b>15</b>

## Nitrogen Compound Violations

- All PWSs are required to comply.
- 19 systems in violation of the Nitrate MCL.
- 58 systems failed to monitor/report for Nitrate or Nitrite.

Table 4. Summary of Nitrogen Compounds

Nitrogen (NOX)				
Contaminant	Health-Based Violations		Non-Health-Based Violations	
	Name	# of Violations	# of Water Systems with Violations	# of Violations
NITRATE	127	19	51	58
NITRITE	-	-	5	3
<b>Nitrogen (NOX) Totals:</b>	<b>127</b>	<b>19</b>	<b>56</b>	<b>61</b>

## Radionuclide Violations

- Community PWSs are required to comply.
- 26 systems in violation of at least one of the MCLs.
- 9 systems failed to monitor/report for at least one of the contaminants.

Table 5. Summary of Radionuclides

Radionuclides (RADs)				
Contaminant	Health-Based Violations		Non-Health-Based Violations	
	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
COMBINED RADU(M(-226 & -228)	293	22	22	3
COMBINED URANIUM	52	5	18	4
GROSS ALPHA, EXCL RADON & U	99	9	20	5
Radionuclides (RADs) Totals:	444	26	60	9

## Volatile Organic Chemical Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- Zero systems in violation of at least one of the MCLs.
- 13 systems failed to monitor/report for at least one of the contaminants.

Table 6. Summary of Volatile Organic Chemicals

Volatile Organics (VOCs)				
Contaminant	Health-Based Violations		Non-Health-Based Violations	
	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
1,1,1-TRICHLOROETHANE	-	-	29	13
1,1,2-TRICHLOROETHANE	-	-	29	13
1,1-DICHLOROETHYLENE	-	-	29	13
1,2,4-TRICHLOROBENZENE	-	-	29	13
1,2-DICHLOROETHANE	-	-	29	13
1,3-DICHLOROPROPANE	-	-	29	13
BENZENE	-	-	29	13
CARBON TETRACHLORIDE	-	-	29	13
CHLOROBENZENE	-	-	29	13
CIS-1,2-DICHLOROETHYLENE	-	-	29	13
DIHALOMETHANE	-	-	29	13
ETHYLBENZENE	-	-	29	13
O-DICHLOROBENZENE	-	-	29	13
P-DICHLOROBENZENE	-	-	29	13
STYRENE	-	-	29	13
TETRACHLOROETHYLENE	-	-	29	13
TOLUENE	-	-	29	13
TRANS-1,2-DICHLOROETHYLENE	-	-	29	13
TRICHLOROETHYLENE	-	-	29	13
VINYL CHLORIDE	-	-	29	13
XYLENES, TOTAL	-	-	29	13
Volatile Organics (VOCs) Totals:	-	-	609	13



## Synthetic Organic Chemical Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- Zero systems in violation of at least one of the MCLs.
- 11 systems failed to monitor/report for at least one of the contaminants.

Table 7. Summary of Synthetic Organic Chemicals

Synthetic Organics (SOCs)				
Contaminant	Health-Based Violations		Non-Health-Based Violations	
	Name	# of Violations	# of Water Systems with Violations	# of Violations
1,2-DIBROMO-3-CHLOROPROPANE	-	-	21	5
2,4,5-TP	-	-	21	5
2,4-D	-	-	21	5
ALDICARB	-	-	3	3
ALDICARB SULFONE	-	-	3	3
ALDICARB SULFOXIDE	-	-	3	3
ATRAZINE	-	-	21	5
BENZO(A)PYRENE	-	-	22	6
BHC-GAMMA	-	-	21	5
CARBOFLURAN	-	-	21	5
CHLORDANE	-	-	21	5
DALAPON	-	-	22	6
DI(2-ETHYLHEXYL)ADIPATE	-	-	21	5
DI(2-ETHYLHEXYL)PHTHALATE	-	-	22	6
DINOSEB	-	-	21	5
DIQUAT	-	-	21	5
ENDOSULF	-	-	21	5
ENDRIN	-	-	21	5
ETHYLENEBROMIDE	-	-	21	5
HEPTACHLOR	-	-	22	6
HEPTACHLOR EPOXIDE	-	-	21	5
HEXACHLOROBENZENE	-	-	21	5
HEXACHLOROCYCLOPENTADIENE	-	-	22	6
LAS 50	-	-	21	5
METHOXYCHLOR	-	-	21	5
OXAMYL	-	-	21	5
PENTACHLOROPHENOL	-	-	21	5
PICLORAM	-	-	22	6
SDMAZINE	-	-	21	5
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	-	-	21	5
TOXAPHENE	-	-	21	5
Synthetic Organics (SOCs) Totals:	-	-	603	11



## Consumer Confidence Report (CCR) Rule Violations

- Community PWSs are required to comply.
- 45 systems in violation for failing to report to their customers.

Table 8. Summary of the Consumer Confidence Report

Consumer Confidence (CCR)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
71 - CCR REPORT	CONSUMER CONFIDENCE RULE	-	-	47	44
72 - CCR ADEQUACY/AVAILABILITY/CONTENT	CONSUMER CONFIDENCE RULE	-	-	1	1
Consumer Confidence (CCR) Totals:		-	-	48	45

## Cross Connection Control and Backflow Prevention Rule Violations

- All PWSs are required to comply.
- 19 systems in violation for potential contamination.
- 150 systems failed to test/report.

Table 9. Summary of Cross Connection Control and Backflow Prevention

Cross Connection Control (CCX)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
MS - STATE TREATMENT TECHNIQUE LEVEL	CROSS CONNECTION RULE	22	19	-	-
MS - STATE MONITORING	CROSS CONNECTION RULE	-	-	92	150
Cross Connection Control (CCX) Totals:		22	19	92	150



## Disinfection Violations

- All PWSs are required to comply.
- 74 systems in violation of at least one of the health-based standards.
- 269 systems in violation of at least one of the non-health-based standards.

Table 10. Summary of Disinfection

Disinfection (DS)					
Violation		Health-Based Violations:		Non-Health-Based Violations:	
Type	Name	# of Violations:	# of Water Systems with Violations:	# of Violations:	# of Water Systems with Violations:
13 - MSDL ACUTE (CHL DIOXIDE)	CHLORINE DIOXIDE	1	1	-	-
41 - RES DESINFECT CONCENTRATION (SWTR)	CHLORINE	65	17	-	-
	SWTR	38	13	-	-
10 - FAILURE PROVIDE DESINFECT. TREATMENT GW	CHLORINE	5	5	-	-
	GROUNDWATER RULE	2	2	-	-
16 - STATE TREATMENT TECHNOLOGY LEVEL	CHLORINE	62	44	-	-
27 - MONITORING, (DEP) (CHL DIOXIDE)	CHLORINE DIOXIDE	-	-	4	2
27 - MONITORING, ROUTINE (DEP), MAJOR	CHLORINE	-	-	37	67
36 - MONITORING, RTNRPT MAJOR (SWTR-FILTER)	CHLORINE	-	-	158	75
36 - MONITORING, RTNRPT MINOR (SWTR-FILTER)	CHLORINE	-	-	3	3
15 - STATE MONITORING	CHLORINE	-	-	94	162
VC - EQUIPMENT VERIFICATION OR CALIBRATION	CHLORINE	-	-	37	37
<b>Disinfection (DS) Totals:</b>		<b>173</b>	<b>74</b>	<b>483</b>	<b>269</b>



## Disinfection Byproducts Rule Violations

### Chlorite and Bromate Rule Violations

- PWSs using chlorine dioxide or ozone are required to comply.
- Two systems failed to monitor/report for at least one of the contaminants.

Table 11. Summary of the Chlorite and Bromate

Chlorite and Bromate (DBP - Other)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
27 - MONITORING, ROUTINE (DBP), MAJOR	BROMATE	-	-	1	1
	CHLORITE	-	-	3	1
Chlorite and Bromate (DBP - Other) Totals:		-	-	4	2

### Total Trihalomethanes and Haloacetic Acids Rule Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 22 systems in violation of at least one of the MCLs.
- 46 systems failed to monitor/report for at least one of the contaminants or failed to complete evaluation report.

Table 12. Summary of Total Trihalomethanes and Haloacetic Acids

TTHM and HAA5 (DBP - TTHM and HAA5)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
02 - MCL, AVERAGE	TOTAL HALOACETIC ACIDS (HAA5)	6	1	-	-
	TTHM	4	2	-	-
02 - MCL, LRAA	TOTAL HALOACETIC ACIDS (HAA5)	26	8	-	-
	TTHM	51	18	-	-
27 - MONITORING, ROUTINE (DBP), MAJOR	TOTAL HALOACETIC ACIDS (HAA5)	-	-	51	42
	TTHM	-	-	43	38
35 - FAILURE SUBMIT OEL REPORT FOR HAA5	TOTAL HALOACETIC ACIDS (HAA5)	-	-	2	2
35 - FAILURE SUBMIT OEL REPORT FOR TTHM	TTHM	-	-	4	3
TTHM and HAA5 (DBP - TTHM and HAA5) Totals:		97	22	100	46

## Groundwater Rule Violations

- PWSs with a groundwater source not treated to surface water standards are required to comply.
- 25 systems failed to monitor/report their raw water source for *E. coli*.

Table 13. Summary of the Groundwater

Ground Water (GW)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
34 - MONITOR GWR TRIGGERED ADDITIONAL MAJOR	E COLI	-	-	30	25
Ground Water (GW) Totals:		-	-	30	25



## Lead and Copper Rule Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 13 systems in violation of at least one of the health-based standards.
- 107 systems in violation of at least one of the non-health-based standards.

Table 14. Summary of Lead and Copper

Lead and Copper (LCR)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
37 - OCCTSOWT RECOMMENDATION/STUDY (LCR)	LEAD&COPPER RULE	0	0	-	-
38 - OCCTSOWT INSTALL DEMONSTRATION (LCR)	LEAD&COPPER RULE	1	1	-	-
63 - PUBLIC EDUCATION (LCR)	LEAD&COPPER RULE	4	4	-	-
51 - INITIAL TAP SAMPLING (LCR)	LEAD&COPPER RULE	-	-	5	5
32 - FOLLOW-UP FOR ROUTINE TAP MR (LCR)	LEAD&COPPER RULE	-	-	38	37
53 - WATER QUALITY PARAMETER MR (LCR)	LEAD&COPPER RULE	-	-	11	11
56 - INITIAL FOLLOW-UP ROUTINE SOWT MR (LCR)	LEAD&COPPER RULE	-	-	4	4
66 - LEAD CONSUMER NOTICE (LCR)	LEAD&COPPER RULE	-	-	65	60
Lead and Copper (LCR) Totals:		4	13	123	107

## Notification, Record Keeping, and Monitoring Plan Violations

- All PWSs are required to comply.
- 136 systems failed to notify, maintain records, or have a complete monitoring plan.

Table 15. Summary of Notification, Record Keeping, and Monitoring Plan

Notification, Record Keeping, and Monitoring Plan (Notifications)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
09 - RECORD KEEPING, WITHOUT RULE CODE	N/A	-	-	30	30
27 - FAILURE TO HAVE MONITORING PLAN (DBP)	DBP STAGE 1	-	-	25	25
32 - FAILURE TO HAVE MONITORING PLAN (LT2)	LT2B WTR	-	-	21	21
5A - SAMPLING PLAN ERRORS (RTCR)	E COLI	-	-	1	1
	REVED TOTAL COLIFORM RULE (RTCR)	-	-	40	40
58 - STATE MONITORING	MONITORING PLAN RULE	-	-	31	31
Notification, Record Keeping, and Monitoring Plan (Notifications) Totals:		-	-	148	136

## Operator Certification Rule Violations

- All PWSs are required to comply.
- 93 systems failed have a certified operator.

Table 16. Summary of Operator Certification

Operator Certification (Op Cert)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
12 - QUALIFIED OPERATOR FAILURE	DEP STAGE1	33	33	-	-
00 - QUALIFIED OPERATOR FAILURE - TRANSIENT	DEP STAGE1	52	51	-	-
	N/A	11	11	-	-
Operator Certification (Op Cert) Totals:		96	93	-	-

## Plans and Specification Violations

- All PWSs are required to comply.
- 57 systems failed to get prior approval before making changes to their systems.

Table 17. Summary of Plans and Specifications

Plans and Specifications (P&S)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
MS - STATE MONITORING	PLANS AND SPECIFICATIONS RULE	-	-	57	57
Plans and Specifications (P&S) Totals:		-	-	57	57

## Public Notice Rule Violations

- All PWSs that incurred a violation or posed an adverse health risk are required to comply.
- 151 systems failed to provide public notice to their customers.

Table 18. Summary of the Public Notice

Public Notice (PN)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
75 - PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	-	-	125	86
76 - PUBLIC NOTICE RULE NOT LINKED TO VIOLATION	PUBLIC NOTICE	-	-	114	81
Public Notice (PN) Totals:		-	-	239	151

## Revised Total Coliform Rule (Microbial) Violations

- All PWSs are required to comply.
- 62 systems in violation of at least one of the health-based standards.
- 171 systems in violation of at least one of the non-health-based standards.

Table 19. Summary of the Revised Total Coliform

Revised Total Coliform (RTCR)					
Violation		Health-Based Violations:		Non-Health-Based Violations:	
Type	Name	# of Violations:	# of Water Systems with Violations:	# of Violations:	# of Water Systems with Violations:
1A - MCL E COLI POS E COLI (RTCR)	E COLI	5	4	-	-
2A - LEVEL 1 ASSESS, MULTIPLE TC POS (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	2	2	-	-
2A - LEVEL 1 ASSESS, TC POS RTNO RPT (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	1	1	-	-
2D - STARTUP PROCEDURES TT (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	55	55	-	-
3A - MONITORING, ROUTINE, MAJOR (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	159	117
	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	39	36
3A - MONITORING, ROUTINE, MINOR (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	7	7
3B - MONITORING, ADD. ROUTINE, MINOR (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	1	1
4B - REPORT SAMPLE RESULT FAIL MONITOR RTCR	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	1	1
	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	2	1
4C - REPORT STARTUP PROCEDURES CERTFORM RTCR	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	16	15
5B - STATE MONITORING	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	1	1
Revised Total Coliform (RTCR) Totals:		63	62	206	171

## Sanitary Survey Rule Violations

- All PWSs are required to comply.
- 29 systems failed to correct deficiencies identified during an inspection.

Table 20. Summary of the Sanitary Survey

Sanitary Survey (SS)					
Violation		Health-Based Violations:		Non-Health-Based Violations:	
Type	Name	# of Violations:	# of Water Systems with Violations:	# of Violations:	# of Water Systems with Violations:
45 - FAILURE ADDRESS DEFICIENCY (GWR)	GROUNDWATER RULE	50	23	-	-
45 - FAILURE ADDRESS DEFICIENCY (ES WTR)	ES WTR	9	6	-	-
Sanitary Survey (SS) Totals:		59	29	-	-



## Storage Tank Rule Violations

- All PWSs with storage tanks are required to comply.
- 30 systems in violation of at least one of the health-based standards.
- 35 systems in violation of at least one of the non-health-based standards.

*Table 21. Summary of the Storage Tank*

Storage Tanks (Tanks)					
Violation		Health-Based Violations:		Non-Health-Based Violations:	
Type	Name	# of Violations:	# of Water Systems with Violations:	# of Violations:	# of Water Systems with Violations:
MS - STATE TREATMENT TECHNOLOGY LEVEL	STORAGE TANK RULE	32	30	-	-
MS - STATE MONITORING	STORAGE TANK RULE	-	-	35	35
Storage Tanks (Tanks) Totals:		32	30	35	35

## Surface Water Treatment Rule Violations

- Surface Water and Groundwater-Under-the-Direct-Influence-of-Surface-Water PWSs are required to comply.
- 37 systems in violation for either inadequate filtration resulting in high turbidity (cloudiness) of the water, inadequate disinfection, or failure to filter.
- 113 systems failed to monitor/report/calibrate for turbidity or perform raw water source monitoring.
- One system in violation for inadequate total organic carbon removal.
- Four systems failed to monitor/report for total organic carbon or alkalinity.

Table 22. Summary of the Surface Water Treatment

Surface Water (S W)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
42 - FAILURE TO FILTER (S WTR)	S WTR	16	16	-	-
43 - SINGLE COMB FLTR EFFLUENT (ESWTR/LT)	ES WTR	2	2	-	-
	TURBIDITY	10	8	-	-
44 - MONTHLY COMB FLTR EFFLUENT (ESWTR/LT)	ES WTR	5	5	-	-
	TURBIDITY	43	15	-	-
32 - MONITORING, SOURCE (LTA), MAJOR	CRYPTOSPOREDIUM	-	-	5	4
	E. COLI	-	-	132	70
	TURBIDITY	-	-	4	3
36 - MONITORING, ROUTINE MAJOR (S WTR-FILTER)	S WTR	-	-	2	2
38 - MONITORING, ROUTINE (ES WTR/LT), MAJOR	ES WTR	-	-	4	2
	TURBIDITY	-	-	75	36
38 - MONITORING, ROUTINE (ES WTR/LT), MINOR	TURBIDITY	-	-	1	1
VC - EQUIPMENT VERIFICATION OR CALIBRATION	TURBIDITY	-	-	27	27
Surface Water (S W) Totals:		76	37	250	113

Table 23. Summary of the Surface Water Precursors

Precursor (Precursor)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
46 - INADEQUATE DBP PRECURSOR REMOVAL	CARBON, TOTAL	1	1	-	-
27 - MONITORING, ROUTINE (DBP), MAJOR	ALKALINITY, TOTAL	-	-	9	4
	CARBON, TOTAL	-	-	16	4
Precursor (Precursor) Totals:		1	1	25	4

## Water Hauler Rule Violations

- All PWSs are required to comply.
- Two system in violation of at least one of the health-based standards.
- Three systems in violation of at least one of the non-health-based standards.

*Table 25. Summary of the Water Hauler*

Water Hauler (Hauler)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
DE - STATE TREATMENT TECHNOLOGY LEVEL	WATER HAULER RULE	2	2	-	-
MS - STATE MONITORING	WATER HAULER RULE	-	-	3	3
Water Hauler (Hauler) Totals:		2	2	3	3

# Variations and Exemptions

---

Colorado's Safe Drinking Water Program did not issue any variations or exemptions to any public water system.

## Report Availability and Contact Information

---

The summary report is available at <https://www.colorado.gov/cdphe/drinking-water-consumer-information>.

For further information concerning this report, or with specific violations associated with public water systems, you may contact Phillip Stanwood with the Safe Drinking Water Compliance Assurance Section at (303) 692-3502 or by email at [Phillip.Stanwood@state.co.us](mailto:Phillip.Stanwood@state.co.us).



## Appendix A: PWSs with Health-Based Violations

PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2017?
CO0219100	4 EAGLE RANCH	Surface Water (SW)	TURBIDITY	No
CO0219100	4 EAGLE RANCH	Disinfection (DIS)	SWTR	Yes
CO0219100	4 EAGLE RANCH	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0219100	4 EAGLE RANCH	Disinfection (DIS)	CHLORINE	No
CO0136100	AGUILAR TOWN OF	Surface Water (SW)	SWTR	No
CO0107115	ALLENSPARK WSD	Disinfection (DIS)	CHLORINE	Yes
CO0207115	ALPINE BROOK WS	Disinfection (DIS)	SWTR	Yes
CO0207115	ALPINE BROOK WS	Sanitary Survey (SS)	IESWTR	Yes
CO0207115	ALPINE BROOK WS	Disinfection (DIS)	CHLORINE	Yes
CO0207115	ALPINE BROOK WS	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0214100	ALPINE LODGE DINNER REST AND CBN	Operator Certification (Op Cert)		No
CO0160050	ALPINE VILLAGE MHP	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0235119	AMBERWOOD ESTATE LLP	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0208116	AMERICAN ADVENTURE EXPEDITIONS	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0247700	AMERICAN SAFARI RANCH	Operator Certification (Op Cert)		No





CO0346116	AMPHITHEATER CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0240050	ANTLERS RIO GRANDE LODGE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0111100	ANTONITO TOWN OF	Surface Water (SW)	SWTR	Yes
CO0111100	ANTONITO TOWN OF	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0261002	ARICKAREE SCHOOL	Nitrogen (NOX)	NITRATE	Yes
CO0222500	ARKANSAS RIVER KOA	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0208240	ARROWHEAD POINT	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0123123	ASGARD SUBDIVISION WA	Nitrogen (NOX)	NITRATE	Yes
CO0123123	ASGARD SUBDIVISION WA	Inorganics (IOCs)	SELENIUM	No
CO0225125	ASPEN CANYON GUEST RANCH	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0225125	ASPEN CANYON GUEST RANCH	Disinfection (DIS)	CHLORINE	Yes
CO0225125	ASPEN CANYON GUEST RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0149123	ASPEN VILLAGE MD	Surface Water (SW)	SWTR	Yes
CO0247133	BADGER BASIN COUNTRY STORE	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0235132	BALDPATE INN LTD THE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes



CO0222170	BANDERAS BUNKHOUSE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0221040	BEAR TRAP RANCH	Surface Water (SW)	TURBIDITY	Yes
CO0145030	BEEHIVE WC NO1	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0101015	BELLEVIEW CHRISTIAN COLLEGE	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0235139	BEN DELATOUR BOY SCOUT CAMP	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0206200	BENTS FORT INN	Disinfection (DIS)	CHLORINE	Yes
CO0135143	BIG ELK MEADOWS WA	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0135143	BIG ELK MEADOWS WA	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0353200	BIG MEADOWS CAMPGROUND	Disinfection (DIS)	CHLORINE	Yes
CO0221060	BIG PINES CAMPGROUND	Operator Certification (Op Cert)		No
CO0222570	BIGHORN RV PARK	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0243152	BLACK CANYON OF THE GUNNISON SOUTH RIM	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0248146	BLISTIES	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0225625	BLM PUMPHOUSE RECREATION SITE	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0328085	BLUE LAKE CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0247003	BLUE MTN RANCH	Disinfection (DIS)	CHLORINE	Yes



CO0151150	BOONE TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0151150	BOONE TOWN OF	Surface Water (SW)	SWTR	No
CO0151150	BOONE TOWN OF	Nitrogen (NOX)	NITRATE	No
CO0107152	BOULDER CITY OF	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0136300	BRANSON TOWN OF	Surface Water (SW)	SWTR	No
CO0262155	BRIGGSDALE SCHOOL	Disinfection (DIS)	CHLORINE	Yes
CO0162155	BRIGGSDALE WC	Disinfection (DIS)	CHLORINE	Yes
CO0101030	BRIGHTON MHP	Nitrogen (NOX)	NITRATE	No
CO0240189	BROADACRES RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0230007	BROOMFIELD VFW 9565	Nitrogen (NOX)	NITRATE	Yes
CO0247325	BULL MOOSE	Nitrogen (NOX)	NITRATE	Yes
CO0132005	BURLINGTON CITY OF	Nitrogen (NOX)	NITRATE	No
CO0149160	BUTTERMILK MD	Sanitary Survey (SS)	IESWTR	Yes
CO0238002	CALICHE SCHOOL	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0238002	CALICHE SCHOOL	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0247018	CAMP ALEXANDER BOY SCOUTS	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0247018	CAMP ALEXANDER BOY SCOUTS	Disinfection (DIS)	CHLORINE	No



CO0215166	CAMP CEDAREEDGE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0307166	CAMP DICK CG	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0221560	CAMP LA FORET	Operator Certification (Op Cert)		No
CO0221560	CAMP LA FORET	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0247020	CAMP ROSALIE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0235172	CAMP TIMBERLINE	Surface Water (SW)	TURBIDITY	No
CO0235172	CAMP TIMBERLINE	Disinfection (DIS)	CHLORINE	No
CO0235172	CAMP TIMBERLINE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0105100	CAMPO TOWN OF	Lead and Copper (LCR)	LEAD & COPPER RULE	No
CO0260820	CATHEDRAL RIDGE	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0115168	CATHEDRAL WC	Surface Water (SW)	SWTR	No
CO0223166	CATHERINE STORE	Disinfection (DIS)	CHLORINE	Yes
CO0210009	CDOT EISENHOWER JOHNSON TUNNEL	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0155500	CENTER TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0208160	CHALK CREEK CAMPGROUND	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0118175	CHATFIELD SOUTH WD	Disinfection (DIS)	CHLORINE	Yes
CO0235175	CHELEY COLORADO CAMP MAIN	Surface Water (SW)	TURBIDITY	Yes



CO0145090	CHERAW TOWN OF	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145090	CHERAW TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0121125	CHEROKEE MD	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0109006	CHEYENNE WELLS TOWN OF	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0259176	CHRIST LUTHERAN CHURCH SCHOOL	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0218101	CHRISTLIFE COMMUNITY CHURCH	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0139180	CLIFTON WD	Surface Water (SW)	TURBIDITY	Yes
CO0115185	COALBY DOMESTIC WC	Disinfection (DIS)	CHLORINE	Yes
CO0247021	COLORADO CHRISTIAN SERVICE CAMP	Operator Certification (Op Cert)		No
CO0151200	COLORADO CITY MD	Disinfection (DIS)	SWTR	Yes
CO0151200	COLORADO CITY MD	Disinfection (DIS)	CHLORINE DIOXIDE	Yes
CO0151200	COLORADO CITY MD	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0151200	COLORADO CITY MD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0233184	COLORADO OUTWARD BOUND SCHOOL	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0230185	CONIFER COMMUNITY CHURCH	Operator Certification (Op Cert)	DBP STAGE 1	Yes



CO0240300	COTTONWOOD COVE LODGE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0221179	COTTONWOOD HOT SPRINGS	Disinfection (DIS)	GROUNDWATER RULE	Yes
CO0118020	COTTONWOOD WSD	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0118020	COTTONWOOD WSD	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0103025	COUNTRY GARDENS MHP	Disinfection (DIS)	CHLORINE	Yes
CO0207192	COUNTRYSIDE MONTESSORI	Disinfection (DIS)	CHLORINE	Yes
CO0224319	COYOTE MOTEL	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0130187	CRAGMONT WC	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0115189	CRAWFORD MESA WA	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0140500	CREEDE CITY OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0101188	CREEKSIDE SOUTH ESTATES HOA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0101188	CREEKSIDE SOUTH ESTATES HOA	Disinfection (DIS)	CHLORINE	Yes
CO0362001	CROW VALLEY CAMPGROUND	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0221260	CRYSTAL KANGAROO CAMPGROUND	Disinfection (DIS)	SWTR	Yes
CO0235123	DAO HOUSE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No



CO0121175	DONALA WSD	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0239154	DRIVE IN THE	Disinfection (DIS)	CHLORINE	Yes
CO0234480	DURANGO LA PLATA AIRPORT	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0134190	DURANGO WEST MD NO 2	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0134190	DURANGO WEST MD NO 2	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0108233	EAGLE ROOST WATER IMPROVEMENT ASSOC	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0108233	EAGLE ROOST WATER IMPROVEMENT ASSOC	Disinfection (DIS)	CHLORINE	Yes
CO0254233	EAGLE SOARING RV PARK	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0145120	EAST END WA	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0135233	EAST LARIMER COUNTY WD	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0221300	EDISON SCHOOL DISTRICT 54JT	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0221110	EL PASO PARKS BLACK FOREST	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0221435	EL PASO PARKS FOUNTAIN CREEK A1	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0221436	EL PASO PARKS FOUNTAIN CREEK NATURE CTR	Operator Certification (Op Cert)	DBP STAGE 1	Yes



CO0221605	EL PASO PARKS HOMESTEAD RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0333200	ELBERT CREEK CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0333200	ELBERT CREEK CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0207466	ELDORA MOUNTAIN RESORT	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0207484	ELDORA MOUNTAIN RESTAURANT	Disinfection (DIS)	SWTR	Yes
CO0247017	ELEVEN MILE RANCH HOA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0145150	EUREKA WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145150	EUREKA WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0230300	EVERGREEN SOUTH	Disinfection (DIS)	CHLORINE	No
CO0230300	EVERGREEN SOUTH	Nitrogen (NOX)	NITRATE	Yes
CO0159050	FARMERS KORNER MHP	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0145180	FAYETTE WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145180	FAYETTE WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0132010	FLAGLER TOWN OF	Nitrogen (NOX)	NITRATE	Yes
CO0160175	FLORISSANT WSD	Lead and Copper (LCR)	LEAD & COPPER RULE	No
CO0121300	FOUNTAIN VALLEY AUTHORITY	Precursors (Precursors)	CARBON, TOTAL	No





CO0208360	FOUR SEASONS RV PARK	Nitrogen (NOX)	NITRATE	Yes
CO0145210	FOWLER TOWN OF	Surface Water (SW)	SWTR	No
CO0208170	FOX DEN RESTAURANT	Disinfection (DIS)	CHLORINE	Yes
CO0103050	FOXRIDGE FARMS MHP	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0240400	FREEMONS GUEST RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0226267	FRENCHYS	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0226267	FRENCHYS	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0247288	FRESHWATER BAR AND GRILL	Nitrogen (NOX)	NITRATE	No
CO0135291	FT COLLINS CITY OF	Surface Water (SW)	TURBIDITY	No
CO0221446	FUEL BS CONVENIENCE STORE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0101060	GALAMBS MOBILE HOME AND RV PARK	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0112700	GARCIA DOMESTIC WUA	Disinfection (DIS)	CHLORINE	Yes
CO0137005	GENOA TOWN OF	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0211318	GOLD PAN RV AND CABINS	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0221450	GOLDEN EAGLE RANCH	Disinfection (DIS)	SWTR	Yes
CO0221450	GOLDEN EAGLE RANCH	Surface Water (SW)	SWTR	Yes



CO0221450	GOLDEN EAGLE RANCH	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0130318	GOLDEN TERRACE SOUTH	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0130317	GOLDEN TERRACE VILLAGE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0130319	GOLDEN TERRACE WEST	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0150300	GRANADA TOWN OF	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0125323	GRAND COUNTY WATER NO 1	Sanitary Survey (SS)	IESWTR	No
CO0215322	GRAND MESA LODGE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0230190	GRANITE LAKE	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0162302	GREELEY RV PARK	Nitrogen (NOX)	NITRATE	No
CO0130321	GREEN MOUNTAIN WSD	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0111500	GUADALUPE WA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0111500	GUADALUPE WA	Disinfection (DIS)	CHLORINE	Yes
CO0254725	HAHNS PEAK ROADHOUSE	Surface Water (SW)	TURBIDITY	Yes
CO0254725	HAHNS PEAK ROADHOUSE	Disinfection (DIS)	SWTR	Yes
CO0254725	HAHNS PEAK ROADHOUSE	Disinfection (DIS)	CHLORINE	Yes
CO0254182	HAHNS PEAK VILLAGE HOA	Surface Water (SW)	TURBIDITY	Yes



CO0333308	HALF MOON WEST CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0115333	HANSON MESA DOMESTIC PIPELINE CO INC	Disinfection (DIS)	CHLORINE	No
CO0204200	HAPPY CAMPER RV PARK	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0204200	HAPPY CAMPER RV PARK	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0226333	HARMELS RANCH RESORT	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0150500	HARTMAN TOWN OF	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0208480	HEART OF THE ROCKIES	Disinfection (DIS)	CHLORINE	No
CO0208480	HEART OF THE ROCKIES	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0130045	HIDDEN VALLEY MUTUAL WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0101080	HIGH PLAINS WUA	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0102300	HIGH VALLEY MHP	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0160200	HIGHLAND LAKES WD	Nitrogen (NOX)	NITRATE	No
CO0144010	HILLROSE TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0145330	HOLBROOK CENTER SOFT WA	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0150600	HOLLY TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No



CO0226352	HOLTS GUEST RANCH	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0130050	HOMESTEAD WC	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0130050	HOMESTEAD WC	Disinfection (DIS)	CHLORINE	Yes
CO0115352	HOTCHKISS TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0130065	INDIAN HILLS WD	Surface Water (SW)	TURBIDITY	Yes
CO0107401	JAMESTOWN TOWN OF	Surface Water (SW)	TURBIDITY	Yes
CO0235618	JELLYSTONE PARK OF ESTES PARK	Surface Water (SW)	SWTR	No
CO0235416	JOHN TIMOTHY STONE CLIFFS ASSOC	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0235416	JOHN TIMOTHY STONE CLIFFS ASSOC	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0339425	JUMBO CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0221480	JUNIPER VALLEY RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0137012	KARVAL WATER USERS INC	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0137012	KARVAL WATER USERS INC	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0121415	KEETON RANCH WATER	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0136400	KIM TOWN OF	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0251452	KOURY TRANSPORT	Operator Certification (Op Cert)	DBP STAGE 1	Yes



CO0314478	LA VISTA CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0227466	LAKE FORK HOA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0333405	LAKE VIEW CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0326467	LAKE VIEW CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0333405	LAKE VIEW CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0207465	LANE GUEST RANCH	Surface Water (SW)	TURBIDITY	No
CO0207465	LANE GUEST RANCH	Disinfection (DIS)	CHLORINE	Yes
CO0118030	LARKSPUR TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0118030	LARKSPUR TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0110025	LAWSON TC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0263400	LIBERTY SCHOOL	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0149476	LITTLE ELK CREEK	Disinfection (DIS)	CHLORINE	Yes
CO0201475	LITTLE LIGHTS EARLY LEARNING CENTER	Nitrogen (NOX)	NITRATE	No
CO0227476	LITTLE SQUAW RESORT	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0227476	LITTLE SQUAW RESORT	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0235283	LIVERMORE WS	Surface Water (SW)	TURBIDITY	Yes



CO0214400	LODGE AT SAN ISABEL	Operator Certification (Op Cert)		No
CO0221580	LONE DUCK CG	Operator Certification (Op Cert)		No
CO0221580	LONE DUCK CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0260161	LOST BURRO CAMPGROUND	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0260161	LOST BURRO CAMPGROUND	Disinfection (DIS)	CHLORINE	No
CO0260161	LOST BURRO CAMPGROUND	Nitrogen (NOX)	NITRATE	No
CO0260161	LOST BURRO CAMPGROUND	Revised Total Coliform (RTCR)	E. COLI	No
CO0326487	LOTTIS CREEK CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0210016	LOVELAND VALLEY SKI AREA	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0359450	LOWRY CG PROSPECTOR CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0247500	M LAZY C RANCH	Disinfection (DIS)	CHLORINE	No
CO0247500	M LAZY C RANCH	Nitrogen (NOX)	NITRATE	No
CO0247500	M LAZY C RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0215538	MAD DOG WC	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0145450	MANZANOLA TOWN OF	Radionuclides (RADs)	COMBINED URANIUM	No



CO0145450	MANZANOLA TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0253540	MASONIC PARK ASSOCIATION	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0342500	MAVREESO CG	Surface Water (SW)	IESWTR	Yes
CO0342500	MAVREESO CG	Disinfection (DIS)	CHLORINE	Yes
CO0333505	MAY QUEEN CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0150800	MAY VALLEY WA	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0150800	MAY VALLEY WA	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0207500	MCDONALD FARMS ENTERPRISES INC	Water Hauler (Hauler)	WATER HAULER RULE	No
CO0207506	MEEKER PARK LODGE	Disinfection (DIS)	SWTR	Yes
CO0138025	MERINO TOWN OF	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0138025	MERINO TOWN OF	Radionuclides (RADs)	COMBINED URANIUM	No
CO0107510	MILE HI WATER INC HAULER	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0210017	MILL CREEK WIA	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0210017	MILL CREEK WIA	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0210017	MILL CREEK WIA	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0207510	MILLSITE INN	Operator Certification (Op Cert)	DBP STAGE 1	Yes



CO0207510	MILLSITE INN	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0255600	MOFFAT SCHOOL	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0211300	MOGOTE MEADOW	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0308522	MONARCH PARK NO 2	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0253517	MONTE VISTA CONGREGATION OF JEHOVAH'S WI	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0253517	MONTE VISTA CONGREGATION OF JEHOVAH'S WI	Disinfection (DIS)	CHLORINE	Yes
CO0142800	MONTEZUMA CNTY WD NO 1	Disinfection (DIS)	CHLORINE	Yes
CO0121475	MONUMENT TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	Yes
CO0241338	MOSER LLC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0241338	MOSER LLC	Disinfection (DIS)	CHLORINE	No
CO0210517	MOUNTAIN GATEWAY PROPERTIES LLC	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0151350	MOUNTAIN SHADOWS MOBILE ESTATES	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0215516	MOUNTAIN VALLEY MEADOWS RV PARK	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0240500	MOUNTAIN VIEW AT RIVERS EDGE RV	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes





CO0246588	MOUNTAINTOP RETREAT OFBC INC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0108500	MT PRINCETON HOT SPRINGS	Inorganics (IOCs)	FLUORIDE	Yes
CO0130090	MT VERNON COUNTRY CLUB	Disinfection (DIS)	CHLORINE	Yes
CO0260570	MUELLER STATE PARK CG	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0143533	NATURITA TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0204900	NAVAJO STATE PARK	Nitrogen (NOX)	NITRATE	Yes
CO0215552	NORTH FORK WATER SERVICE	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0145630	NORTH HOLBROOK WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0143559	NUCLA TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0143559	NUCLA TOWN OF	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0262177	OLSONS GREENHOUSE	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0326584	ONE MILE CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0211100	OSIER STATION COMPANY	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0144025	PAGELS TP	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0144025	PAGELS TP	Radionuclides (RADs)	COMBINED URANIUM	No
CO0121550	PALMER LAKE MOBILE HOME RANCH	Operator Certification (Op Cert)	DBP STAGE 1	No



CO0121550	PALMER LAKE MOBILE HOME RANCH	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0123601	PANORAMIC MESA SUBD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0145540	PATTERSON VALLEY WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145540	PATTERSON VALLEY WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0359605	PEAK ONE PINE COVE CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0160095	PEAK VIEW PARK LLC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0160095	PEAK VIEW PARK LLC	Disinfection (DIS)	CHLORINE	Yes
CO0160095	PEAK VIEW PARK LLC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0138030	PEETZ TOWN OF	Inorganics (IOCs)	ARSENIC	No
CO0219806	PINEY RIVER RANCH	Surface Water (SW)	SWTR	Yes
CO0136610	PINON WSD	Disinfection (DIS)	CHLORINE	No
CO0149610	PITKIN GREEN HOA	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0115610	PITKIN MESA PIPELINE CO	Surface Water (SW)	SWTR	No
CO0115610	PITKIN MESA PIPELINE CO	Sanitary Survey (SS)	IESWTR	No
CO0235668	PLATTE RIVER POWER AUTHORITY	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0222670	PLEASANT VALLEY RV PARK	Operator Certification (Op Cert)	DBP STAGE 1	Yes



CO0208720	PONDEROSA LODGE INC	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0208720	PONDEROSA LODGE INC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0153800	PONDEROSA SUBDIVISION	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0153800	PONDEROSA SUBDIVISION	Disinfection (DIS)	CHLORINE	Yes
CO0221740	POP A TOP SALOON	Operator Certification (Op Cert)		No
CO0221740	POP A TOP SALOON	Disinfection (DIS)	CHLORINE	No
CO0262622	PRAIRIE ELEM AT NEW RAYMER	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0262622	PRAIRIE ELEM AT NEW RAYMER	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0222990	PROSPECTORS RV RESORT	Operator Certification (Op Cert)		No
CO0222990	PROSPECTORS RV RESORT	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0151600	PUEBLO CHEMICAL DEPOT	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0336650	PURGATOIRE CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0260600	QUAKER RIDGE CAMP	Disinfection (DIS)	CHLORINE	Yes
CO0226620	QUARTZ CREEK PROPERTY OWNERS ASSOCIATION	Surface Water (SW)	SWTR	No
CO0226620	QUARTZ CREEK PROPERTY OWNERS ASSOCIATION	Operator Certification (Op Cert)	DBP STAGE 1	Yes



CO0226620	QUARTZ CREEK PROPERTY OWNERS ASSOCIATION	Revised Total Coliform (RTCR)	E. COLI	Yes
CO0126668	RAINBOW PIPELINE PLACER SUBDIV	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0126668	RAINBOW PIPELINE PLACER SUBDIV	Disinfection (DIS)	GROUNDWATER RULE	No
CO0126668	RAINBOW PIPELINE PLACER SUBDIV	Revised Total Coliform (RTCR)	E. COLI	Yes
CO0211700	RAINBOW TROUT RANCH	Disinfection (DIS)	CHLORINE	Yes
CO0211700	RAINBOW TROUT RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0160375	RAINBOW VALLEY WD	Surface Water (SW)	TURBIDITY	No
CO0160375	RAINBOW VALLEY WD	Disinfection (DIS)	SWTR	Yes
CO0160375	RAINBOW VALLEY WD	Surface Water (SW)	IESWTR	Yes
CO0202666	RAKHRA MUSHROOM FARM	Inorganics (IOCs)	ARSENIC	No
CO0121675	RAMAH TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0235666	RAVENCREST CHALET	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0235673	RED FEATHER SUPER MARKET	Disinfection (DIS)	SWTR	Yes
CO0121700	RED ROCK VALLEY WD	Disinfection (DIS)	SWTR	Yes
CO0121700	RED ROCK VALLEY WD	Surface Water (SW)	IESWTR	Yes



CO0119673	RED SKY RANCH	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0115671	REDWOOD ARMS MOTEL	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0254676	RIVERBEND CABINS	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0140800	RIVERCREST ACRES HOA	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0208120	RIVERS MOUNTAIN HOTEL	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0234720	RIVERSIDE RVP	Operator Certification (Op Cert)		No
CO0145570	RIVERSIDE WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0235676	RIVERVIEW CG	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0235676	RIVERVIEW CG	Disinfection (DIS)	CHLORINE	No
CO0143676	RIVERWOOD SUBD WC	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0253690	RIVIERE ESTATES	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0121725	ROCK CREEK MESA	Surface Water (SW)	SWTR	Yes
CO0122800	ROCKVALE TOWN OF	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0230002	ROCKY MOUNTAIN COLLEGE OF ARTS	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0219685	ROUNDUP RIVER RANCH	Disinfection (DIS)	SWTR	Yes
CO0151700	RYE TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No



CO0151700	RYE TOWN OF	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0151700	RYE TOWN OF	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0155800	SAGUACHE TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0112850	SAN ACACIO DOMESTIC WA	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0227698	SAN JUAN RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0107702	SAN SOUCI MHP	Surface Water (SW)	TURBIDITY	Yes
CO0107702	SAN SOUCI MHP	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0260700	SANBORN WESTERN CAMPS	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0255700	SAND DUNES SWIMMING POOL AND RV PARK	Disinfection (DIS)	CHLORINE	Yes
CO0233701	SATURDAYS DISCOUNT STORE	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0121750	SECURITY MHP	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0132015	SEIBERT TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0132015	SEIBERT TOWN OF	Lead and Copper (LCR)	LEAD & COPPER RULE	No
CO0207708	SGRY	Disinfection (DIS)	CHLORINE	Yes
CO0131800	SHERIDAN LAKE WC	Radionuclides (RADs)	COMBINED URANIUM	No
CO0251743	SIGNAL MOUNTAIN RANCH PROPERTY OWNERS WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No



CO0251743	SIGNAL MOUNTAIN RANCH PROPERTY OWNERS WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0326710	SILVER JACK CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0120025	SIMLA TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0260780	SKY HIGH SCOUT RANCH	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0260780	SKY HIGH SCOUT RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0211900	SKY LINE LODGE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0108100	SNOWY PEAKS RV AND RENTALS	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0108100	SNOWY PEAKS RV AND RENTALS	Disinfection (DIS)	CHLORINE	Yes
CO0259018	SOLITUDE STATION COPPER MOUNTAIN	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0126715	SOMERSET DOMESTIC WD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0204925	SONLIGHT ADVENTURES INC	Disinfection (DIS)	CHLORINE	No
CO0145690	SOUTH SWINK WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145690	SOUTH SWINK WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0218029	SPRUCEWOOD INN	Disinfection (DIS)	CHLORINE	Yes
CO0325724	ST LOUIS CREEK CG NO 1 EAST	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes



CO0325725	ST LOUIS CREEK CG NO 2 WEST	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0110040	ST MARYS GLACIER WSD	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0103079	STAGE RUN HOA	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0224724	STAGE STOP WS	Nitrogen (NOX)	NITRATE	Yes
CO0136724	STARKVILLE TOWN OF	Disinfection (DIS)	CHLORINE	No
CO0207724	STONE MOUNTAIN LODGE AND CABINS	Surface Water (SW)	TURBIDITY	Yes
CO0236700	STONEWALL SHOPPING BAG	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0335725	STOVE PRAIRIE CG	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0115726	STUCKER MESA DOMESTIC WC	Surface Water (SW)	IESWTR	No
CO0233850	SUGAR LOAFIN RV CAMPGROUND	Operator Certification (Op Cert)		No
CO0123500	SUN MEADOW ESTATES	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0123500	SUN MEADOW ESTATES	Radionuclides (RADs)	COMBINED URANIUM	No
CO0223725	SUNLIGHT MOUNTAIN INN	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0239725	SUNSET LAKE SUMMER HOME OWNERS	Surface Water (SW)	IESWTR	Yes
CO0357725	SUNSHINE CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes





CO0219730	SYLVAN LAKE VISITOR CENTER	Disinfection (DIS)	CHLORINE	Yes
CO0157900	TELLURIDE PINES HOA	Surface Water (SW)	TURBIDITY	No
CO0157900	TELLURIDE PINES HOA	Surface Water (SW)	IESWTR	No
CO0353700	THIRTY MILE CG	Disinfection (DIS)	CHLORINE	Yes
CO0247756	TRAVEL PORT CG	Disinfection (DIS)	CHLORINE	Yes
CO0103090	TRAVOIS HOA	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0103090	TRAVOIS HOA	Disinfection (DIS)	CHLORINE	Yes
CO0128726	TRES VALLES WEST	Sanitary Survey (SS)	IESWTR	No
CO0243185	TRI STATE G AND T NUCLA STA	Disinfection (DIS)	CHLORINE	Yes
CO0333790	TURQUOISE LAKE REC AREA	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0333790	TURQUOISE LAKE REC AREA	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0333790	TURQUOISE LAKE REC AREA	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0134855	TWILIGHT PEAKS MOUNTAIN VILLAGE	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0233400	TWIN LAKES INN	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0239761	TWIN PEAKS BIBLE CAMP	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0333795	TWIN PEAKS CG PARRY PEAK CG	Sanitary Survey (SS)	GROUNDWATER RULE	No



CO0333795	TWIN PEAKS CG PARRY PEAK CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0115784	UPPER SURFACE CREEK DOMESTIC WUA	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0121845	US AIR FORCE ACADEMY	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0134790	UTE PASS WA INC	Surface Water (SW)	TURBIDITY	Yes
CO0134790	UTE PASS WA INC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0234880	VALLECITO RESORT	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0239800	VALLEY RANCH SUPPLY	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0255850	VALLEY VIEW HOT SPRINGS	Disinfection (DIS)	CHLORINE	Yes
CO0255850	VALLEY VIEW HOT SPRINGS	Revised Total Coliform (RTCR)	E. COLI	Yes
CO0145750	VALLEY WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145750	VALLEY WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0227810	VICKERS RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0105800	VILAS TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0105800	VILAS TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0255680	VILLA GROVE TRADE	Sanitary Survey (SS)	GROUNDWATER RULE	No



CO0145780	VROMAN WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145780	VROMAN WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0201051	WAGON WHEEL SKATING RINK	Nitrogen (NOX)	NITRATE	No
CO0223833	WALDORF SCHOOL	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0128900	WALSENBURG CITY OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0128900	WALSENBURG CITY OF	Surface Water (SW)	SWTR	No
CO0128900	WALSENBURG CITY OF	Sanitary Survey (SS)	IESWTR	No
CO0105900	WALSH TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0105900	WALSH TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0235833	WATER MAN THE	Water Hauler (Hauler)	WATER HAULER RULE	Yes
CO0149613	WEST RANCH SUBD	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0118085	WESTCREEK LAKES WD	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0235315	WESTERN RIDGE RESTAURANT AND RESORT LLC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0130842	WHEAT RIDGE WATER DISTRICT	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0333890	WHITE STAR HOST SITE	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0121900	WIDEFIELD WSD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes



CO0235842	WILDWOOD INN	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0235844	WIND RIVER RANCH WS	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0260975	WISHING WELL MOTEL	Surface Water (SW)	SWTR	No
CO0149844	WJ METRO DISTRICT	Surface Water (SW)	SWTR	Yes
CO0240850	WOLF CREEK SKI CORP	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0240850	WOLF CREEK SKI CORP	Disinfection (DIS)	SWTR	No
CO0221980	WOLFORD ELEMENTARY SCHOOL DISTRICT 20	Disinfection (DIS)	CHLORINE	Yes
CO0227852	WOODLAKE PARK	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0227852	WOODLAKE PARK	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0261003	WOODLIN SCHOOL	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0121950	WOODMOOR WSD	Disinfection (DIS)	CHLORINE	Yes
CO0235850	WORKSHIRE LODGE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0163010	WRAY CITY OF	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0254901	YAMPA RIVER STATE PARK	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0135883	YMCA ROCKIES WIND RIVER	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No



CO0135883	YMCA ROCKIES WIND RIVER	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0135883	YMCA ROCKIES WIND RIVER	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0263185	YUMA FEEDLOT	Disinfection (DIS)	CHLORINE	Yes

