



COLORADO
Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

COLORADO SAFE DRINKING WATER PROGRAM CALENDAR YEAR 2018 ANNUAL COMPLIANCE REPORT

This report is available at colorado.gov/cdphe/drinking-water-consumer-information



Table of Contents

Introduction	3
Definitions	3
National Primary Drinking Water Regulations	5
Violations	6
Overview	7
Summary of All Violations	7
Inorganic Chemical Violations (not including Nitrogen Compounds and Radionuclides)	9
Nitrogen Compound Violations	9
Radionuclide Violations	9
Volatile Organic Chemical Violations	10
Synthetic Organic Chemical Violations	10
Consumer Confidence Report (CCR) Rule Violations	12
Cross Connection Control and Backflow Prevention Rule Violations	12
Disinfection Violations	13
Disinfection Byproducts Rule Violations	14
Chlorite and Bromate Rule Violations	14
Total Trihalomethanes and Haloacetic Acids Rule Violations	14
Groundwater Rule Violations	15
Lead and Copper Rule Violations	15
Notification, Record Keeping, and Monitoring Plan Violations	16
Operator Certification Rule Violations	16
Plans and Specification Violations	16
Public Notice Rule Violations	16
Revised Total Coliform Rule (Microbial) Violations	17
Sanitary Survey Rule Violations	17
Storage Tank Rule Violations	18
Surface Water Treatment Rule Violations	19
Water Hauler Rule Violations	20
Variances and Exemptions	21
Report Availability and Contact Information	21
Appendix A: PWSs with Health-Based Violations	22

Introduction

The United States Environmental Protection Agency (EPA) established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 Amendments, EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs). For some regulations, EPA establishes treatment techniques (TTs) in lieu of MCLs. Standards were also set on how often public water systems (PWSs) monitor their water for contaminants and report the sample results. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M&R) requirements. In addition, EPA requires select PWSs to monitor for unregulated contaminants to provide data for future regulatory development. The 1996 Amendments to the SDWA require public notification to include a clear and understandable explanation of the nature of each violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation, and the possibility of alternative water supplies during the violation. The Colorado Department of Public Health and Environment's (CDPHE) Safe Drinking Water Program (SDWP) implements the SDWA, with amendments, pursuant to Regulation 11 (Colorado Primary Drinking Water Regulations) for the State of Colorado.

The Annual Compliance Report (ACR) is intended to provide a total annual representation of the numbers of violations. Violations fall into one of two categories:

1. Health-Based
2. Non-Health-Based

This report was prepared to meet the EPA's reporting requirements and is updated on a yearly basis.

Definitions

- **Public Water System (PWS)**: Provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs:
 - Community (e.g. cities, or towns)
 - Non-Transient, Non-Community (e.g. schools, or factories)
 - Transient, Non-Community systems (e.g. restaurants, rest stops, or parks)
- **Health-Based**: Potential short-term or long-term health risks.
 - **Maximum Contaminant Level (MCL)**: The highest level of a contaminant allowed in drinking water. Note: Under the Lead and Copper Rule, MCLs were not established. For this rule, “action levels” rather than MCLs define the levels at which a public water system must take action to reduce the concentration of lead and/or copper.
 - **Maximum Residual Disinfectant Level (MRDL)**: The highest level of a disinfectant (added for the treatment of water) allowed in drinking water. MRDLs are enforceable in the same manner as MCLs.
 - **Treatment Techniques (TT)**: Unacceptable levels, in lieu of a MCL, for selected water characteristics or a failure to correct an identified issue. Turbidity, for example, which measures the cloudiness of water.
- **Non-Health-Based**: No health risks or health risks are unknown.
 - **Monitoring and Reporting (M&R)**: To monitor, test, and report for water characteristics (e.g. contaminants) present in drinking water. All minor and major violations are included.
 - **Public Notice (PN)**: A requirement for the PWS to notify their customers of any and all violations. PN requirements take into account the seriousness of the violation (or situation) and any potential adverse health effects that may be involved.
- **Variance**: A departure from a primary drinking water regulation if the characteristics of the raw water sources available to the PWS do not allow the system to meet the MCL.
- **Exemption**: Temporarily relieves a PWS of its obligation to comply with an MCL, TT, or both, due to compelling factors (which may include economic factors).

National Primary Drinking Water Regulations

The Safe Drinking Water Act (SDWA) is the federal law that regulates the quality of drinking water. The SDWA sets standards for drinking water quality and stipulates the monitoring requirements for PWSs. The following regulations have been promulgated under the CPDWR:

- **Chemical Phase Rule:** Provide public health protection through the reduction of chronic risk (e.g. cancer, organ damage, etc.) from the exposure of:
 - Inorganic Chemicals (IOCs)
 - Nitrate and Nitrite (NOX)
 - Synthetic Organic Chemicals (SOCs)
 - Volatile Organic Chemicals (VOCs)
 - Radionuclides (RADs)
- **Consumer Confidence Rule (CCR):** An annual drinking water quality report distributed by PWSs to their customers by July 1st. The report contains information regarding sources used (i.e. rivers, lakes, reservoirs, etc.), detected contaminants, violations, and educational information.
- **Cross-Connection Control Rule (CCX):** Require PWSs to inspect system for cross-connections and backflow prevention devices.
- **Microbial, Disinfection, and Disinfection Byproducts (MICRO, DIS, and DBPs):** In general, drinking water must be disinfected to inactivate microbial pathogens (e.g. *E. coli*, salmonella, etc.). To protect against potential microbial contamination, PWSs add disinfectants such as chlorine. However, disinfectants can react with naturally occurring material in the source water and form byproducts, which may pose adverse health risks. PWSs must carefully maintain a balance between addressing potential microbial contamination and byproduct formation. The following rules address this issue:
 - **Groundwater Rule (GWR):** The purpose of the GWR is to provide increased protection against microbial pathogens in PWSs that utilize groundwater sources.
 - **Disinfection (DIS):** The purpose of these rules is to provide protection against microbial contamination.
 - **Disinfection Byproduct Rules (DBPs):** The purpose of these rules is to reduce exposure to disinfection byproducts for customers of PWSs that add a disinfectant to the drinking water during any part of the treatment process.
 - **Surface Water Treatment Rules (SWTRs):** The purpose of the SWTRs is to prevent waterborne diseases caused by viruses, *Giardia*, and *Cryptosporidium*. The rules require surface water systems to filter and disinfect their water to reduce the occurrence of microbial contamination.
 - **Revised Total Coliform Rule (RTCRC):** The purpose of this rule is to increase public health protection through the reduction of contamination in the drinking water distribution system.
 - **Total Coliform Rule (TCR):** Provide public health protection by maintaining the integrity of the distribution system and requiring public water systems to



monitor for the presence of microbial contamination. This rule was replaced by the Revised Total Coliform Rule on April 1, 2016.

- Lead and Copper Rule (LCR): Protect public health by minimizing the public's exposure to lead and copper.
- Notification, Record Keeping, and Monitoring Plan (Notification): Require PWSs to notify the state of any drinking water violations or situations that may pose an adverse health risk, retain records, and have a monitoring plan.
- Operator Certification Rule (Op Cert): Require PWSs to have a certified operator.
- Plans and Specifications (P&S): Require PWSs to get approval from the state before making physical modifications to the water system.
- Public Notice Rule (PN): Require PWSs to notify their customers of any drinking water violations or situations that may pose an adverse health risk.
- Sanitary Survey (SS): Require PWSs to correct deficiencies found during an inspection.
- Storage Tanks (Tanks): Require PWSs to perform inspections on finished water storage tanks and fix any issues identified.
- Water Hauler Rule (Hauler): Require PWSs that haul water to meet special requirements.



Violations

Overview

The number of PWSs in the state changes on a day by day basis. This is due to seasonal operations, new PWSs opening, existing PWSs closing, and changes to the population being served. Table 1 displays a typical number of systems, on any one day, by population and system type.

Table 1. Number of PWSs by System Type and Population

Population	Water System Type			Total
	Community	Transient, Non-Community	Non-Transient, Non-Community	
25-500	528	879	139	1546
501-3,300	204	74	28	306
3,301-10,000	86	5	5	96
10,001-100,000	73	0	0	73
>100,000	10	0	0	10
Total	901	958	172	2031

Violations are based on data compiled in June, 2019 from Colorado’s production SDWIS/State database. If a violation: (1) was unresolved as of January 1, 2018, or (2) occurred in calendar year 2018, it was included. M&R violations for PWSs sampling less frequently than annually will be reported in the third, sixth, or ninth year of a compliance cycle. Calendar year 2018 was the eighth year in a compliance cycle. Table 2 summarizes the number of violations and the number of systems by each drinking water rule and violation type. The subsequent sections provide further details for each of the drinking water rules.

Appendix A identifies the public water systems that were in violation of maximum contaminant levels and/or treatment technique requirements. The final column indicates if the violation was resolved.



Summary of All Violations

- 324 systems in violation of at least one of the health-based standards.
- 808 systems in violation of at least one of the non-health-based standards.

Table 2. Summary by Rule and Violation Type

Group	Non-Health-Based Violations		Health-Based Violations	
	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
Chlorite and Bromate (DBP - Other) Totals:	7	2	-	-
Consumer Confidence (CCR) Totals:	60	55	-	-
Cross Connection Control (CCX) Totals:	330	221	70	45
Disinfection (DIS) Totals:	533	306	148	80
Ground Water (GW) Totals:	29	23	-	-
Inorganics (IOCs) Totals:	113	13	27	4
Lead and Copper (LCR) Totals:	192	161	13	11
Nitrogen (NOX) Totals:	70	59	136	15
Notification, Record Keeping, and Monitoring Plan (Notification) Totals:	122	110	-	-
Operator Certification (Op Cert) Totals:	-	-	62	61
Plans and Specifications (P&S) Totals:	55	55	-	-
Precursors (Precursors) Totals:	7	3	2	2
Public Notice (PN) Totals:	494	254	-	-
Radionuclides (RADs) Totals:	39	13	582	28
Revised Total Coliform (RTCR) Totals:	196	159	29	26
Sanitary Survey (SS) Totals:	-	-	114	47
Storage Tanks (Tanks) Totals:	41	41	46	42
Surface Water (SW) Totals:	232	111	40	29
Synthetic Organics (SOCs) Totals:	241	17	-	-
TTHM and HAA5 (DBP - TTHM and HAA5) Totals:	119	63	136	26
Volatile Organics (VOCs) Totals:	426	23	-	-
Water Hauler (Hauler) Totals:	-	-	1	1
Total:	3306	808	1406	324



Inorganic Chemical Violations
(not including Nitrogen Compounds and Radionuclides)

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 4 systems in violation of at least one of the MCLs.
- 13 systems failed to monitor/report for at least one of the contaminants.

Table 3. Summary of Inorganic Chemicals

Inorganics (IOCs)				
Contaminant	Health-Based Violations		Non-Health-Based Violations	
Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
ANTIMONY, TOTAL	-	-	9	9
ARSENIC	22	3	12	11
BARIUM	-	-	9	9
BERYLLIUM, TOTAL	-	-	9	9
CADMIUM	-	-	9	9
CHROMIUM	-	-	9	9
FLUORIDE	-	-	11	11
MERCURY	-	-	9	9
NICKEL	-	-	9	9
SELENIUM	5	1	9	9
SODIUM	-	-	9	9
THALLIUM, TOTAL	-	-	9	9
Inorganics (IOCs) Totals:	27	4	113	13

Nitrogen Compound Violations

- All PWSs are required to comply.
- 15 systems in violation of the Nitrate MCL.
- 59 systems failed to monitor/report for Nitrate or Nitrite.

Table 4. Summary of Nitrogen Compounds

Nitrogen (NOX)				
Contaminant	Health-Based Violations		Non-Health-Based Violations	
Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
NITRATE	136	15	67	58
NITRITE	-	-	3	3
Nitrogen (NOX) Totals:	136	15	70	59



Radionuclide Violations

- Community PWSs are required to comply.
- 28 systems in violation of at least one of the MCLs.
- 13 systems failed to monitor/report for at least one of the contaminants.

Table 5. Summary of Radionuclides

Radionuclides (RADs)				
Contaminant	Health-Based Violations		Non-Health-Based Violations	
Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
COMBINED RADIUM (-226 & -228)	384	24	17	13
COMBINED URANIUM	61	5	10	9
GROSS ALPHA, EXCL. RADON & U	137	9	12	10
Radionuclides (RADs) Totals:	582	28	39	13

Volatile Organic Chemical Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- Zero systems in violation of at least one of the MCLs.
- 23 systems failed to monitor/report for at least one of the contaminants.

Table 6. Summary of Volatile Organic Chemicals

Volatile Organics (VOCs)				
Contaminant	Health-Based Violations		Non-Health-Based Violations	
Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
1,1,1-TRICHLOROETHANE	-	-	20	20
1,1,2-TRICHLOROETHANE	-	-	20	20
1,1-DICHLOROETHYLENE	-	-	20	20
1,2,4-TRICHLOROBENZENE	-	-	20	20
1,2-DICHLOROETHANE	-	-	20	20
1,2-DICHLOROPROPANE	-	-	20	20
BENZENE	-	-	20	20
CARBON TETRACHLORIDE	-	-	20	20
CHLOROBENZENE	-	-	20	20
CIS-1,2-DICHLOROETHYLENE	-	-	20	20
DICHLOROMETHANE	-	-	20	20
ETHYLBENZENE	-	-	22	22
O-DICHLOROBENZENE	-	-	20	20
P-DICHLOROBENZENE	-	-	20	20
STYRENE	-	-	20	20
TETRACHLOROETHYLENE	-	-	20	20
TOLUENE	-	-	21	21
TRANS-1,2-DICHLOROETHYLENE	-	-	20	20
TRICHLOROETHYLENE	-	-	20	20
VINYL CHLORIDE	-	-	20	20
XYLENES, TOTAL	-	-	23	23
Volatile Organics (VOCs) Totals:	-	-	426	23



Synthetic Organic Chemical Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- Zero systems in violation of at least one of the MCLs.
- 17 systems failed to monitor/report for at least one of the contaminants.

Table 7. Summary of Synthetic Organic Chemicals

Synthetic Organics (SOCs)				
Contaminant Name	Health-Based Violations		Non-Health-Based Violations	
	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
1,2-DIBROMO-3-CHLOROPROPANE	-	-	8	8
2,4,5-TP	-	-	8	8
2,4-D	-	-	8	8
ALDICARB	-	-	4	4
ALDICARB SULFONE	-	-	4	4
ALDICARB SULFOXIDE	-	-	4	4
ATRAZINE	-	-	7	7
BENZO(A)PYRENE	-	-	10	10
BHC-GAMMA	-	-	9	9
CARBOFURAN	-	-	7	7
CHLORDANE	-	-	8	8
DALAPON	-	-	9	9
DI(2-ETHYLHEXYL) ADIPATE	-	-	8	8
DI(2-ETHYLHEXYL) PHTHALATE	-	-	11	11
DINOSEB	-	-	7	7
DIQUAT	-	-	8	8
ENDOTHALL	-	-	8	8
ENDRIN	-	-	8	8
ETHYLENE DIBROMIDE	-	-	9	9
HEPTACHLOR	-	-	8	8
HEPTACHLOR EPOXIDE	-	-	8	8
HEXACHLOROBENZENE	-	-	8	8
HEXACHLOROCYCLOPENTADIENE	-	-	10	8
LASSO	-	-	7	7
METHOXYCHLOR	-	-	8	8
OXAMYL	-	-	8	8
PENTACHLOROPHENOL	-	-	8	8
PICLORAM	-	-	7	7
SIMAZINE	-	-	8	8
TOTAL POLYCHLORINATED BIPHENYLS (PCB)	-	-	8	8
TOXAPHENE	-	-	8	8
Synthetic Organics (SOCs) Totals:	-	-	241	17



Consumer Confidence Report (CCR) Rule Violations

- Community PWSs are required to comply.
- 55 systems in violation for failing to report to their customers.

Table 8. Summary of the Consumer Confidence Report

Consumer Confidence (CCR)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
71 - CCR REPORT	CONSUMER CONFIDENCE RULE	-	-	58	54
72 - CCR ADEQUACY/AVAILABILITY /CONTENT	CONSUMER CONFIDENCE RULE	-	-	2	2
Consumer Confidence (CCR) Totals:		-	-	60	55

Cross Connection Control and Backflow Prevention Rule Violations

- All PWSs are required to comply.
- 45 systems in violation for potential contamination.
- 221 systems failed to test/report.

Table 9. Summary of Cross Connection Control and Backflow Prevention

Cross Connection Control (CCX)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
ML - STATE TREATMENT TECHNIQUE LEVEL	CROSS CONNECTION RULE	70	45	-	-
MS - STATE MONITORING	CROSS CONNECTION RULE	-	-	330	221
Cross Connection Control (CCX) Totals:		70	45	330	221



Disinfection Violations

- All PWSs are required to comply.
- 80 systems in violation of at least one of the health-based standards.
- 306 systems in violation of at least one of the non-health-based standards.

Table 10. Summary of Disinfection

Disinfection (DIS)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
41 - RES DISINFECT CONCENTRATION (SWTR)	CHLORINE	59	22	-	-
	SWTR	24	5	-	-
MD - FAILURE PROVIDE DISINFECT TREATMENT	CHLORINE	11	11	-	-
	GROUNDWATER RULE	4	4	-	-
ML - STATE TREATMENT TECHNIQUE LEVEL	CHLORINE	50	43	-	-
27 - MONITORING (DBP) (CHL DIOXIDE)	CHLORINE DIOXIDE	-	-	6	2
27 - MONITORING ROUTINE (DBP) MAJOR	CHLORINE	-	-	92	76
27 - MONITORING ROUTINE (DBP) MINOR	CHLORINE	-	-	1	1
36 - MONITORING, RT MAJOR (LT2-FILTERED)	CHLORINE	-	-	4	2
36 - MONITORING, RTN, RPT MAJOR (SWTR-FILTER)	CHLORINE	-	-	170	95
36 - MONITORING, RTN, RPT MINOR (SWTR-FILTER)	CHLORINE	-	-	2	2
MS - STATE MONITORING	CHLORINE	-	-	224	187
VC - EQUIPMENT VERIFICATION OR CALIBRATION	CHLORINE	-	-	34	34
Disinfection (DIS) Totals:		148	80	533	306

Disinfection Byproducts Rule Violations

Chlorite and Bromate Rule Violations

- PWSs using chlorine dioxide or ozone are required to comply.
- Two systems failed to monitor/report for at least one of the contaminants.

Table 11. Summary of Chlorite and Bromate

Chlorite and Bromate (DBP - Other)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
27 - MONITORING, ROUTINE (DBP), MAJOR	CHLORITE	-	-	7	2
Chlorite and Bromate (DBP - Other) Totals:		-	-	7	2

Total Trihalomethanes and Haloacetic Acids Rule Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 26 systems in violation of at least one of the MCLs.
- 63 systems failed to monitor/report for at least one of the contaminants or failed to complete an evaluation report.

Table 12. Summary of Total Trihalomethanes and Haloacetic Acids

TTHM and HAA5 (DBP - TTHM and HAA5)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
02 - MCL, AVERAGE	TOTAL HALOACETIC ACIDS (HAA5)	6	1	-	-
	TTHM	14	2	-	-
02 - MCL, LRAA	TOTAL HALOACETIC ACIDS (HAA5)	35	9	-	-
	TTHM	81	21	-	-
27 - MONITORING, ROUTINE (DBP), MAJOR	TOTAL HALOACETIC ACIDS (HAA5)	-	-	46	42
	TTHM	-	-	47	43
27 - MONITORING, ROUTINE (DBP), MINOR	TOTAL HALOACETIC ACIDS (HAA5)	-	-	1	1
	TTHM	-	-	1	1
35 - FAILURE SUBMIT OEL REPORT FOR HAA5	TOTAL HALOACETIC ACIDS (HAA5)	-	-	2	2
35 - FAILURE SUBMIT OEL REPORT FOR TTHM	TTHM	-	-	7	5
35 - FAILURE SUBMIT SUBPART V PLAN, ESCALATED	DBP STAGE 2	-	-	15	15
TTHM and HAA5 (DBP - TTHM and HAA5) Totals:		136	26	119	63

Groundwater Rule Violations

- PWSs with a groundwater source not treated to surface water standards are required to comply.
- 23 systems failed to monitor/report their raw water source for *E. coli*.

Table 13. Summary of the Groundwater

Ground Water (GW)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
19 - MONITORING (GWR), ASSESSMENT, MAJOR	E COLI	-	-	1	1
34 - MONITOR GWR TRIGGERED/ADDITIONAL, MAJOR	E COLI	-	-	28	22
Ground Water (GW) Totals:		-	-	29	23

Lead and Copper Rule Violations

- Community and Non-Transient, Non-Community PWSs are required to comply.
- 11 systems in violation of at least one of the health-based standards.
- 161 systems in violation of at least one of the non-health-based standards.

Table 14. Summary of Lead and Copper

Lead and Copper (LCR)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
57 - OCCT/SOWT RECOMMENDATION/STUDY (LCR)	LEAD & COPPER RULE	8	7	-	-
58 - OCCT/SOWT INSTALL DEMONSTRATION (LCR)	LEAD & COPPER RULE	1	1	-	-
65 - PUBLIC EDUCATION (LCR)	LEAD & COPPER RULE	4	4	-	-
51 - INITIAL TAP SAMPLING (LCR)	LEAD & COPPER RULE	-	-	6	5
52 - FOLLOW-UP OR ROUTINE TAP M/R (LCR)	LEAD & COPPER RULE	-	-	44	42
53 - WATER QUALITY PARAMETER M/R (LCR)	LEAD & COPPER RULE	-	-	21	19
56 - INITIAL FOLLOW-UP/ROUTINE SOWT M/R (LCR)	LEAD & COPPER RULE	-	-	8	8
66 - LEAD CONSUMER NOTICE (LCR)	LEAD & COPPER RULE	-	-	113	104
Lead and Copper (LCR) Totals:		13	11	192	161

Notification, Record Keeping, and Monitoring Plan Violations

- All PWSs are required to comply.
- 110 systems failed to notify, maintain records, or have a complete monitoring plan.

Table 15. Summary of Notification, Record Keeping, and Monitoring Plan

Notification, Record Keeping, and Monitoring Plan					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
09 - RECORD KEEPING WITHOUT RULE CODE	N/A	-	-	43	43
32 - FAILURE TO HAVE MONITORING PLAN (LT2)	LT2ESWTR	-	-	7	7
5A - SAMPLE SITING PLAN ERRORS (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	47	47
MS - STATE MONITORING	MONITORING PLAN RULE	-	-	25	25
Notification, Record Keeping, and Monitoring Plan		-	-	122	110

Operator Certification Rule Violations

- All PWSs are required to comply.
- 61 systems failed have a certified operator.

Table 16. Summary of Operator Certification

Operator Certification (Op Cert)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
12 - QUALIFIED OPERATOR FAILURE	DBP STAGE 1	32	31	-	-
OC - QUALIFIED OPERATOR FAILURE - TRANSIENT	DBP STAGE 1	29	29	-	-
	N/A	1	1	-	-
Operator Certification (Op Cert) Totals:		62	61	-	-

Plans and Specification Violations

- All PWSs are required to comply.
- 55 systems failed to get prior approval before making changes to their systems.

Table 17. Summary of Plans and Specifications

Plans and Specifications (P&S)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
MS - STATE MONITORING	PLANS AND SPECIFICATIONS RULE	-	-	55	55
Plans and Specifications (P&S) Totals:		-	-	55	55

Public Notice Rule Violations

- All PWSs that incurred a violation or posed an adverse health risk are required to comply.
- 254 systems failed to provide public notice to their customers.



Table 18. Summary of the Public Notice

Public Notice (PN)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
75 - PUBLIC NOTICE RULE LINKED TO VIOLATION	PUBLIC NOTICE	-	-	241	129
76 - PUBLIC NOTICE RULE NOT LINKED VIOLATION	PUBLIC NOTICE	-	-	253	164
Public Notice (PN) Totals:		-	-	494	294

Revised Total Coliform Rule (Microbial) Violations

- All PWSs are required to comply.
- 26 systems in violation of at least one of the health-based standards.
- 159 systems in violation of at least one of the non-health-based standards.

Table 19. Summary of the Revised Total Coliform

Revised Total Coliform (RTCR)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
1A - MCL, E. COLI POS E COLI (RTCR)	E COLI	5	2	-	-
2A - LEVEL 1 ASSESS, MULTIPLE TC POS (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	2	2	-	-
2D - STARTUP PROCEDURES TT (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	22	22	-	-
3A - MONITORING, ROUTINE, MAJOR (RTCR)	E COLI	-	-	122	98
	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	50	46
3A - MONITORING, ROUTINE, MINOR (RTCR)	E COLI	-	-	11	11
	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	1	1
3B - MONITORING, ADD. ROUTINE, MAJOR (RTCR)	E COLI	-	-	1	1
3B - MONITORING, ADD. ROUTINE, MINOR (RTCR)	E COLI	-	-	1	1
4A - REPORTING, ASSESSMENT FORMS (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	1	1
4B - REPORT SAMPLE RESULT FAIL MONITOR RTCR	E COLI	-	-	4	3
4C - REPORT STARTUP PROCEDURES CERT FORM RTCR	REVISED TOTAL COLIFORM RULE (RTCR)	-	-	5	5
Revised Total Coliform (RTCR) Totals:		29	26	196	159

Sanitary Survey Rule Violations

- All PWSs are required to comply.
- 47 systems failed to correct deficiencies identified during an inspection.

Table 20. Summary of the Sanitary Survey



Sanitary Survey (SS)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
45 - FAILURE ADDRESS DEFICIENCY (GWR)	GROUNDWATER RULE	114	47	-	-
Sanitary Survey (SS) Totals:		114	47	-	-

Storage Tank Rule Violations

- All PWSs with storage tanks are required to comply.
- 42 systems in violation of at least one of the health-based standards.
- 41 systems in violation of at least one of the non-health-based standards.

Table 21. Summary of the Storage Tank

Storage Tanks (Tanks)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
ML - STATE TREATMENT TECHNIQUE LEVEL	STORAGE TANK RULE	46	42	-	-
MS - STATE MONITORING	STORAGE TANK RULE	-	-	41	41
Storage Tanks (Tanks) Totals:		46	42	41	41



Surface Water Treatment Rule Violations

- Surface Water and Groundwater-Under-the-Direct-Influence-of-Surface-Water PWSs are required to comply.
- 29 systems in violation for either inadequate filtration resulting in high turbidity (cloudiness) of the water, inadequate disinfection, or failure to filter.
- 111 systems failed to monitor/report/calibrate for turbidity or perform raw water source monitoring.
- Two systems in violation for inadequate total organic carbon removal.
- Three systems failed to monitor/report for total organic carbon or alkalinity.

Table 22. Summary of the Surface Water Treatment

Surface Water (SW)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
42 - FAILURE TO FILTER (SWTR)	SWTR	14	14	-	-
43 - SINGLE COMB FLTR EFFLUENT (IESWTR,LT1)	IESWTR	1	1	-	-
	TURBIDITY	4	4	-	-
44 - MONTHLY COMB FLTR EFFLUENT (IESWTR,LT1)	IESWTR	1	1	-	-
	TURBIDITY	20	13	-	-
32 - MONITORING, SOURCE (LT2), MAJOR	CRYPTOSPORIDIUM	-	-	1	1
	E COLI	-	-	97	51
	TURBIDITY	-	-	1	1
32 - MONITORING, SOURCE (LT2), MINOR	E COLI	-	-	1	1
38 - MONITORING, ROUTINE (IESWTR,LT1), MAJOR	TURBIDITY	-	-	116	59
VC - EQUIPMENT VERIFICATION OR CALIBRATION	TURBIDITY	-	-	16	16
Surface Water (SW) Totals:		40	29	232	111

Table 23. Summary of the Surface Water Precursors

Precursors (Precursors)					
Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
46 - INADEQUATE DBP PRECURSOR REMOVAL	CARBON, TOTAL	2	2	-	-
27 - MONITORING, ROUTINE (DBP), MAJOR	ALKALINITY, TOTAL	-	-	5	3
	CARBON, TOTAL	-	-	2	1
Precursors (Precursors) Totals:		2	2	7	3



Water Hauler Rule Violations

- All PWSs are required to comply.
- One system in violation of at least one of the health-based standards.
- Zero systems in violation of at least one of the non-health-based standards.

Table 25. Summary of the Water Hauler

Violation		Health-Based Violations		Non-Health-Based Violations	
Type	Name	# of Violations	# of Water Systems with Violations	# of Violations	# of Water Systems with Violations
ML - STATE TREATMENT TECHNIQUE LEVEL	WATER HAULER RULE	1	1	-	-
Water Hauler (Hauler) Totals:		1	1	-	-



Variations and Exemptions

Colorado's Safe Drinking Water Program did not issue any variations or exemptions to any public water system.

Report Availability and Contact Information

The summary report is available at
<https://www.colorado.gov/cdphe/drinking-water-consumer-information>.

For further information concerning this report, or with specific violations associated with public water systems, you may contact Phillip Stanwood with the Safe Drinking Water Compliance Assurance Section at (303) 692-3502 or by email at Phillip.Stanwood@state.co.us.



Appendix A: PWSs with Health-Based Violations

PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2018?
CO0221820	1859 RESTAURANT AT SEVEN FALLS	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0219100	4 EAGLE RANCH	Surface Water (SW)	TURBIDITY	Yes
CO0219100	4 EAGLE RANCH	Disinfection (DIS)	CHLORINE	Yes
CO0121111	4 WAY RANCH MD 1	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0107100	A 1 DISCOUNT WC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0121025	ACADEMY WSD	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0120001	AGATE WA	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0120001	AGATE WA	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0120001	AGATE WA	Disinfection (DIS)	CHLORINE	No
CO0136100	AGUILAR TOWN OF	Surface Water (SW)	SWTR	No
CO0215115	ALEXANDER LAKE LODGE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0215115	ALEXANDER LAKE LODGE	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0160050	ALPINE VILLAGE MHP	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0346116	AMPHITHEATER CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0308020	ANGEL OF SHAVANO CG NO 1	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0235185	ANNUNCIATION HEIGHTS	Lead and Copper (LCR)	LEAD & COPPER RULE	No



CO0335146	ANSEL WATROUS CG UPPER	Disinfection (DIS)	CHLORINE	No
CO0240050	ANTLERS RIO GRANDE LODGE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0111100	ANTONITO TOWN OF	Surface Water (SW)	TURBIDITY	No
CO0111100	ANTONITO TOWN OF	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0111100	ANTONITO TOWN OF	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0111100	ANTONITO TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0126121	ARROWHEAD RANCH WC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0126121	ARROWHEAD RANCH WC	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	Yes
CO0123123	ASGARD SUBDIVISION WA	Nitrogen (NOX)	NITRATE	No
CO0123123	ASGARD SUBDIVISION WA	Inorganics (IOCs)	SELENIUM	No
CO0249129	ASPEN SKI CORP GARRETT GULCH	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0249130	ASPEN SKI CORP HI ALPINE L9	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0103005	AURORA CITY OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0151050	AVONDALE WSD	Surface Water (SW)	SWTR	No
CO0247133	BADGER BASIN COUNTRY STORE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0235138	BEAVER MEADOWS RESORT	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0235138	BEAVER MEADOWS RESORT	Disinfection (DIS)	CHLORINE	No
CO0145030	BEEHIVE WC NO1	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No



CO0101015	BELLEVIEW CHRISTIAN COLLEGE	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0118001	BEVERLY HILLS MUTUAL WC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0135143	BIG ELK MEADOWS WA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0135143	BIG ELK MEADOWS WA	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0222570	BIGHORN RV PARK	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0225625	BLM PUMPHOUSE RECREATION SITE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0328085	BLUE LAKE CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0229150	BOCKMAN CAMPGROUNDS	Disinfection (DIS)	CHLORINE	No
CO0151150	BOONE TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0151150	BOONE TOWN OF	Surface Water (SW)	SWTR	No
CO0151150	BOONE TOWN OF	Nitrogen (NOX)	NITRATE	Yes
CO0136300	BRANSON TOWN OF	Surface Water (SW)	SWTR	No
CO0136300	BRANSON TOWN OF	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0101030	BRIGHTON VILLAGE LLC	Nitrogen (NOX)	NITRATE	No
CO0138001	BUFFALO HILLS RV PARK	Disinfection (DIS)	CHLORINE	Yes
CO0230159	BULK WATER RUNNER	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0132005	BURLINGTON CITY OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0132005	BURLINGTON CITY OF	Nitrogen (NOX)	NITRATE	Yes



CO0121075	CALHAN TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0238002	CALICHE SCHOOL	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0247018	CAMP ALEXANDER BOY SCOUTS	Disinfection (DIS)	CHLORINE	Yes
CO0307166	CAMP DICK CG	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0307166	CAMP DICK CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0221560	CAMP LA FORET	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0105100	CAMPO TOWN OF	Lead and Copper (LCR)	LEAD & COPPER RULE	No
CO0230166	CANYON SHOPPES THE	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0260160	CATAMOUNT CENTER	Surface Water (SW)	SWTR	No
CO0260820	CATHEDRAL RIDGE	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0115168	CATHEDRAL WC	Surface Water (SW)	SWTR	Yes
CO0211025	CENTAURI HS CENTAURI MS	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0308120	CHALK LAKE CAMPGROUND	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0145090	CHERAW TOWN OF	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145090	CHERAW TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0218003	CHERRY VALLEY ELEM SCHOOL	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0121176	CHEYENNE MOUNTAIN ESTATES MHP	Sanitary Survey (SS)	GROUNDWATER RULE	No



CO0221205	CHEYENNE MTN AIR FORCE STATION	Disinfection (DIS)	CHLORINE	Yes
CO0109006	CHEYENNE WELLS TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0109006	CHEYENNE WELLS TOWN OF	Disinfection (DIS)	GROUNDWATER RULE	Yes
CO0136175	CHICOSA WATER USERS ASSOCIATION	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0308130	COLLEGIATE PEAK CAMPGROUND NO 2	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0247021	COLORADO CHRISTIAN SERVICE CAMP	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0151200	COLORADO CITY MD	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	Yes
CO0151200	COLORADO CITY MD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0211186	CONEJOS COUNTY COMPLEX	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0211185	CONEJOS COUNTY COURTHOUSE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0211184	CONEJOS COUNTY JAIL	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0130184	CONIFER MD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0308135	COTTONWOOD LAKE CAMPGROUND	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0120184	COYOTE HILLS WS	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0115189	CRAWFORD MESA WA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0140500	CREEDE CITY OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0140500	CREEDE CITY OF	Disinfection (DIS)	CHLORINE	Yes



CO0126189	CRESTED BUTTE SOUTH	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0362001	CROW VALLEY CAMPGROUND	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0362001	CROW VALLEY CAMPGROUND	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0260040	CRYSTOLA BAR AND GRILL	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0260040	CRYSTOLA BAR AND GRILL	Surface Water (SW)	SWTR	No
CO0247004	DEER CREEK ELEM SCHOOL	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0353230	DEL NORTE OFFICE	Disinfection (DIS)	CHLORINE	Yes
CO0153200	DEL NORTE TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0116001	DENVER WATER BOARD	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0141210	DINOSAUR TOWN OF	Disinfection (DIS)	CHLORINE	No
CO0234480	DURANGO LA PLATA AIRPORT	Surface Water (SW)	TURBIDITY	Yes
CO0234480	DURANGO LA PLATA AIRPORT	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0134180	DURANGO WEST MD NO 1	Disinfection (DIS)	CHLORINE	Yes
CO0134190	DURANGO WEST MD NO 2	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0145120	EAST END WA	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0163001	ECKLEY TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0134210	EL RANCHO FLORIDA MD	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0120245	ELBERT COUNTY HWY 86 WD	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No



CO0333200	ELBERT CREEK CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0207466	ELDORA MOUNTAIN RESORT	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	Yes
CO0207235	ELDORADO CANYON STATE PARK	Disinfection (DIS)	CHLORINE	No
CO0234247	ELECTRA LAKE SPORTING CLUB	Disinfection (DIS)	SWTR	No
CO0234247	ELECTRA LAKE SPORTING CLUB	Disinfection (DIS)	CHLORINE	No
CO0121200	ELEPHANT ROCK MHP	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0252246	ELK CREEK RANCH	Disinfection (DIS)	CHLORINE	Yes
CO0125246	ELK VALLEY OLYMPIC VILLAGE	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0110010	EMPIRE TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0101031	ESTATES AT BROMLEY	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0101031	ESTATES AT BROMLEY	Disinfection (DIS)	CHLORINE	Yes
CO0145150	EUREKA WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145150	EUREKA WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0230300	EVERGREEN SOUTH	Disinfection (DIS)	CHLORINE	No
CO0147020	FAIRPLAY TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0147020	FAIRPLAY TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0159050	FARMERS KORNER MHP	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0145180	FAYETTE WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No



CO0145180	FAYETTE WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0132010	FLAGLER TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0132010	FLAGLER TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0318282	FLAT ROCKS CAMPGROUND	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0138010	FLEMING TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0160175	FLORISSANT WSD	Lead and Copper (LCR)	LEAD & COPPER RULE	No
CO0121300	FOUNTAIN VALLEY AUTHORITY	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0121300	FOUNTAIN VALLEY AUTHORITY	Precursors (Precursors)	CARBON, TOTAL	Yes
CO0223279	FOUR MILE RANCH HOA	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0145210	FOWLER TOWN OF	Surface Water (SW)	SWTR	No
CO0103050	FOXRIDGE FARMS MHP	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0218006	FRANKTOWN ELEM SCHOOL	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0125288	FRASER TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0240400	FREEMONS GUEST RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0226267	FRENCHYS	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0226267	FRENCHYS	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0135291	FT COLLINS CITY OF	Surface Water (SW)	TURBIDITY	Yes



CO0101060	GALAMBS MOBILE HOME AND RV PARK	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0120300	GAMBEL OAKS HOA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0134840	GLACIER CLUB	Precursors (Precursors)	CARBON, TOTAL	Yes
CO0134840	GLACIER CLUB	Lead and Copper (LCR)	LEAD & COPPER RULE	No
CO0150300	GRANADA TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0150300	GRANADA TOWN OF	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0150300	GRANADA TOWN OF	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0150300	GRANADA TOWN OF	Disinfection (DIS)	CHLORINE	No
CO0125323	GRAND COUNTY WATER NO 1	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0230190	GRANITE LAKE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0162302	GREELEY RV PARK	Nitrogen (NOX)	NITRATE	Yes
CO0111500	GUADALUPE WA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0254725	HAHNS PEAK ROADHOUSE	Disinfection (DIS)	CHLORINE	Yes
CO0115333	HANSON MESA DOMESTIC PIPELINE CO INC	Disinfection (DIS)	CHLORINE	Yes
CO0226333	HARMELS RANCH RESORT	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0150500	HARTMAN TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0208480	HEART OF THE ROCKIES	Disinfection (DIS)	CHLORINE	Yes
CO0101075	HI LAND ACRES WSD	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No



CO0130045	HIDDEN VALLEY MUTUAL WC	Nitrogen (NOX)	NITRATE	No
CO0226845	HIGH PARK SPRING LLC SONRISE	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0102300	HIGH VALLEY MHP	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0102300	HIGH VALLEY MHP	Inorganics (IOCs)	ARSENIC	No
CO0102300	HIGH VALLEY MHP	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0160200	HIGHLAND LAKES WD	Nitrogen (NOX)	NITRATE	No
CO0145330	HOLBROOK CENTER SOFT WA	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0222700	HOLCIM INC	Disinfection (DIS)	CHLORINE	Yes
CO0149352	HOLLAND HILLS MD	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0149352	HOLLAND HILLS MD	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0150600	HOLLY TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0226352	HOLTS GUEST RANCH	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0148005	HOLYOKE CITY OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0157250	ILIUM VALLEY WS	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0130065	INDIAN HILLS WD	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0130065	INDIAN HILLS WD	Disinfection (DIS)	SWTR	Yes
CO0308300	IRON CITY CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0315390	ISLAND LAKE CG	Disinfection (DIS)	CHLORINE	No
CO0207401	JACOBS CORNER	Disinfection (DIS)	CHLORINE	Yes



CO0107401	JAMESTOWN TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0107401	JAMESTOWN TOWN OF	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0235618	JELLYSTONE PARK OF ESTES PARK	Surface Water (SW)	SWTR	Yes
CO0235618	JELLYSTONE PARK OF ESTES PARK	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0235416	JOHN TIMOTHY STONE CLIFFS ASSOC	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0235416	JOHN TIMOTHY STONE CLIFFS ASSOC	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0235416	JOHN TIMOTHY STONE CLIFFS ASSOC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0162418	JOHNSTOWN TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0255412	JOYFUL JOURNEY HOT SPRINGS AND SPA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0339425	JUMBO CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0137012	KARVAL WATER USERS INC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0162438	KEENESBURG TOWN OF	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0121415	KEETON RANCH WATER	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0120015	KIOWA TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0120015	KIOWA TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0120015	KIOWA TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0111600	LA JARA TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0111600	LA JARA TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes



CO0111600	LA JARA TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0134530	LAKE DURANGO WA	Surface Water (SW)	TURBIDITY	Yes
CO0134530	LAKE DURANGO WA	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0212466	LAKE SANCHEZ ESTATES	Disinfection (DIS)	CHLORINE	No
CO0333405	LAKE VIEW CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0326467	LAKE VIEW CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0207465	LANE GUEST RANCH	Surface Water (SW)	TURBIDITY	No
CO0118030	LARKSPUR TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0107472	LEFTHAND WSD LAKE PINES	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0134570	LIGHTNER CREEK MHP	Disinfection (DIS)	CHLORINE	Yes
CO0201475	LITTLE LIGHTS EARLY LEARNING CENTER	Nitrogen (NOX)	NITRATE	Yes
CO0227476	LITTLE SQUAW RESORT	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0235283	LIVERMORE WS	Disinfection (DIS)	CHLORINE	No
CO0110026	LOOKOUT MOUNTAIN WD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0260161	LOST BURRO CAMPGROUND	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0260161	LOST BURRO CAMPGROUND	Disinfection (DIS)	CHLORINE	Yes
CO0260161	LOST BURRO CAMPGROUND	Nitrogen (NOX)	NITRATE	No
CO0260161	LOST BURRO CAMPGROUND	Revised Total Coliform (RTCR)	E. COLI	Yes



CO0326487	LOTTIS CREEK CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0118035	LOUVIERS WSD	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0118035	LOUVIERS WSD	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0210016	LOVELAND VALLEY SKI AREA	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0238100	LUS BUFFALO STOP	Disinfection (DIS)	CHLORINE	Yes
CO0107496	LYONS TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0107496	LYONS TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0247500	M LAZY C RANCH	Disinfection (DIS)	CHLORINE	Yes
CO0247500	M LAZY C RANCH	Nitrogen (NOX)	NITRATE	No
CO0247500	M LAZY C RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0253390	MALT SHOPPE THE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0145450	MANZANOLA TOWN OF	Radionuclides (RADs)	COMBINED URANIUM	No
CO0145450	MANZANOLA TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0107502	MAPLE GROVE WD	Disinfection (DIS)	CHLORINE	Yes
CO0349502	MAROON LAKE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0253540	MASONIC PARK ASSOCIATION	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0333505	MAY QUEEN CG	Sanitary Survey (SS)	GROUNDWATER RULE	No



CO0150800	MAY VALLEY WA	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0150800	MAY VALLEY WA	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0241517	MAYBELL GENERAL STORE	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0241517	MAYBELL GENERAL STORE	Disinfection (DIS)	CHLORINE	No
CO0207500	MCDONALD FARMS ENTERPRISES INC	Water Hauler (Hauler)	WATER HAULER RULE	Yes
CO0138025	MERINO TOWN OF	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0138025	MERINO TOWN OF	Radionuclides (RADs)	COMBINED URANIUM	No
CO0239505	MESA LAKES LODGE AND RESORT	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0210017	MILL CREEK WIA	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0210017	MILL CREEK WIA	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0143510	MILLARDS MANAGEMENT LLC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0119510	MINTURN TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0119510	MINTURN TOWN OF	Surface Water (SW)	TURBIDITY	No
CO0123510	MITCHELL COOPER DITCH PIPELINE	Surface Water (SW)	SWTR	No
CO0211300	MOGOTE MEADOW	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0154518	MORRISON CREEK METRO DISTRICT	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0151350	MOUNTAIN SHADOWS MOBILE ESTATES	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No



CO0215516	MOUNTAIN VALLEY MEADOWS RV PARK	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0240500	MOUNTAIN VIEW AT RIVERS EDGE RV	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0133500	MT ELBERT WA	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0130090	MT VERNON COUNTRY CLUB	Disinfection (DIS)	CHLORINE	No
CO0143533	NATURITA TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0204900	NAVAJO STATE PARK	Disinfection (DIS)	CHLORINE	No
CO0162666	NEW RAYMER TOWN OF	Disinfection (DIS)	CHLORINE	No
CO0262546	NGL WATER SOLUTIONS DJ C6	Disinfection (DIS)	GROUNDWATER RULE	Yes
CO0145630	NORTH HOLBROOK WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0143559	NUCLA TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0262177	OLSONS GREENHOUSE	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0151400	ONEAL WS	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0151400	ONEAL WS	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0151400	ONEAL WS	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0161010	OTIS TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0144025	PAGELS TP	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0144025	PAGELS TP	Sanitary Survey (SS)	GROUNDWATER RULE	No



CO0144025	PAGELS TP	Disinfection (DIS)	CHLORINE	Yes
CO0144025	PAGELS TP	Radionuclides (RADs)	COMBINED URANIUM	No
CO0121550	PALMER LAKE MOBILE HOME RANCH	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0121550	PALMER LAKE MOBILE HOME RANCH	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0123601	PANORAMIC MESA SUBD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0143600	PARADOX PIPELINE CO	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0122600	PARK CENTER WD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0145540	PATTERSON VALLEY WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145540	PATTERSON VALLEY WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0335600	PAWNEE CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0335605	PEACEFUL VALLEY CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0259012	PEAK 8 VILLAGE CONDOS	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0160095	PEAK VIEW PARK LLC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0160095	PEAK VIEW PARK LLC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0138030	PEETZ TOWN OF	Inorganics (IOCs)	ARSENIC	No
CO0122700	PENROSE WD	Disinfection (DIS)	CHLORINE	Yes
CO0154609	PHIPPSBURG TOWN OF	Disinfection (DIS)	CHLORINE	Yes



CO0154609	PHIPPSBURG TOWN OF	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0218040	PINE TREE PLAZA WEST	Disinfection (DIS)	CHLORINE	Yes
CO0235183	PINGREE PARK PALMER CENTER	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0136610	PINON WSD	Disinfection (DIS)	CHLORINE	Yes
CO0115610	PITKIN MESA PIPELINE CO	Surface Water (SW)	TURBIDITY	Yes
CO0115610	PITKIN MESA PIPELINE CO	Surface Water (SW)	SWTR	Yes
CO0115610	PITKIN MESA PIPELINE CO	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0153800	PONDEROSA SUBDIVISION	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0221740	POP A TOP SALOON	Disinfection (DIS)	CHLORINE	Yes
CO0262622	PRAIRIE ELEM AT NEW RAYMER	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	Yes
CO0262622	PRAIRIE ELEM AT NEW RAYMER	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0144621	PRAIRIE VIEW RANCH WD	Disinfection (DIS)	CHLORINE	Yes
CO0226620	QUARTZ CREEK PROPERTY OWNERS ASSOCIATION	Disinfection (DIS)	SWTR	No
CO0226620	QUARTZ CREEK PROPERTY OWNERS ASSOCIATION	Surface Water (SW)	SWTR	No
CO0226620	QUARTZ CREEK PROPERTY OWNERS ASSOCIATION	Disinfection (DIS)	CHLORINE	No
CO0126668	RAINBOW PIPELINE PLACER SUBDIV	Disinfection (DIS)	GROUNDWATER RULE	No



CO0126668	RAINBOW PIPELINE PLACER SUBDIV	Disinfection (DIS)	CHLORINE	No
CO0126668	RAINBOW PIPELINE PLACER SUBDIV	Revised Total Coliform (RTCR)	E. COLI	No
CO0211700	RAINBOW TROUT RANCH	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0160375	RAINBOW VALLEY WD	Surface Water (SW)	TURBIDITY	Yes
CO0202666	RAKHRA MUSHROOM FARM	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0202666	RAKHRA MUSHROOM FARM	Disinfection (DIS)	CHLORINE	No
CO0202666	RAKHRA MUSHROOM FARM	Inorganics (IOCs)	ARSENIC	No
CO0230310	RAMAH IN THE ROCKIES	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0230310	RAMAH IN THE ROCKIES	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0121675	RAMAH TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0235666	RAVENCREST CHALET	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0121700	RED ROCK VALLEY WD	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0119673	RED SKY RANCH	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0253860	RIO GRANDE WATER CO LLC	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0145570	RIVERSIDE WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0235676	RIVERVIEW CG	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0235676	RIVERVIEW CG	Disinfection (DIS)	CHLORINE	Yes



CO0143676	RIVERWOOD SUBD WC	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0143676	RIVERWOOD SUBD WC	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0253690	RIVIERE ESTATES	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0234684	ROADHOUSE MARKET	Disinfection (DIS)	GROUNDWATER RULE	No
CO0235686	ROCKY RIDGE MUSIC CENTER	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0262684	ROGGEN MOTEL	Disinfection (DIS)	CHLORINE	Yes
CO0262684	ROGGEN MOTEL	Nitrogen (NOX)	NITRATE	No
CO0103081	ROLLING PLAINS ESTATE	Disinfection (DIS)	CHLORINE	No
CO0326685	ROSY LANE CG	Disinfection (DIS)	CHLORINE	No
CO0219685	ROUNDUP RIVER RANCH	Disinfection (DIS)	SWTR	Yes
CO0151700	RYE TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0151700	RYE TOWN OF	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0151700	RYE TOWN OF	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0151700	RYE TOWN OF	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	Yes
CO0151700	RYE TOWN OF	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0112850	SAN ACACIO DOMESTIC WA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0107701	SAN LAZARO MFCTD HOUSING COMMUNITY	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0153701	SAN LUIS VALLEY RESEARCH CENTER	Disinfection (DIS)	CHLORINE	No



CO0107702	SAN SOUCI MHP	Lead and Copper (LCR)	LEAD & COPPER RULE	No
CO0255700	SAND DUNES SWIMMING POOL AND RV PARK	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0132015	SEIBERT TOWN OF	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0208808	SHAVANO TRUCK STOP	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0131800	SHERIDAN LAKE WC	Radionuclides (RADs)	COMBINED URANIUM	No
CO0251743	SIGNAL MOUNTAIN RANCH PROPERTY OWNERS WC	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0251743	SIGNAL MOUNTAIN RANCH PROPERTY OWNERS WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0251743	SIGNAL MOUNTAIN RANCH PROPERTY OWNERS WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0326710	SILVER JACK CG	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0226709	SILVER PLUME GENERAL STORE THE	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes
CO0120025	SIMLA TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0259018	SOLITUDE STATION COPPER MOUNTAIN	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0126715	SOMERSET DOMESTIC WD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0204925	SONLIGHT ADVENTURES INC	Disinfection (DIS)	CHLORINE	Yes
CO0153718	SOUTH FORK HEIGHTS APARTMENTS	Lead and Copper (LCR)	LEAD & COPPER RULE	No



CO0130718	SOUTH SHERIDAN WATER AND SEWER DIST	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0145690	SOUTH SWINK WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145690	SOUTH SWINK WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0202875	SPLASHLAND LLC	Disinfection (DIS)	CHLORINE	No
CO0208815	SPRING CANYON CAMP AND CC	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0107719	SPRING VALLEY MUTUAL WA	Lead and Copper (LCR)	LEAD & COPPER RULE	No
CO0253840	SPRUCE LODGE	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0218029	SPRUCEWOOD INN	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0151750	ST CHARLES MESA WD	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0110040	ST MARYS GLACIER WSD	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0136724	STARKVILLE TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0254842	STEAMBOAT MOUNTAIN SCHOOL	Surface Water (SW)	TURBIDITY	Yes
CO0138045	STERLING CITY OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0207724	STONE MOUNTAIN LODGE AND CABINS	Surface Water (SW)	TURBIDITY	Yes
CO0207724	STONE MOUNTAIN LODGE AND CABINS	Disinfection (DIS)	CHLORINE	Yes
CO0132020	STRATTON TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0132020	STRATTON TOWN OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0132020	STRATTON TOWN OF	Sanitary Survey (SS)	GROUNDWATER RULE	No



CO0115726	STUCKER MESA DOMESTIC WC	Surface Water (SW)	IESWTR	Yes
CO0143515	SUBURBAN WATER	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0143515	SUBURBAN WATER	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0113900	SUGAR CITY TOWN OF	Disinfection (DIS)	CHLORINE	Yes
CO0233850	SUGAR LOAFIN RV CAMPGROUND	Operator Certification (Op Cert)		No
CO0123500	SUN MEADOW ESTATES	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0123500	SUN MEADOW ESTATES	Radionuclides (RADs)	COMBINED URANIUM	No
CO0235726	SUNDANCE TRAIL GUEST RANCH	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0235726	SUNDANCE TRAIL GUEST RANCH	Disinfection (DIS)	CHLORINE	No
CO0223725	SUNLIGHT MOUNTAIN INN	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0123725	SUNLIGHT VIEW WWW COMPANY	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0138725	SUNNYSLOPE HOMEOWNERS	Disinfection (DIS)	CHLORINE	Yes
CO0239725	SUNSET LAKE SUMMER HOME OWNERS	Surface Water (SW)	TURBIDITY	Yes
CO0239725	SUNSET LAKE SUMMER HOME OWNERS	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	No
CO0262735	TAGAWA GREENHOUSES INC	Nitrogen (NOX)	NITRATE	No
CO0204733	TARA MANDALA	Disinfection (DIS)	CHLORINE	Yes
CO0157900	TELLURIDE PINES HOA	Surface Water (SW)	TURBIDITY	Yes
CO0157900	TELLURIDE PINES HOA	Surface Water (SW)	IESWTR	Yes



CO0157900	TELLURIDE PINES HOA	Lead and Copper (LCR)	LEAD & COPPER RULE	No
CO0247288	THE CORONAS AT FRESHWATER	Nitrogen (NOX)	NITRATE	No
CO0118078	THUNDERBIRD WSD	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0223755	TRAPPERS LAKE LODGE	Disinfection (DIS)	CHLORINE	Yes
CO0128726	TRES VALLES WEST	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0333790	TURQUOISE LAKE REC AREA	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0333790	TURQUOISE LAKE REC AREA	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0134855	TWILIGHT WC	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0333795	TWIN PEAKS CG PARRY PEAK CG	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0210014	TWO BEARS GRILL	Disinfection (DIS)	CHLORINE	No
CO0234785	UES VENTURES	Disinfection (DIS)	CHLORINE	No
CO0138785	UPPER HIGHLAND HOA	Disinfection (DIS)	CHLORINE	No
CO0115784	UPPER SURFACE CREEK DOMESTIC WUA	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	Yes
CO0121845	US AIR FORCE ACADEMY	Disinfection (DIS)	CHLORINE	No
CO0121845	US AIR FORCE ACADEMY	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0211790	USFS BLM OFFICE LA JARA	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0134790	UTE PASS WA INC	Disinfection (DIS)	CHLORINE	No
CO0234880	VALLECITO RESORT	Revised Total Coliform (RTCR)	REVISED TOTAL COLIFORM RULE (RTCR)	Yes



CO0255850	VALLEY VIEW HOT SPRINGS	Disinfection (DIS)	CHLORINE	Yes
CO0145750	VALLEY WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145750	VALLEY WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0105800	VILAS TOWN OF	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	Yes
CO0255680	VILLA GROVE TRADE	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0107810	VISTA VILLAGE MHP	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0145780	VROMAN WC	Radionuclides (RADs)	GROSS ALPHA, EXCL. RADON & U	No
CO0145780	VROMAN WC	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0201051	WAGON WHEEL SKATING RINK	Nitrogen (NOX)	NITRATE	Yes
CO0128900	WALSENBURG CITY OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0128900	WALSENBURG CITY OF	Surface Water (SW)	SWTR	No
CO0128900	WALSENBURG CITY OF	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0128900	WALSENBURG CITY OF	Disinfection (DIS)	CHLORINE	No
CO0105900	WALSH TOWN OF	Sanitary Survey (SS)	GROUNDWATER RULE	Yes
CO0105900	WALSH TOWN OF	Nitrogen (NOX)	NITRATE	No
CO0135838	WELLINGTON TOWN OF	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0145810	WEST GRAND VALLEY WA	Disinfection (DIS)	CHLORINE	No
CO0149613	WEST RANCH SUBD	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No



CO0160750	WESTWOOD LAKES WD	Lead and Copper (LCR)	LEAD & COPPER RULE	Yes
CO0333890	WHITE STAR HOST SITE	Sanitary Survey (SS)	GROUNDWATER RULE	No
CO0230067	WINDY PEAKS OUTDOOR LABORATORY	Surface Water (SW)	TURBIDITY	No
CO0225840	WINTER PARK RESORT LUNCH ROCK	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0225846	WINTER PARK RESORT SUNSPOT	Storage Tanks (Tanks)	STORAGE TANK RULE	No
CO0260975	WISHING WELL MOTEL	Surface Water (SW)	SWTR	No
CO0260975	WISHING WELL MOTEL	Radionuclides (RADs)	COMBINED RADIUM (-226 & -228)	No
CO0240850	WOLF CREEK SKI CORP	Disinfection (DIS)	SWTR	No
CO0227852	WOODLAKE PARK	Operator Certification (Op Cert)	DBP STAGE 1	Yes
CO0261003	WOODLIN SCHOOL	Cross Connection Control (CCX)	CROSS CONNECTION RULE	No
CO0261003	WOODLIN SCHOOL	Operator Certification (Op Cert)	DBP STAGE 1	No
CO0261003	WOODLIN SCHOOL	Disinfection (DIS)	CHLORINE	Yes
CO0163010	WRAY CITY OF	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0135883	YMCA ROCKIES WIND RIVER	Cross Connection Control (CCX)	CROSS CONNECTION RULE	Yes
CO0135883	YMCA ROCKIES WIND RIVER	Surface Water (SW)	TURBIDITY	Yes
CO0135883	YMCA ROCKIES WIND RIVER	TTHM and HAA5 (DBP - TTHM and HAA5)	TOTAL HALOACETIC ACIDS (HAA5)	No
CO0225918	YOUNG LIFE CROOKED CREEK	Storage Tanks (Tanks)	STORAGE TANK RULE	Yes
CO0224917	YOUTH WITH A MISSION EAGLE ROCK	Storage Tanks (Tanks)	STORAGE TANK RULE	No



