



COLORADO

Department of Public
Health & Environment

Dedicated to protecting and improving the health and environment of the people of Colorado

COLORADO SAFE DRINKING WATER PROGRAM CALENDAR YEAR 2024 ANNUAL COMPLIANCE REPORT

This report provides an overview for Colorado for the previous year. For current water system information please visit our [consumer information website](#). Please [contact us with any accessibility issues](#).

Introduction.....	3
Definitions.....	4
National Primary Drinking Water Regulations.....	5
Violations.....	7
Table 1. Number of PWSs by system type and population group.....	7
Table 2. Summary violations by rule and violation type.....	8
Table 3. Summary of inorganic chemicals violations.....	10
Table 4. Summary of nitrogen compounds violations.....	11
Table 5. Summary of radionuclide violations.....	11
Table 6. Summary of synthetic organic chemical violations.....	12
Table 7. Summary of volatile organic chemical violations.....	14
Table 8. Summary of the Consumer Confidence Report Rule violations.....	15
Table 9. Summary of Cross Connection Control and Backflow Prevention violations..	16
Table 10. Summary of disinfection violations.....	17
Table 11. Summary of chlorite and bromate violations.....	18
Table 12. Summary of total trihalomethanes and haloacetic acids.....	19
Table 13. Summary of the Groundwater Rule violations.....	20
Table 14. Summary of Lead and Copper Rule violations.....	21
Table 15. Summary of notification, record Keeping, and monitoring plan violations.	23
Table 16. Summary of Operator Certification Rule violations.....	24
Table 17. Summary of plans and specifications violations.....	24
Table 18. Summary of the Public Notice Rule violations.....	25
Table 19. Summary of the Revised Total Coliform Rule violations.....	26
Table 20. Summary of the Sanitary Survey Rule violations.....	28
Table 21. Summary of the Storage Tank Rule violations.....	28
Table 22. Summary of the Surface Water Treatment Rule violations.....	29
Table 23. Summary of the Surface Water Precursors violations.....	30
Table 25. Summary of the Water Hauler Rule violations.....	31
Exemptions, Variances, and Waivers.....	31
Report Availability and Contact Information.....	31
Appendix A: PWSs with Health-Based Violations.....	32



Introduction

The United States Environmental Protection Agency (EPA) established the Public Water System Supervision (PWSS) Program under the authority of the 1974 Safe Drinking Water Act (SDWA). Under the SDWA and the 1986 Amendments, EPA sets national limits on contaminant levels in drinking water to ensure that the water is safe for human consumption. These limits are known as Maximum Contaminant Levels (MCLs) or Action Levels (ALs). For some regulations, EPA establishes treatment techniques (TTs) instead of MCLs.

EPA also sets standards on how often public water systems (PWSs) monitor their water for contaminants and report the sample results. Generally, the larger the population served by a water system, the more frequent the monitoring and reporting (M&R) requirements. In addition, EPA selects individual PWSs to monitor for unregulated contaminants to provide data for future regulatory development.

The 1996 Amendments to the SDWA require public notification to include a clear and understandable explanation of the nature of each violation, its potential adverse health effects, steps that the PWS is undertaking to correct the violation, and the possibility of alternative water supplies during the violation.

The Colorado Department of Public Health and Environment's (CDPHE) Safe Drinking Water Program (SDWP) implements the SDWA, with amendments, pursuant to the Colorado Primary Drinking Water Regulations (Regulation 11) for the State of Colorado.

The Annual Compliance Report (ACR) is intended to provide a total annual representation of the number of violations. Violations fall into one of two categories:

1. Health-Based (HB).
2. Non-Health-Based (NHB).

This report was prepared to meet the EPA's reporting requirements and is updated on a yearly basis. For current information please visit <https://cdphe.colorado.gov/dwinfo>.



Definitions

- **Public Water System (PWS):** An entity that provides water via piping or other constructed conveyances for human consumption to at least 15 service connections or serves an average of at least 25 people for at least 60 days each year. There are three types of PWSs:
 - Community (e.g., cities or towns).
 - Non-Transient, Non-Community (e.g., schools or factories).
 - Transient, Non-Community systems (e.g., restaurants, rest stops, or parks).
- **Health-Based (HB):** Potential short-term or long-term health risks.
 - **Maximum Contaminant Level (MCL):** The highest level of a contaminant allowed in drinking water. Note: Under the Lead and Copper Rule, MCLs were not established. For this rule, “action levels” rather than MCLs define the levels at which a public water system must take action to reduce the concentration of lead and/or copper.
 - **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant (added for the treatment of water) allowed in drinking water. MRDLs are enforceable in the same manner as MCLs.
 - **Treatment Techniques (TT):** Unacceptable levels, in lieu of a MCL, for selected water characteristics or a failure to correct an identified issue. Turbidity, for example, measures the cloudiness of water. If the water is too cloudy, the department can issue a TT violation.
- **Non-Health-Based (NHB):** No health risks or health risks are unknown. Some violations that are NHB include:
 - **Monitoring and Reporting (M&R):** To monitor, test, and report for water characteristics (e.g., contaminants) present in drinking water. All minor and major violations are included.
 - **Public Notice (PN):** A requirement for the PWS to notify their customers of any and all violations. PN requirements take into account the seriousness of the violation (or situation) and any potential adverse health effects that may be involved.
- **Variance:** A departure from a primary drinking water regulation if the characteristics of the raw water sources available to the PWS do not allow the system to meet the MCL.
- **Exemption:** Temporarily relieves a PWS of its obligation to comply with an MCL, TT, or both, due to compelling factors (which may include economic factors).



National Primary Drinking Water Regulations

The Safe Drinking Water Act (SDWA) is the federal law that regulates the quality of drinking water. The SDWA sets standards for drinking water quality and stipulates the monitoring requirements for PWSs. The following regulations have been promulgated under the Colorado Primary Drinking Water Regulations (Regulation 11):

- Chemical Phase Rule: Provides public health protection through the reduction of chronic risk (e.g., cancer, organ damage, etc.) from the exposure of:
 - Inorganic Chemicals (IOCs).
 - Nitrate and Nitrite (NOX).
 - Synthetic Organic Chemicals (SOCs).
 - Volatile Organic Chemicals (VOCs).
 - Radionuclides (RADs).
- Consumer Confidence Rule (CCR): A drinking water quality report that PWSs distribute to their customers by July 1 each year. The report contains information regarding sources used (i.e., rivers, lakes, reservoirs, etc.), detected contaminants, violations, and educational information.
- Cross-Connection Control Rule (CCX): Requires PWSs to inspect their system for cross-connections and backflow prevention devices.
- Microbial, Disinfection, and Disinfection Byproducts (MICRO, DIS, and DBPs): In general, drinking water must be disinfected to inactivate microbial pathogens (e.g., E. coli, salmonella, etc.). To protect against potential microbial contamination, PWSs add disinfectants such as chlorine. However, disinfectants can react with naturally occurring material in the source water and form byproducts which may cause health risks. PWSs must carefully maintain a balance between addressing potential microbial contamination and byproduct formation. The following rules address this issue:
 - Groundwater Rule (GWR): The purpose of the GWR is to provide increased protection against microbial pathogens in PWSs that use groundwater sources.
 - Disinfection (DIS): The purpose of these rules is to provide protection against microbial contamination.
 - Disinfection Byproduct Rules (DBPs): The purpose of these rules is to reduce public exposure to disinfection byproducts, which can form when disinfectants interact with naturally-occurring organic material in water.
 - Surface Water Treatment Rules (SWTRs): The purpose of the SWTRs is to prevent waterborne diseases caused by viruses, Giardia, and Cryptosporidium. The rules require surface water systems to filter and disinfect their water to reduce microbial contamination.
 - Surface Water Precursors: PWSs with specific filtration types are required to monitor for total organic carbon removal in order to minimize disinfection byproducts from forming.
 - Revised Total Coliform Rule (RTCR): The purpose of this rule is to reduce bacterial contamination in drinking water distribution systems.
- Lead and Copper Rule (LCR): Protects public health by minimizing the public's exposure to lead and copper.



- Notification, Record Keeping, and Monitoring Plan (Notification): Requires PWSs to notify the state of any drinking water violations or situations that may pose an adverse health risk, retain records, and have a monitoring plan.
- Operator Certification Rule: Requires PWSs to have a certified operator.
- Plans and Specifications (P&S): Requires PWSs to get approval before making physical modifications to the water system.
- Public Notice Rule (PN): Requires PWSs to notify their customers of any drinking water violations or situations that may pose an adverse health risk.
- Sanitary Survey (SS): Requires PWSs to correct deficiencies found during an inspection.
- Storage Tanks (Tanks): Requires PWSs to inspect finished water storage tanks and fix any issues identified.
- Water Hauler Rule (Hauler): Requires PWSs that haul water to meet special requirements.



Violations

Overview

The number of PWSs in the state changes on a daily basis. This is due to seasonal operations, new PWSs opening, existing PWSs closing, and changes to the population being served. Table 1 displays a typical number of systems, on any one day, by population and system type.

Table 1. Number of PWSs by system type and population group

Population	Community Systems	Transient, Non-Community Systems	Non-Transient, Non-Community Systems	Total
25-500	629	878	145	1,652
501-3,300	247	80	28	355
3,301-10,000	79	4	3	86
10,001-100,000	82	0	0	82
>100,000	14	0	0	14
Total	1,051	962	176	2,189

Violations are based on data compiled in April 2025 from Colorado's production SDWIS/State database. If a violation: (1) was unresolved as of January 1, 2024; or (2) occurred in calendar year 2024, we included it in this report. M&R violations for PWSs sampling less frequently than annually are reported in the third, sixth, or ninth year of a compliance cycle. Calendar year 2024 was the second year in a compliance cycle.

Appendix A identifies the public water systems that violated maximum contaminant levels and/or treatment technique requirements. The final column shows if the violation was resolved.

Summary of All Violations

Table 2 summarizes the number of violations and the number of systems with violations for each drinking water rule and violation type. The subsequent tables provide further details for each of the drinking water rules.

Table 2. Summary violations by rule and violation type

Rule	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
Chlorite and Bromate (DBP - Other) Totals:	-	-	10	3
Consumer Confidence (CCR) Totals:	-	-	98	80
Cross Connection Control (CCX) Totals:	124	97	279	179
Disinfection (DIS) Totals:	92	61	673	366
Ground Water (GW) Totals:	1	1	35	32
Inorganics (IOCs) Totals:	13	4	124	15
Lead and Copper (LCR) Totals:	44	42	200	143
Nitrogen (NOX) Totals:	28	14	105	83
Notification, Record Keeping, and Monitoring Plan (Notification) Totals:	-	-	124	111
Operator Certification (Op Cert) Totals:	52	52	-	-
Plans and Specifications (P&S) Totals:	-	-	60	59
Precursors (Precursors) Totals:	4	1	31	6

Rule	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
Public Notice (PN) Totals:	-	-	704	335
Radionuclides (RADs) Totals:	1,197	32	113	31
Revised Total Coliform (RTCR) Totals:	43	40	283	196
Sanitary Survey (SS) Totals:	74	44	-	-
Storage Tanks (Tanks) Totals:	76	58	39	37
Surface Water (SW) Totals:	97	43	189	108
Synthetic Organics (SOCs) Totals:	-	-	160	14
TTHM and HAA5 (DBP - TTHM and HAA5) Totals:	98	21	173	85
Volatile Organics (VOCs) Totals:	-	-	534	31
Water Hauler (Hauler) Totals:	2	2	2	2
Total:	1,945	365	3,936	880



Inorganic Chemical Violations (not including Nitrogen Compounds and Radionuclides)

Only Community and Non-Transient, Non-Community PWSs are required to comply with these requirements.

Table 3. Summary of inorganic chemicals violations

Contaminant Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
Antimony, Total	-	-	10	9
Arsenic	7	2	11	10
Barium	-	-	10	9
Beryllium, Total	-	-	10	9
Cadmium	6	2	12	11
Chromium	-	-	10	9
Fluoride	-	-	10	9
Mercury	-	-	10	9
Nickel	-	-	10	9
Selenium	-	-	11	10
Sodium	-	-	10	9
Thallium, Total	-	-	10	9
Inorganics (IOCs) Totals:	13	4	124	15



Nitrogen Compound Violations

All PWSs are required to comply with these requirements.

Table 4. Summary of nitrogen compounds violations

Contaminant Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
Nitrate	27	13	97	81
Nitrite	1	1	8	6
Nitrogen (NOX) Totals:	28	14	105	83

Radionuclide Violations

Only Community PWSs are required to comply with these requirements.

Table 5. Summary of radionuclide violations

Contaminant Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
Combined Radium (-226 & -228)	839	26	47	25
Combined Uranium	14	2	32	19
Gross Alpha, Excl. Radon & Uranium	344	15	34	20
Radionuclides (RADs) Totals:	1197	32	113	31



Synthetic Organic Chemical Violations

Only Community and Non-Transient, Non-Community PWSs are required to comply with these requirements.

Table 6. Summary of synthetic organic chemical violations

Contaminant Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
1,2-Dibromo-3-Chloropropane	-	-	6	5
2,4,5-Tp	-	-	5	4
2,4-D	-	-	6	5
Aldicarb	-	-	1	1
Aldicarb Sulfone	-	-	1	1
Aldicarb Sulfoxide	-	-	1	1
Atrazine	-	-	5	4
Benzo(A)Pyrene	-	-	5	4
Bhc-Gamma	-	-	6	5
Carbofuran	-	-	5	4
Chlordane	-	-	6	5
Dalapon	-	-	7	6
Di(2-Ethylhexyl) Adipate	-	-	5	4
Di(2-Ethylhexyl) Phthalate	-	-	11	8
Dinoseb	-	-	5	4
Diquat	-	-	5	4
Endothall	-	-	5	4
Endrin	-	-	5	4



Contaminant Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
Ethylene Dibromide	-	-	6	5
Glyphosate	-	-	2	1
Heptachlor	-	-	5	4
Heptachlor Epoxide	-	-	5	4
Hexachlorobenzene	-	-	5	4
Hexachlorocyclopentadiene	-	-	5	4
Lasso	-	-	5	4
Methoxychlor	-	-	5	4
Oxamyl	-	-	5	4
Pentachlorophenol	-	-	5	4
Picloram	-	-	5	4
Simazine	-	-	5	4
Total Polychlorinated Biphenyls (PCB)	-	-	6	5
Toxaphene	-	-	6	5
Synthetic Organics (SOCs) Totals:	-	-	160	14



Volatile Organic Chemical Violations

Only Community and Non-Transient, Non-Community PWSs are required to comply with these requirements.

Table 7. Summary of volatile organic chemical violations

Contaminant Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
1,1,1-Trichloroethane	-	-	25	24
1,1,2-Trichloroethane	-	-	25	24
1,1-Dichloroethylene	-	-	25	24
1,2,4-Trichlorobenzene	-	-	25	24
1,2-Dichloroethane	-	-	25	24
1,2-Dichloropropane	-	-	25	24
Benzene	-	-	25	24
Carbon Tetrachloride	-	-	26	25
Chlorobenzene	-	-	25	24
Cis-1,2-Dichloroethylene	-	-	25	24
Dichloromethane	-	-	26	24
Ethylbenzene	-	-	26	25
O-Dichlorobenzene	-	-	25	24
P-Dichlorobenzene	-	-	25	24
Styrene	-	-	25	24
Tetrachloroethylene	-	-	25	24
Toluene	-	-	27	26
Trans-1,2-Dichloroethylene	-	-	25	24



Contaminant Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
Trichloroethylene	-	-	25	24
Vinyl Chloride	-	-	25	24
Xylenes, Total	-	-	29	28
Volatile Organics (Vocs) Totals:	-	-	534	31

Consumer Confidence Report (CCR) Rule Violations

Only Community PWSs are required to comply with these requirements.

Table 8. Summary of the Consumer Confidence Report Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
71 - CCR Report - Consumer Confidence Rule	-	-	98	80
Consumer Confidence (CCR) Totals:	-	-	98	80



Cross Connection Control and Backflow Prevention Rule Violations

All PWSs are required to comply with these requirements.

Table 9. Summary of Cross Connection Control and Backflow Prevention violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
ML - State Treatment Technique Level - Cross Connection Rule	124	97	-	-
MS - State Monitoring - Cross Connection Rule	-	-	279	179
Cross Connection Control (CCX) Totals:	124	97	279	179



Disinfection Violations

All PWSs are required to comply with these requirements.

Table 10. Summary of disinfection violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
41 - Res Disinfect Concentration (SWTR) - Chlorine	37	18	-	-
41 - Res Disinfect Concentration (SWTR) - Chlorine	1	1	-	-
MD - Failure Provide Disinfect. Treatment GW - Chlorine	12	12	-	-
MD - Failure Provide Disinfect. Treatment Gw - Chlorine	6	6	-	-
ML - State Treatment Technique Level - Chlorine	36	26	-	-
27 - Monitoring, (DBP) (Chl. Dioxide) - Chlorine Dioxide	-	-	11	4
27 - Monitoring, Routine (DBP), Major - Chloramine	-	-	5	5
27 - Monitoring, Routine (DBP), Major - Chloramine	-	-	128	91
36 - Monitoring, Rtn/Rpt Major (SWTR-Filter) - Chloramine	-	-	8	8
36 - Monitoring, Rtn/Rpt Major	-	-	194	130



Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
(SWTR-Filter) - Chloramine				
MS- State Monitoring - Chlorine	-	-	272	202
VC - Equipment Verification Or Calibration - Chlorine	-	-	55	55
Disinfection (DIS) Totals:	92	61	673	366

Chlorite and Bromate Rule Violations

Only PWSs using chlorine dioxide or ozone are required to comply with these requirements.

Table 11. Summary of chlorite and bromate violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
27 - Monitoring, Routine (DBP), Major - Chlorite	-	-	10	3
Chlorite And Bromate (DBP - Other) Totals:	-	-	10	3

Total Trihalomethanes and Haloacetic Acids Rule Violations

Community and Non-Transient, Non-Community PWSs are required to comply.

Table 12. Summary of total trihalomethanes and haloacetic acids

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
02 - MCL, LRAA - Total Haloacetic Acids (HAA5)	48	9	-	-
02 - MCL, LRAA - TTHM	50	14	-	-
27 - Monitoring, Routine (DBP), Major - Total Haloacetic Acids (HAA5)	-	-	81	75
27 - Monitoring, Routine (DBP), Major - TTHM	-	-	80	75
35 - Failure Submit Idse/Subpt V Plan (DBPR2) - DBP Stage 2	-	-	6	6
35 - Failure Submit OEL Report for HAA5 - Total Haloacetic Acids (HAA5)	-	-	1	1
35 - Failure Submit OEL Report For TTHM - TTHM	-	-	4	3
35 - Failure Submit Subpart V Plan, Escalated - DBP Stage 2	-	-	1	1
TTHM And HAA5 (DBP - TTHM And HAA5) Totals:	98	21	173	85



Groundwater Rule Violations

PWSs with a groundwater source not treated to surface water standards are required to comply with these requirements.

Table 13. Summary of the Groundwater Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
48 - Failure To Address Contamination (GWR) - Groundwater Rule	1	1	-	-
19 - Monitoring, (GWR), Assessment, Major - E. Coli	-	-	1	1
34 - Monitor GWR Triggered/Additional, Major - E. Coli	-	-	34	31
Ground Water (GW) Totals:	1	1	35	32



Lead and Copper Rule Violations

Only Community and Non-Transient, Non-Community PWSs are required to comply with these requirements.

Table 14. Summary of Lead and Copper Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
2E - LSL Inventory-Initial - Lead And Copper Rule Revisions	27	27	-	-
57 - OCCT/SOWT Recommendation/Stu dy (LCR) - Lead & Copper Rule	3	3	-	-
58 - OCCT/SOWT Install Demonstration (LCR) - Lead & Copper Rule	4	4	-	-
59 - WQP Level Non-Compliance (LCR) - Lead & Copper Rule	8	6	-	-
65 - Public Education (LCR) - Lead & Copper Rule	2	2	-	-
4G - LSL Reporting-Initial - Lead And Copper Rule Revisions	-	-	37	37
51 - Initial Tap Sampling (LCR) - Lead & Copper Rule	-	-	9	8
52 - Follow-Up Or Routine Tap M/R (LCR) - Lead & Copper Rule	-	-	63	56



Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
53 - Water Quality Parameter M/R (LCR) - Lead & Copper Rule	-	-	9	9
56 - Initial/Follow-Up/Routine SOWT M/R (LCR) - Lead & Copper Rule	-	-	1	1
66 - Lead Consumer Notice (LCR) - Lead & Copper Rule	-	-	74	59
MS - State Monitoring - Lead & Copper Rule	-	-	7	7
Lead And Copper (LCR) Totals:	44	42	200	143



Notification, Record Keeping, and Monitoring Plan Violations

All PWSs are required to comply with these requirements.

Table 15. Summary of notification, record Keeping, and monitoring plan violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
09 - Record Keeping, Without Rule Code - N/A	-	-	23	23
32 - Failure To Have Monitoring Plan (LT2) - LT2EWTR	-	-	1	1
5A - Sample Siting Plan Errors (RTCR) - Revised Total Coliform Rule (RTCR)	-	-	91	89
MS - State Monitoring - Monitoring Plan Rule	-	-	9	9
Notification, Record Keeping, And Monitoring Plan (Notification) Totals:	-	-	124	111



Operator Certification Rule Violations

All PWSs are required to comply with these requirements.

Table 16. Summary of Operator Certification Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
12 - Qualified Operator Failure - DBP Stage 1	26	26	-	-
OC - Qualified Operator Failure - Transient - DBP Stage 1	26	26	-	-
Operator Certification (Op Cert) Totals:	52	52	-	-

Plans and Specification Violations

All PWSs are required to comply with these requirements.

Table 17. Summary of plans and specifications violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
MS - State Monitoring - Plans And Specifications Rule	-	-	60	59
Plans And Specifications (P&S) Totals:	-	-	60	59



Public Notice Rule Violations

All PWSs that incurred a violation or posed an adverse health risk are required to comply with these requirements.

Table 18. Summary of the Public Notice Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
75 - Public Notice Rule Linked To Violation - Public Notice	-	-	317	169
76 - Public Notice Rule Not Linked Violation - Public Notice	-	-	387	216
Public Notice (PN) Totals:	-	-	704	335



Revised Total Coliform Rule (Microbial) Violations

All PWSs are required to comply with these requirements.

Table 19. Summary of the Revised Total Coliform Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
1A - MCL, E. Coli, Pos E. Coli (RTCR) - E. Coli	1	1	-	-
2A - Level 1 Assess, Multiple TC POS (RTCR) - Revised Total Coliform Rule (RTCR)	5	5	-	-
2A - Level 1 Assess, TC POS RT no RPT (RTCR) - Revised Total Coliform Rule (RTCR)	3	3	-	-
2C - Corrective/Expedited Actions (RTCR) - Revised Total Coliform Rule (RTCR)	5	2	-	-
2D- Startup Procedures TT (RTCR) - Revised Total Coliform Rule (RTCR)	29	29	-	-
3A - Monitoring, Routine, Major (RTCR) - E. Coli	-	-	208	145
3A - Monitoring, Routine, Major (RTCR) - Revised Total Coliform Rule (RTCR)	-	-	11	10
3A - Monitoring, Routine, Minor (RTCR) - E. Coli	-	-	16	12



Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
3B - Monitoring, Add. Routine, Major (RTCR) - E. Coli	-	-	2	2
4A - Reporting, Assessment Forms (RTCR) - Revised Total Coliform Rule (RTCR)	-	-	1	1
4B - Report Sample Result/Fail Monitor RTCR - E. Coli	-	-	35	33
4C - Report Startup Procedures Cert Form RtcR - Revised Total Coliform Rule (RTCR)	-	-	10	10
Revised Total Coliform (RTCR) Totals:	43	40	283	196



Sanitary Survey Rule Violations

All PWSs are required to comply with these requirements.

Table 20. Summary of the Sanitary Survey Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
45 - Failure Address Deficiency (GWR) - Groundwater Rule	74	44	-	-
Sanitary Survey (SS) Totals:	74	44	-	-

Storage Tank Rule Violations

All PWSs with storage tanks are required to comply with these requirements.

Table 21. Summary of the Storage Tank Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
ML - State Treatment Technique Level - Storage Tank Rule	76	58	-	-
MS - State Monitoring - Storage Tank Rule	-	-	39	37
Storage Tanks (Tanks) Totals:	76	58	39	37



Surface Water Treatment Rule Violations

Only Surface Water and Groundwater-Under-the-Direct-Influence-of-Surface-Water PWSs are required to comply with these requirements.

Table 22. Summary of the Surface Water Treatment Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
41 - MONTHLY COMB. FILTER EFFLUENT (SWTR)	3	1	-	-
41 - Monthly Comb. Filter Effluent (SWTR - Turbidity)	2	1	-	-
41 - Single Comb. Filter Effluent (Swtr) - SWTR	42	9	-	-
41 - Single Comb. Filter Effluent (SWTR) - Turbidity	1	1	-	-
42 - Failure To Filter (SWTR) - SWTR	10	10	-	-
43 - Single Comb Fltr Effluent (LESWTR/LT1) - Turbidity	9	8	-	-
44 - Monthly Comb Fltr Effluent (LESWTR/LT1) - Turbidity	30	20	-	-
32 - Monitoring, Source (LT2), Major - E. Coli	-	-	29	14
32 - Monitoring, Source (LT2), Minor - E. Coli	-	-	2	2



Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
38 - Monitoring, Routine (LESWTR/LT1), Major - Turbidity	-	-	83	69
38 - Monitoring, Routine (LESWTR/LT1), Minor - Turbidity	-	-	40	12
VC - Equipment Verification or Calibration - Turbidity	-	-	35	35
Surface Water (SW) Totals:	97	43	189	108

Table 23. Summary of the Surface Water Precursors violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
46 - Inadequate DBP Precursor Removal - Carbon, Total	4	1	-	-
27 - Monitoring, Routine (DBP), Major - Alkalinity, Total	-	-	12	5
27 - Monitoring, Routine (DBP), Major - Carbon, Total	-	-	19	5
Precursors (Precursors) Totals:	4	1	31	6



Water Hauler Rule Violations

All PWSs categorized as water haulers are required to comply with this rule.

Table 25. Summary of the Water Hauler Rule violations

Violation Type - Name	Number of HB Violations	Number of PWS with HB Violations	Number of NHB Violations	Number of PWS with NHB Violations
ML - State Treatment Technique Level - Water Hauler Rule	2	2	-	-
MS - State Monitoring - Water Hauler Rule	-	-	2	2
Water Hauler (Hauler) Totals:	2	2	2	2

Exemptions, Variances, and Waivers

Colorado's Safe Drinking Water Program did not issue any variances or exemptions to any public drinking water system in 2024. There are no active prior variances or exemptions in place in Colorado for MCLs. EPA granted the Denver Water Board a variance from the Lead and Copper Rule in 2019 and 2022. In partnership with the EPA, the Safe Drinking Water Program is helping oversee the implementation of the variance. There are state-wide monitoring waivers in place for asbestos, cyanide (except for Cripple Creek and the City of Victor, which are required to monitor for cyanide), and glyphosate (if the system is chlorinating).

Report Availability and Contact Information

This report, data, and specific violations or enforcement actions associated with public water systems are available at <https://cdphe.colorado.gov/dwinfo>.

For further information concerning this report, you may contact Phillip Stanwood with the Safe Drinking Water Compliance Assurance Section by email at Phillip.Stanwood@state.co.us.



Appendix A: PWSs with Health-Based Violations

Table 26. Summary of PWSs with health-based violations and resolution status

PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0219100	4 Eagle Ranch	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0219100	4 Eagle Ranch	Operator Certification (Op Cert)	DBP Stage 1	Yes
Co0219100	4 Eagle Ranch	Disinfection (Dis)	Chlorine	No
CO0150100	A and B WA Inc	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0116104	Advenir French Quarter	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0259108	Agape Outpost Baptist Chapel	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0120001	Agate WA	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0136100	Aguilar Town of	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0136100	Aguilar Town of	Sanitary Survey (SS)	Groundwater Rule	No
CO0161001	Akron Town of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0161001	Akron Town of	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0202450	Alamosa Migrant & Seasonal Head Start	Operator Certification (Op Cert)	DBP Stage 1	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0215115	Alexander Lake Lodge	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0107115	Allenspark WSD	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0221114	Altman Plants	Disinfection (Dis)	Chlorine	Yes
CO0221114	Altman Plants	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0314042	Alvarado CG 4122	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0314042	Alvarado CG 4122	Disinfection (Dis)	Chlorine	No
CO0235185	Annunciation Heights	Disinfection (Dis)	Chlorine	Yes
CO0235185	Annunciation Heights	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0160075	Arabian Acres MD	Sanitary Survey (SS)	Groundwater Rule	No
CO0121050	Arrowhead MHP	Sanitary Survey (SS)	Groundwater Rule	No
CO0208240	Arrowhead Point	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0123123	Asgard Subdivision WA	Nitrogen (NOX)	Nitrate	Yes
CO0149122	Aspen City of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0149122	Aspen City of	Storage Tanks (Tanks)	Storage Tank Rule	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0353050	Aspen Glade CG	Revised Total Coliform (Rtcr)	Revised Total Coliform Rule (RTCR)	No
CO0230122	Aspen Park Community Center	Operator Certification (Op Cert)	DBP Stage 1	No
CO0230122	Aspen Park Community Center	Disinfection (DIS)	Chlorine	No
CO0207133	Balarat Outdoor Laboratory	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0130133	Bancroft Clover WSD	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0145030	Beehive WC No1	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0145030	Beehive WC No1	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0145030	Beehive WC No1	Lead And Copper (LCR)	Lead and Copper Rule Revisions	No
CO0101015	Bellevue Christian College	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0101015	Bellevue Christian College	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0101015	Bellevue Christian College	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0101015	Bellevue Christian College	Disinfection (Dis)	Chlorine	Yes
CO0135143	Big Elk Meadows WA	Cross Connection Control (CCX)	Cross Connection Rule	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0135143	Big Elk Meadows WA	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0221060	Big Pines Campground	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0230006	Black Mountain Ranch	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0207192	Blue Leaf School LLC	Sanitary Survey (SS)	Groundwater Rule	No
CO0226150	Blue Mesa Recreation Ranch	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0220152	Bonnie Blues Event Venue	Disinfection (Dis)	Chlorine	Yes
CO0151150	Boone Town of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0162155	Briggsdale WC	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0149160	Buttermilk MD	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0149160	Buttermilk MD	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0207166	Cal Wood	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0207684	Calvary Boulder Valley	Operator Certification (Op Cert)	DBP Stage 1	No
CO0207684	Calvary Boulder Valley	Disinfection (Dis)	Chlorine	No
CO0307166	Camp Dick CG	Revised Total Coliform (Rtcr)	Revised Total Coliform Rule (RTCR)	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0224166	Camp Eden	Surface Water (SW)	Turbidity	Yes
CO0247020	Camp Rosalie	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0247020	Camp Rosalie	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0143800	Camp V	Sanitary Survey (SS)	Groundwater Rule	No
CO0247027	Campground of the Rockies Assoc	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0111200	Capulin WD	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0218167	Castlewood Community Preschool	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0210009	CDOT Eisenhower Johnson Tunnel	Disinfection (Dis)	Chlorine	No
Co0155500	Center Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0124171	Central City City of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0145090	Cheraw Town of	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	Yes
CO0145090	Cheraw Town of	Radionuclides (Rads)	Combined Radium (-226 & -228)	Yes
CO0116175	Cherry Creek Valley WSD	Cross Connection Control (CCX)	Cross Connection Rule	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0109006	Cheyenne Wells Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0225177	Church of Eternal Hills	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0254183	Clark Store	Disinfection (Dis)	Chlorine	Yes
CO0139180	Clifton WD	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0139180	Clifton WD	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0210001	Climax Henderson Mine	Surface Water (SW)	Turbidity	Yes
CO0225116	Climax Molybdenum Co Henderson Mill	Surface Water (SW)	Turbidity	Yes
CO0151200	Colorado City MD	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0151200	Colorado City MD	Sanitary Survey (SS)	Groundwater Rule	No
CO0123170	Colorado Mtn College Svc	Lead And Copper (LCR)	Lead and Copper Rule Revisions	No
CO0241186	Colowyo Coal Company	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0230004	Conifer Community Park at Beaver Ranch	Disinfection (Dis)	Chlorine	No
CO0230225	Conifer High School	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0230225	Conifer High School	TTHM and HAA5 (DBP - TTHM and HAA5)	Total Haloacetic Acids (HAA5)	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0135315	Consolidated Glacier View Meadows Assoc	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0135315	Consolidated Glacier View Meadows Assoc	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0218011	Core Electric Cooperative	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0222230	Cotopaxi School	Surface Water (SW)	Turbidity	Yes
CO0221179	Cottonwood Hot Springs	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0218046	Cottonwood Riding Club	Operator Certification (Op Cert)	DBP Stage 1	No
CO0218046	Cottonwood Riding Club	Disinfection (Dis)	Chlorine	Yes
CO0101188	Creekside South Estates Metro District	Inorganics (IOCs)	Arsenic	No
CO0155188	Crestone WS	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0155188	Crestone WS	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0234320	Cross Bar X Youth Ranch	Disinfection (Dis)	Chlorine	Yes
CO0230052	Crossroads Restaurant	Nitrogen (NOX)	Nitrate	Yes
CO0247200	Crow Hill Bible Church	Disinfection (Dis)	Chlorine	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0247200	Crow Hill Bible Church	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0362001	Crow Valley Campground	Disinfection (Dis)	Chlorine	No
CO0113100	Crowley County WA	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0260040	Crystola Bar and Grill	Surface Water (Sw)	Turbidity	No
Co0260040	Crystola Bar and Grill	Disinfection (Dis)	SWTR	No
CO0219170	CSLB 41149 US 6	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0207785	CU Mountain Research Station	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0207785	CU Mountain Research Station	Surface Water (SW)	SWTR	Yes
CO0207785	CU Mountain Research Station	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0128100	Cucharas Sanitation and Water District	Disinfection (Dis)	Chlorine	No
CO0153200	Del Norte Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0153200	Del Norte Town of	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0115205	Delta City of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0252838	Deserado Mine	Surface Water (SW)	SWTR	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0241210	Dinosaur Mnt Echo Park CG	Disinfection (Dis)	Chlorine	No
CO0241210	Dinosaur Mnt Echo Park CG	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0241200	Dinosaur Natl Mnt Hdqtrs	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0241200	Dinosaur Natl Mnt Hdqtrs	Disinfection (Dis)	Chlorine	Yes
CO0141210	Dinosaur Town of	Lead And Copper (LCR)	Lead & Copper Rule	Yes
CO0160275	Divide South	Surface Water (SW)	Turbidity	Yes
CO0117300	Dove Creek Town of	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	No
CO0117300	Dove Creek Town of	Lead And Copper (LCR)	Lead and Copper Rule Revisions	No
CO0335217	Dowdy Lake East CG	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0335218	Dowdy Lake West Shore CP Arap	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0225222	Drowsy Water Ranch	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0225222	Drowsy Water Ranch	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0134150	Durango City of	Cross Connection Control (CCX)	Cross Connection Rule	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0134225	Durango Falga MHC LLC	Surface Water (SW)	SWTR	No
CO0134510	Durango JCMHP, LLC	Surface Water (SW)	SWTR	No
CO0234800	Durango RV Park	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0335225	Dutch George CG	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0119234	Eagle River Village MHP	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0219234	Eagle Springs Golf Club	Disinfection (Dis)	Chlorine	Yes
CO0145120	East End WA	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0145120	East End WA	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0162233	Eaton Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0242150	Echo Basin Ranch	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0242150	Echo Basin Ranch	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0242150	Echo Basin Ranch	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0163001	Eckley Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0135237	Eden Valley Institute	Surface Water (SW)	Turbidity	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0135237	Eden Valley Institute	Lead and Copper (LCR)	Lead and Copper Rule Revisions	Yes
CO0121246	El Morro Mobile Estates	Operator Certification (Op Cert)	Dbp Stage 1	Yes
CO0207466	Eldora Mountain Resort	TTHM and HAA5 (DBP - TTHM and HAA5)	Total Haloacetic Acids (Haa5)	Yes
CO0253200	Emmanuel Chapel	Nitrogen (NOX)	Nitrite	Yes
CO0218250	Encompass Preschool	Lead And Copper (LCR)	Lead & Copper Rule	Yes
CO0145150	Eureka WC	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0145150	Eureka WC	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0145150	Eureka WC	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0145150	Eureka WC	Lead and Copper (LCR)	Lead & Copper Rule	No
CO0254138	Euzoa Bible Church	Disinfection (Dis)	Chlorine	Yes
CO0221418	Farish Memorial Ctr 2 USAF	Surface Water (SW)	SWTR	Yes
CO0235267	Fawn Valley Inn	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0145180	Fayette WC	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0145180	Fayette WC	Radionuclides (Rads)	Combined Radium (-226 & -228)	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0235506	Fire Mountain Programs	Nitrogen (NOX)	Nitrate	No
CO0234350	Five Branches Camper Park	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0234350	Five Branches Camper Park	Disinfection (Dis)	Groundwater Rule	No
CO0234350	Five Branches Camper Park	Sanitary Survey (SS)	Groundwater Rule	No
CO0234350	Five Branches Camper Park	Disinfection (Dis)	Chlorine	No
CO0234350	Five Branches Camper Park	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0122500	Florence City of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0160175	Florissant WSD	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0160175	Florissant WSD	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0160175	Florissant WSD	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0160175	Florissant WSD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0153285	Foothills WS	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0130033	Forest Hills MD Riva Chase	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0106900	Fort Lyon	Storage Tanks (Tanks)	Storage Tank Rule	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0145210	Fowler Town of	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	Yes
CO0154285	Fox Estates HOA	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0159055	Frisco Town of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0159055	Frisco Town of	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0115288	Fruitland Domestic WC	Sanitary Survey (SS)	Groundwater Rule	No
CO0115288	Fruitland Domestic WC	Lead and Copper (LCR)	Lead and Copper Rule Revisions	Yes
CO0221446	Fuel BS Convenience Store	Nitrogen (NOX)	Nitrate	No
CO0153300	G and M Mobile Home Park	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0153300	G and M Mobile Home Park	Disinfection (Dis)	Chlorine	No
CO0101060	Galamb's Mobile Home and RV Park	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0101060	Galamb's Mobile Home and RV Park	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0103095	Galbraith Estates	Nitrogen (NOX)	Nitrate	Yes
CO0120300	Gambel Oaks HOA	Disinfection (Dis)	Chlorine	No
CO0112700	Garcia Domestic WUA	Lead and Copper (LCR)	Lead and Copper Rule Revisions	Yes
CO0121325	Garden Valley	Cross Connection Control (C)CX	Cross Connection Rule	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0121325	Garden Valley	Sanitary Survey (SS)	Groundwater Rule	No
CO0121325	Garden Valley	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0207485	Gates Camp	Disinfection (Dis)	Chlorine	No
CO0221302	Gateway Childcare and Preschool	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0221302	Gateway Childcare and Preschool	Lead and Copper (LCR)	Lead & Copper Rule	No
CO0235317	Glen Echo Resort	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0247039	Glen Isle Resort	Nitrogen (NOX)	Nitrate	No
CO0103055	Glendale City of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0211318	Gold Pan RV and Cabins	Operator Certification (Op Cert)	DBP Stage 1	No
CO0221450	Golden Eagle Ranch	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0334620	Graham Cr North Canyon CG	Disinfection (Dis)	Chlorine	Yes
CO0150300	Granada Town of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0150300	Granada Town of	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0150300	Granada Town of	Sanitary Survey (SS)	Groundwater Rule	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0150300	Granada Town of	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0225338	Granby Ranch Amenities	Disinfection (Dis)	Chlorine	Yes
CO0225338	Granby Ranch Amenities	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0125323	Grand County Water No 1	Surface Water (SW)	Turbidity	Yes
CO0202300	Great Sand Dunes HQ	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0162321	Greeley City of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0156300	Grizzly Peak Water Sales	Lead and Copper (LCR)	Lead and Copper Rule Revisions	Yes
CO0126220	Gunnison County WSD	Cross Connection Control (Ccx)	Cross Connection Rule	Yes
CO0215325	Gunnison River Pleasure Park	Operator Certification (Op Cert)	DBP Stage 1	No
CO0150500	Hartman Town of	Operator Certification (Op Cert)	DBP Stage 1	No
CO0150500	Hartman Town of	Sanitary Survey (SS)	Groundwater Rule	No
CO0150500	Hartman Town of	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0106200	Hasty WC	Radionuclides (Rads)	Combined Radium (-226 & -228)	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0106200	Hasty WC	Lead and Copper (LCR)	Lead & Copper Rule	Yes
CO0131600	Haswell Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0131600	Haswell Town of	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0234339	Hesperus Baptist Camp Inc	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0254342	Hidden Springs Ranch	Disinfection (Dis)	Chlorine	Yes
CO0115342	Hidden Valley HOA Water Company	Operator Certification (Op Cert)	DBPStage 1	Yes
CO0130045	Hidden Valley Water District	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0130045	Hidden Valley Water District	Lead and Copper (LCR)	Lead and Copper Rule Revisions	Yes
CO0160200	Highland Lakes WD	Surface Water (SW)	SWTR	No
CO0207343	Highlands Presbyterian Camp	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0207343	Highlands Presbyterian Camp	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0207343	Highlands Presbyterian Camp	Sanitary Survey (SS)	Groundwater Rule	No
CO0235345	Hill Top General Store	Surface Water (SW)	Turbidity	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0235345	Hill Top General Store	Revised Total Coliform (RTCR)	E. Coli	Yes
CO0145330	Holbrook Center Soft WA	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0150600	Holly Town of	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0226352	Holts Guest Ranch	Disinfection (Dis)	Chlorine	Yes
CO0130050	Homestead WC	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0130050	Homestead WC	Lead and Copper (LCR)	Lead & Copper Rule	No
CO0111525	Horca Subd Red Bear Inn	Inorganics (IOCs)	Cadmium	No
CO0137010	Hugo Town of	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0110020	Idaho Springs City of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0263003	Idalia School	Sanitary Survey (SS)	Groundwater Rule	No
CO0130055	Idledale WSD	Surface Water (SW)	SWTR	No
CO0107401	Jamestown Town of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0107401	Jamestown Town of	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0235618	Jellystone Park of Estes Park	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0235618	Jellystone Park of Estes Park	Storage Tanks (Tanks)	Storage Tank Rule	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0162418	Johnstown Town of	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0201039	Joseph T Ryerson and Son Inc	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0158001	Julesburg Town of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0158001	Julesburg Town of	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0158001	Julesburg Town of	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0162438	Keenesburg Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0162438	Keenesburg Town Of	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0121415	Keeton Ranch Water	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0162439	Kersey WD	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0162439	Kersey WD	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0159065	Keystone Ranch	Lead and Copper (LCR)	Lead & Copper Rule	No
CO0109011	Kit Carson Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0251470	KOA Pueblo S Colorado City	Disinfection (Dis)	Chlorine	Yes
CO0162466	La Salle Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0128500	La Veta Town of	TTHM and HAA5 (DBP - TTHM and HAA5)	Total Haloacetic Acids (HAA5)	Yes
CO0247466	Lake George Charter School	Lead and Copper (LCR)	Lead & Copper Rule	No
CO0118030	Larkspur Town of	Radionuclides (Rads)	Combined Radium (-226 & -228)	Yes
CO0115467	Lazear Domestic WC	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0121425	Lazy Days MHV	Operator Certification (Op Cert)	DBP Stage 1	No
CO0228566	LDS Joseph	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0228566	LDS Joseph	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0263400	Liberty School	Operator Certification (Op Cert)	DBP Stage 1	No
CO0263400	Liberty School	Disinfection (Dis)	Chlorine	No
CO0110026	Lookout Mountain WD	TTHM and HAA5 (DBP - TTHM and HAA5)	Total Haloacetic Acids (HAA5)	Yes
CO0110026	Lookout Mountain WD	TTHM and HAA5 (DBP - TTHM and HAA5)	TTHM	Yes
CO0118035	Louviers WSD	Radionuclides (Rads)	Combined Radium (-226 & -228)	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0210016	Loveland Valley Ski Area	Surface Water (SW)	Turbidity	Yes
CO0359450	Lowry CG Prospector Cg	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0247500	M Lazy C Ranch	Nitrogen (NOX)	Nitrate	No
CO0142600	Mancos Rural Water Company	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0121450	Manitou Springs City of	Surface Water (SW)	Turbidity	Yes
CO0145450	Manzanola Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0145450	Manzanola Town of	Sanitary Survey (SS)	Groundwater Rule	No
CO0145450	Manzanola Town of	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0145450	Manzanola Town of	Radionuclides (Rads)	Combined Uranium	No
CO0145450	Manzanola Town of	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0107502	Maple Grove WD	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0226500	Marble WC	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0226500	Marble WC	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0150800	May Valley WA	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0150800	May Valley WA	Radionuclides (Rads)	Combined Radium (-226 & -228)	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0235503	Mcgregor Mtn Lodge	Disinfection (Dis)	Chlorine	Yes
CO0207506	Meeker Park Lodge	Surface Water (SW)	Turbidity	Yes
CO0207506	Meeker Park Lodge	Disinfection (Dis)	Chlorine	Yes
CO0152505	Meeker Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0138025	Merino Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0107510	Mile Hi Water Inc Hauler	Water Hauler (Hauler)	Water Hauler Rule	No
CO0123510	Mitchell Cooper Ditch Pipeline	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0123510	Mitchell Cooper Ditch Pipeline	Surface Water (SW)	SWTR	Yes
CO0155518	Moffat Town of	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0155518	Moffat Town of	Sanitary Survey (SW)	Groundwater Rule	No
CO0155518	Moffat Town of	Disinfection (Dis)	Chlorine	No
CO0108420	Monarch Mountain Lodge	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0108420	Monarch Mountain Lodge	Surface Water (SW)	Turbidity	Yes
CO0108420	Monarch Mountain Lodge	Sanitary Survey (SS)	Groundwater Rule	No
CO0108420	Monarch Mountain Lodge	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0142800	Montezuma Cnty WD No 1	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0321525	Monument Work Center No 1	Lead and Copper (LCR)	Lead & Copper Rule	No
CO0233700	Moose Haven Condos	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0233700	Moose Haven Condos	Disinfection (Dis)	Chlorine	Yes
CO0241338	Moser LLC	Sanitary Survey (SS)	Groundwater Rule	No
CO0335518	Mountain Park CG	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0206524	Mountain Prairie LLC	Disinfection (Dis)	Chlorine	Yes
CO0123519	Mountain Valley MHP	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0101100	Mountain View WUA	Lead and Copper (LCR)	Lead and Copper Rule Revisions	Yes
CO0130100	Mountain WSD	Surface Water (SW)	Turbidity	Yes
CO0222518	Mountaindale CG and Cabins	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0222518	Mountaindale CG and Cabins	Disinfection (Dis)	Groundwater Rule	No
CO0222518	Mountaindale CG and Cabins	Sanitary Survey (SS)	Groundwater Rule	No
CO0233524	Mt Massive Golf Course	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0143525	Mustang Water Authority	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0104533	Navajo River Ranch POA	Surface Water (SW)	Turbidity	No
CO0128600	Navajo Western WD Resorts	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0162710	New Vision MHP	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0247552	North Fork Guest Ranch	Nitrogen (NOX)	Nitrate	No
CO0145630	North Holbrook WC	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0101110	North Washington WUA	Cross Connection Control (CCX)	Cross Connection Rule	No
Co0101110	North Washington WUA	Sanitary Survey (SS)	Groundwater Rule	No
CO0157500	Norwood Water Commission	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0135600	Nueva Vida Mobile Home Park	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0154566	Oak Creek Town of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0154566	Oak Creek Town of	Surface Water (SW)	Turbidity	Yes
CO0154566	Oak Creek Town of	Surface Water (SW)	SWTR	No
CO0154566	Oak Creek Town of	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0226730	Oasis Gunnison Lakeside	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0234440	Oasis RV Resort	Surface Water (SW)	SWTR	Yes
CO0143582	Olathe Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0125246	Olympic Village	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0262508	Opal Foods LLC Hudson Farm	Sanitary Survey (SS)	Groundwater Rule	No
CO0262153	Opal Foods LLC Roggen Farm	Disinfection (Dis)	Groundwater Rule	Yes
CO0157600	Ophir Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0157600	Ophir Town of	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0157600	Ophir Town of	Surface Water (SW)	SWTR	Yes
CO0157600	Ophir Town of	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0146588	Ouray City of	Surface Water (SW)	SWTR	Yes
CO0153400	Pacheco Trailer Park	Operator Certification (Op Cert)	DBP Stage 1	No
CO0153400	Pacheco Trailer Park	Disinfection (Dis)	Chlorine	No
CO0144025	Pagels TP	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0144025	Pagels TP	Radionuclides (Rads)	Combined Uranium	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0148010	Paoli Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0148010	Paoli Town of	Lead and Copper (LCR)	Lead and Copper Rule Revisions	Yes
CO0143600	Paradox Pipeline Co	Sanitary Survey (SS)	Groundwater Rule	No
CO0145540	Patterson Valley WC	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0145540	Patterson Valley WC	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0262333	Peak Oilfield Services LLC	Water Hauler (Hauler)	Water Hauler Rule	Yes
CO0138030	Peetz Town of	Sanitary Survey (SS)	Groundwater Rule	No
CO0254605	Perry Mansfield Camp	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0104700	Piedra Park MD	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0249610	Pine Creek Cookhouse	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0151450	Pine Drive WD	Precursors (Precursors)	Carbon, Total	No
CO0135610	Pinewood Springs WD	Disinfection (Dis)	Chlorine	No
CO0135610	Pinewood Springs WD	TTHM And HAA5 (DBP - TTHM And HAA5)	Total Haloacetic Acids (HAA5)	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0135610	Pinewood Springs WD	TTHM And HAA5 (DBP - TTHM And HAA5)	TTHM	No
CO0219806	Piney River Ranch	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0121625	Pioneer Lookout WD	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0239615	Plateau Valley School Dist 50	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0108650	Poncha Springs Town of	Lead and Copper (LCR)	Lead & Copper Rule	No
CO0208720	Ponderosa Lodge Inc	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0208720	Ponderosa Lodge Inc	Operator Certification (Op Cert)	DBP Stage 1	No
CO0118050	Ponderosa Retreat and Conference Ctr	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0135627	Poudre Valley MHC	Disinfection (Dis)	Chlorine	No
CO0144621	Prairie View Ranch WD	Sanitary Survey (SS)	Groundwater Rule	No
CO0105300	Pritchett Town of	Radionuclides (Rads)	Combined Radium (-226 & -228)	Yes
CO0210624	Ptarmigan Warming Hut	Nitrogen (NOX)	Nitrate	Yes
CO0151650	Pueblo West MD	TTHM And HAA5 (DBP - TTHM And HAA5)	TTHM	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0159100	Quandry Condos Skiers Edge	Sanitary Survey (SS)	Groundwater Rule	No
CO0226630	Ragged Mountain Camp	Surface Water (SW)	SWTR	Yes
CO0226630	Ragged Mountain Camp	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0208678	Rainbow Lake Resort	Surface Water (SW)	Turbidity	No
CO0208678	Rainbow Lake Resort	Disinfection (Dis)	Chlorine	No
CO0121675	Ramah Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0121675	Ramah Town of	Sanitary Survey (SS)	Groundwater Rule	No
CO0253666	Ramons Mexican	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0123667	Ranch at Roaring Fork	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0235666	Ravencrest Chalet	TTHM And HAA5 (DBP - TTHM And HAA5)	TTHM	No
CO0235677	Red Feather Mountain Library District	Surface Water (SW)	SWTR	Yes
CO0146676	Ridgway Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0123676	Rifle City of	TTHM And HAA5 (DBP - TTHM And HAA5)	TTHM	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0223680	Rio Blanco Ranch Company	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0253420	Rio Grande Meadows RV Park	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0140800	Rivercrest Acres HOA	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0145570	Riverside WC	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0201683	Rocky Mountain Rail Park	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0235686	Rocky Ridge Music Center	Surface Water (SW)	SWTR	Yes
CO0235686	Rocky Ridge Music Center	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0115685	Rogers Mesa WC	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0103081	Rolling Plains Estate	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0224685	Rollinsville West Center LLC	Disinfection (Dis)	Chlorine	Yes
CO0215683	Root and Vine Market	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0326685	Rosy Lane CG	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0222730	Royal Gorge Bridge Co of Colo	Storage Tanks (Tanks)	Storage Tank Rule	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0222730	Royal Gorge Bridge Co of Colo	Surface Water (SW)	Turbidity	No
CO0151700	Rye Town of	Surface Water (SW)	Turbidity	No
CO0151700	Rye Town of	TTHM And HAA5 (DBP - TTHM And HAA5)	Total Haloacetic Acids (HAA5)	No
CO0151700	Rye Town of	Lead and Copper (LCR)	Lead & Copper Rule	No
CO0219224	Sage Outdoor Adventures LLC	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0262676	Salt & Acres	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0112850	San Acacio Domestic WA	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0157701	San Bernardo HOA	Lead and Copper (LCR)	Lead & Copper Rule	Yes
CO0260700	Sanborn Western Camps	Nitrogen (NOX)	Nitrate	Yes
CO0107702	Sans Souci MHP	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0136700	Santa Fe Trail Ranch MD	Lead and Copper (LCR)	Lead and Copper Rule Revisions	Yes
CO0163706	Seaboard Foods LLC	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0158010	Sedgwick Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0158010	Sedgwick Town of	Storage Tanks (Tanks)	Storage Tank Rule	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0235685	Shambhala Mountain Center	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0235685	Shambhala Mountain Center	Disinfection (Dis)	Chlorine	Yes
CO0131800	Sheridan Lake WD	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0131800	Sheridan Lake WD	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0131800	Sheridan Lake WD	Sanitary Survey (SS)	Groundwater Rule	No
CO0131800	Sheridan Lake WD	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0210005	Shwayder Camp Temple Emanuel	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0251743	Signal Mountain Ranch Property Owners WC	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0251743	Signal Mountain Ranch Property Owners WC	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0218028	Silver State Baptist Youth Camp	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0126185	Ski Town Village	Surface Water (SW)	SWTR	No
CO0260780	Sky High Scout Ranch	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0211900	Sky Line Lodge	Operator Certification (Op Cert)	DBP Stage 1	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0211900	Sky Line Lodge	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0154715	Sleepy Bear MHP	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0149717	Snowmass Village WSD	Disinfection (Dis)	Chlorine	Yes
CO0126715	Somerset Domestic WD	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0126715	Somerset Domestic WD	TTHM And HAA5 (DBP - TTHM And HAA5)	TTHM	Yes
CO0101140	South Adams County WSD	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0253810	South Fork Lodge	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0253870	South Fork Ute Bluff Lodge Inc	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0145660	South Side WA	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0145660	South Side WA	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0145690	South Swink WA	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0145690	South Swink WA	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0110040	St Marys Glacier WSD	Surface Water (SW)	Turbidity	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0110040	St Marys Glacier WSD	Sanitary Survey (SS)	Groundwater Rule	No
CO0110040	St Marys Glacier WSD	Disinfection (Dis)	Chlorine	Yes
CO0254726	Steamboat Golf Club Inc	Surface Water (SW)	SWTR	No
CO0254726	Steamboat Golf Club Inc	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0254726	Steamboat Golf Club Inc	Sanitary Survey (SS)	Groundwater Rule	No
CO0254726	Steamboat Golf Club Inc	Disinfection (Dis)	Chlorine	No
CO0254726	Steamboat Golf Club Inc	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0154724	Steamboat II MD	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0154724	Steamboat II MD	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0154724	Steamboat II MD	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0254842	Steamboat Mountain School	Surface Water (SW)	Turbidity	Yes
CO0254842	Steamboat Mountain School	Surface Water (SW)	SWTR	Yes
CO0254842	Steamboat Mountain School	TTHM And HAA5 (DBP - TTHM And HAA5)	Total Haloacetic Acids (HAA5)	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0138045	Sterling City of	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0236700	Stonewall Shopping Bag	Ground Water (GW)	Groundwater Rule	No
CO0236700	Stonewall Shopping Bag	Disinfection (Dis)	Chlorine	Yes
CO0236700	Stonewall Shopping Bag	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0101145	Strasburg WSD	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0101145	Strasburg WSD	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0101145	Strasburg WSD	Sanitary Survey (SS)	Groundwater Rule	No
CO0113900	Sugar City Town of	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0233850	Sugar Loafin RV Campground	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0123500	Sun Meadow Estates	TTHM And HAA5 (DBP - TTHM And HAA5)	TTHM	Yes
CO0123500	Sun Meadow Estates	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0235726	Sundance Trail Guest Ranch	Disinfection (Dis)	Groundwater Rule	No
CO0222724	Sweetwater River Ranch	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0222724	Sweetwater River Ranch	Disinfection (Dis)	Chlorine	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0222724	Sweetwater River Ranch	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0145720	Swink Town of	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0145720	Swink Town of	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0235729	Sylvan Dale Ranch	Disinfection (Dis)	Chlorine	Yes
CO0219729	Sylvan Lake State Park	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0107733	Table Mesa Village MHP	Disinfection (Dis)	Chlorine	Yes
CO0262735	Tagawa Greenhouses Inc	Nitrogen (NOX)	Nitrate	Yes
CO0226736	Taylor Park Trading Post	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0226736	Taylor Park Trading Post	Disinfection (Dis)	Groundwater Rule	Yes
CO0329324	Teal Lake CG	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0157900	Telluride Pines HOA	Lead and Copper (LCR)	Lead & Copper Rule	Yes
CO0157800	Telluride Town of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0157800	Telluride Town of	Surface Water (SW)	SWTR	Yes
CO0226742	Three Rivers Resort	Cross Connection Control (CCX)	Cross Connection Rule	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0259036	Tiger Run HOA RV Park	Disinfection (Dis)	Chlorine	Yes
CO0325743	Timber Creek CG	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0325743	Timber Creek CG	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0259003	Timber Creek WD	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0224752	Toss Wood Fired Eatery	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0224752	Toss Wood Fired Eatery	Sanitary Survey (SS)	Groundwater Rule	No
CO0225750	Town of Winter Park Lift Transit WTS	Disinfection (Dis)	Groundwater Rule	Yes
CO0160650	Tranquil Acres WS	Sanitary Survey (SS)	Groundwater Rule	No
CO0128726	Tres Valles West	Surface Water (SW)	Turbidity	Yes
CO0212400	Trinchera Property Management Inc	Inorganics (IOCs)	Cadmium	No
CO0353750	Trujillo Meadows CG	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0247015	Tumbling River Ranch	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	Yes
CO0333790	Turquoise Lake Rec Area	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0333790	Turquoise Lake Rec Area	Surface Water (SW)	SWTR	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0333790	Turquoise Lake Rec Area	Sanitary Survey (SS)	Groundwater Rule	No
CO0114550	Tv Hills Water	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0230063	Twins Inn Inc	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0105700	Two Buttes Town of	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0105700	Two Buttes Town of	Radionuclides (Rads)	Combined Radium (-226 & -228)	Yes
CO0115784	Upper Surface Creek Domestic WUA	TTHM And HAA5 (DBP - TTHM And HAA5)	Total Haloacetic Acids (HAA5)	Yes
CO0115784	Upper Surface Creek Domestic WUA	Lead and Copper (LCR)	Lead & Copper Rule	No
CO0252620	Ute Lodge	Disinfection (Dis)	Chlorine	No
CO0219800	Vail Assoc Midvail Eagle	Storage Tanks (Tanks)	Storage Tank Rule	Yes
CO0219800	Vail Assoc Midvail Eagle	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0234880	Vallecito Resort	Disinfection (Dis)	Chlorine	Yes
CO0223800	Valley Investment Properties	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0102300	Valley Mobile Home LLC	Sanitary Survey (SS)	Groundwater Rule	No
CO0102300	Valley Mobile Home LLC	Disinfection (Dis)	Chlorine	Yes



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0102300	Valley Mobile Home LLC	Inorganics (IOCs)	Arsenic	Yes
CO0145750	Valley WC	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0145750	Valley WC	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0134900	Van Den Berg MD	Operator Certification (Op Cert)	DBP Stage 1	Yes
CO0239750	Vega State Park Oak Point	Revised Total Coliform (RTCR)	Revised Total Coliform Rule (RTCR)	No
CO0160700	Victor City of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0160700	Victor City of	TTHM And HAA5 (DBP - TTHM And HAA5)	Total Haloacetic Acids (HAA5)	Yes
CO0254810	Vista Verde Guest Ranch	Disinfection (Dis)	Chlorine	Yes
CO0132025	Vona Town of	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0145780	Vroman WC	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0145780	Vroman WC	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0128900	Walsenburg City of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0128900	Walsenburg City of	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0105900	Walsh Town of	Nitrogen (NOX)	Nitrate	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0105900	Walsh Town of	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0201833	Watkins Square	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0162833	Wattenburg Improvement Assoc	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0135838	Wellington Town of	Surface Water (SW)	Turbidity	Yes
CO0145810	West Grand Valley WA	Radionuclides (Rads)	Gross Alpha, Excl. Radon & U	No
CO0145810	West Grand Valley WA	Radionuclides (Rads)	Combined Radium (-226 & -228)	No
CO0333890	White Star Host Site	Sanitary Survey (SS)	Groundwater Rule	Yes
CO0144035	Wiggins Town of	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0207843	Wild Basin Lodge	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0247325	Wild Spirit Mountain Lodge LLC	Nitrogen (NOX)	Nitrate	No
CO0249843	Wildwood School	Lead and Copper (LCR)	Lead and Copper Rule Revisions	Yes
CO0160900	Woodland Park City of	Lead and Copper (LCR)	Lead and Copper Rule Revisions	No
CO0160950	Woodland West WUA	Storage Tanks (Tanks)	Storage Tank Rule	No
CO0251700	Xcel Energy Comanche Plant	TTHM And HAA5 (DBP - TTHM And HAA5)	TTHM	No



PWS ID	Water System Name	Violation Type	Contaminant Name	Resolved as of 12/31/2024?
CO0254185	Xcel Energy Hayden Station	Surface Water (SW)	Turbidity	No
CO0254185	Xcel Energy Hayden Station	Lead and Copper (LCR)	Lead & Copper Rule	Yes
CO0154900	Yampa Town of	Cross Connection Control (CCX)	Cross Connection Rule	Yes
CO0154900	Yampa Town of	Disinfection (Dis)	Chlorine	Yes
CO0251950	Ymca Camp Jackson	Surface Water (SW)	Turbidity	Yes
CO0251950	Ymca Camp Jackson	Disinfection (Dis)	Chlorine	Yes
CO0135883	Ymca Rockies Wind River	Cross Connection Control (CCX)	Cross Connection Rule	No
CO0225918	Young Life Crooked Creek	Storage Tanks (Tanks)	Storage Tank Rule	Yes

